

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	1	85									
2	NLG	3	110									
3	MDK	6	81									
4	RR(S)	10	102		1		1		1			
5	RR(N)	45	271		1		1		1			
6	RR(E)	33	203									
7	Hyd	135	837		1		1		1			
	Total	233	1689	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	78	891	1	4	1	4		4	1		1 no.33kv still
2	NLG	109	738		4		4		4			
3	MDK	79	690		1		1		1			
4	RR(S)	31	341									
5	RR(N)	8	48									
6	RR(E)	15	78									
	Total	320	2786	1	9	1	9	0	9	1	0	
	Grand Total	553	4475	1	12	1	12	0	12	1	0	

TSSPDCL - LMRC / Corporate office

Date: 10.08.2016

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthy	Revally	33kv	Wanaparthy	17.20	Still		E/L & O/L	Only Revally Supply OK	Gopalpet, Revally, P.K Pally, Thudkurthy, Chennaram, Remaddula	Jumpers open at 33KV Chennaram SS at 17:37 & Incoming AB Switch Opened at 33KV Revally at 18:40Hrs

TSSPDCL - LMRC / Corporate office

Date: 10.08.2016

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Rakonda	Rakonda	11KV	Nagarkurnool	07.00	12.30	05.30		11KV Wire cut at Rakonda AGL	-
2		lthole	lthole	11KV	Nagarkurnool	13.30	14.30	01.00		Phase to Phase Near Antharam(V)	-
3		Peddur	Peddur	11KV	Nagarkurnool	07.15	12.15	05.00		11KV Wire Cut Near Peddur(V)	-
4		Teegalapally	Kakula Gattu	11KV	Nagarkurnool	10.30	13.30	03.00		11KV Wire Cut Near Kakula Gattu	-
1	NLG	Repala	Repala	11KV	Huzurnagar	07.15	08.40	01.25	EL	11 kv line snapped at Repala village	-
2		Edloor	Naregudem	11KV	Suryapet	04.00	07.00	03.00	EL	Line cut	-
3		K.M.Pally	Palvai	11KV	Devarakonda	07.00	10.00	03.00	EL	Jumper cut	-
4		Yerraram	T.P.Gouraram	11KV	Devarakonda	10.00	12.00	02.00	EL	Insulator failed	-
1	MDK	Chatlapally	Chatlapally Agl	11KV	Toopran	05.40	07.05	01.25		B/D due to Jumper cut	-
1	RR S	Moinabad	Enkepally	11KV	RJNR	16.35	18.00	01.25		Bird Fallen on 11 KV Line at Enkepally	-
1	RR N	Jeedimetla -I	USP Organics	11KV	KKP	15.41	17.11	01.30	BD	11kv line Jumper Cut near Mylon Company at Phase-I	-
1	HYD N	Patigadda	Sanjeevaiah Park	11KV	V	16.15	17.18	01.03	EL	Cable fault near Sanjeevaiah Park	Arranged B/F on 11KV Kamath Lingapur fdr