

TSSPDCL - LMRC / Corporate office

Date: 28.08.16

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Thungathurthy	Panigiri	33KV	Suryapet	10:00	13:40	3:40	E/L	33KV Insulator failed	Panigiri	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kodagal	Kodagal	11KV	Jadcherla	04.00	08.00	04.00		11KV Wire cut near Kodgal	No
2		Boothpur	Amistapur	11KV	Jadcherla	01.30	06.45	05.15		11KV Wire cut near Seripally	No
3		Kadthal	Ravichode 24 hours	11KV	Jadcherla	00.00	08.15	08.15		Insulator fail near Tahraj guda	No
1	NLG	Yerraram	Kampally	11KV	Devarakonda	08.00	11:00	03.00	E/L	11KV Jumper cut	No
2		Marriguda	Thandampally	11KV	Devarakonda	05.00	08.00	03.00	E/L	11KV Jumper cut	No
3		Marriguda	Vattipally	11KV	Devarakonda	07.00	11:00	04.00	E/L	11KV Insulator failed	No
4		Alingapuram	Raghavapuram	11KV	Huzurnagar	08.10	10:10	02.00	E/L	Transfarmer failed at Raghvapuram village	No
5		Raghunadapalem	Gundlapally	11KV	Huzurnagar	12:20	13:20	01.00	E/L	11KV Line snapped at Gundlapally village	No
6		Marrur	Marrur	11KV	Suryapet	13:35	17:25	03.50	E/L	11KV Insulator failed	No
7		Jelalpuram	Velishala	11KV	Suryapet	10:00	11:30	01.30	E/L	11KV Jumper cut	No
8		Akaram	Vaddipamula	11KV	Suryapet	15:40	18:00	02.20	E/L	11KV Jumper cut	No
9		Chikatimamedi	Kompally	11KV	Nalgonda	09.00	11.00	02.00	E/L	Tree fallen on the line	No
10		Nemani	Merlakunta	11KV	Nalgonda	05.00	08.30	03.30	E/L	11KV Line snapped	No
11		Pulemla	Pulemla(Agl)	11KV	Nalgonda	04.30	07.30	03.00	E/L	11KV Disc failed	No
12		Urumadla	Elikate	11KV	Nalgonda	05.30	08.30	03.00	E/L	11KV Jumper cut	No
1	MDK	Chippalthurthy	Jakkapally	11KV	Medak	10:00	12:15	2:15		11 kv Jumper cut at imbrahimbad	No
2		Chippalthurthy	Chippalthurthy	11KV	Medak	12.15	14.15	02.00		Insulator failed	No
1	RR S	Mallapur	Al Jabri Colony	11KV	CPT	0:17	6:25	6:08		11KV Pin insulator failed at Al Jabri Colony	No
2		Mamidipally	Pahadishareef	11KV	CPT	01.05	05.50	04.45		11KV Insulator failed at Pahadishareef	No
3		Leninnagar	Meerpet	11KV	CPT	00.40	10.56	10.16		11KV insulator failed at Badangpet	No
4		Champapet	Padmanagar	11KV	CPT	00.25	01.50	01.25		Line petroling no fault	No
5		Kattedan-II	Jalpally	11KV	RJNR	00.10	02.05	01.55		No Visible Fault Due To Heavy Rain	No
6		Kattedan-I	Gangothri	11KV	RJNR	0:30	2:00	1:30		No Visible Fault Due To Heavy Rain	No
1	RR N	JDM-II	SRC Naiknagar	11KV	Kukatpally	0:00	3:00	3:00	BD	11KV End kit failure near rock flour mill Phase-III Due to heavy rain	No
2		JDM-IV	Aaimatha	11KV	Kukatpally	02.15	03.15	01.00	BD	11kv Line cut near Little star School Aaimatha Colony	No
3		Suraram	Venkram Nagar	11KV	Kukatpally	00.00	01.50	01.50	BD	11kv Line post of insulator failed at Sai srinivas apartment Venakatramnagar	No
4		Vijayangar	Shanthinagar	11KV	Kukatpally	01.20	02.30	01.10	BD	11kv Pin insulator failed at Badradri Apartment Shanthinagar	No
5		KPHB	Adityanagar	11KV	Kukatpally	02.30	03.30	01.00	BD	11kv Pin insulator failed at Tulsinagar	No
6		JDM-III	Ramreddy nagar	11KV	Kukatpally	00.40	03.50	03.10	BD	11kv papsagar Ramreddy nagar feeder jumper phase to phase at kantha rubber company phase-V	No
7		Subash Nagar	Ramraj Nagar	11KV	Medchal	00.35	01.15	00.40	BD	11KV Pin Insulator failed at Spring Filled Colony	No
8		Kothaguda	Shilpa Park	11KV	Gachibowli	00.45	04.13	03.28	BD	11kv line pin-insulator failed near Shilpa Park(Due to heavy rain)	No
9		JNTU	Gokul Plots	11KV	Gachibowli	00.28	02.14	01.46	BD	Tree fallen on the 11kv line at Plot No.842, Gokul Plots(Due to heavy rain)	No
10		JNTU	S.P.Nagar	11KV	Gachibowli	01.15	03.45	02.30	BD	11kv line pin-insulator failed at S.P. Nagar Community Hall(Due to heavy rain)	No
11		Chanda Nagar	Madinaguda	11KV	Gachibowli	1:00	5:30	4:30	BD	11kv line pin-insulator failed at MyHome Apartment(Due to heavy rain)	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR E	Ramanthapur	Chruch colony	11KV	HBG	1:55	3:10	1:15		11kv line petroling done but no visiable fault found	No
2		Nacharam	Rajender nagar	11KV	HBG	00.10	01.16	01.06		11kv Pinsulator fail at Rajemder nagar	No
3		Auto Nagar	Kilamyisamma	11KV	SRNR	00.57	02.36	01.39		11KV insulator failed at NTR Nagar	No
1	HYD N	N.I.M.S	Tata Rao	11KV	Jublee Hills	02.10	03.50	01.40	EL	UG Cable fault at E-Seva	No
2		Road No.13	Road No.1	11KV	Jublee Hills	2:40	3:58	1:18	All Indication	No Visible Fault	No
3		Nehru Nagar	Water Works	11KV	Sec'bad	2:53	6:15	3:22	All Indication	HT Jumper cut at Water Works	No
4		Greenlands	Ameerpet	11KV	Erragadda	4:35	6:17	1:42	EL	No Visible Fault	Arranged B/F on 11KV Brahmanwadi feeder
5		H.P.S	Suryodaya Complex	11KV	Erragadda	7:40	8:50	1:10	EL,OL-Rph	No Visible Fault	No
6		Borabanda	Banjara Nagar	11KV	Erragadda	08.40	09.40	01.00	EL	Jumper Cut at Hanuman Temple	No
1	HYD S	Miralam	Tadbund	11KV	Charminar	00.05	01.35	01.30	EL,OL	No Visible Fault	No
2		Santosh Nagar	Jahangir Nagar	11KV	Asmangadh	00.10	02.30	02.20	Master Relay	Faulty loads of 11KV Jamal Colony feeder	No
3		Miralam	Hasan Nagar	11KV	Charminar	00.15	01.35	01.20	EL,OL	No Visible Fault	No
4		Osm.Hospital	Begum Bazar	11KV	Begumbazar	00.20	01.55	01.35	EL	No Visible Fault	Arranged B/F on 11KV Gosha Mahal feeder
5		Salarjung	Sadath Nagar	11KV	Asmangadh	00.50	02.24	01.34	EL	DTR fault at Unique School	No
6		Hyderguda	Janapriya OH	11KV	Charminar	01.00	02.35	01.35	EL	Tree branches fallen on lines at Janapriya High School	No
7		Attapur	Kishan Bagh OH	11KV	Charminar	01.20	02.20	01.00	EL	AB Switch fault at Harsha Mahal	No
8		Salarjung	Alija Kotla	11KV	Charminar	01.26	02.30	01.04	EL,OL-Bph	Faulty 3No's DTR's at Alija Kotla	No
9		Kanchanbagh	Jamal Colony	11KV	Asmangadh	4:15	6:29	2:14	EL,OL-Yph	Cable fault	Arranged B/F on 11KV Jahangir Nagar feeder
10		Womens College	Esamiya Bazar	11KV	Begumbazar	11:25	14:05	2:40	EL	No Visible Fault	Arranged B/F on 11KV Koti feeder
11		Falaknuma	Vattepally	11KV	Charminar	11:45	13:55	2:10	EL,OL-Bph	DTR fault at Nice Café	No
12		Miralam	N.S.Kunta	11KV	Charminar	12.05	14.30	02.25	EL	HT Lines twisted at Gudika Hospital & S.K.G Function Hall	No
1	HYD C	Vittalwadi	ICICI Bank	11KV	Saifabad	00.30	02.15	01.45	EL	No Visible Fault	No

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	1	85									
2	NLG	3	110									
3	MDK	6	81									
4	RR(S)	10	106		6		6		6			
5	RR(N)	45	274		11		11		11			
6	RR(E)	34	223		3		3		3			
7	Hyd	136	844		19		19		19			
	Total	235	1723	0	39	0	39	0	39	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	81	891		3		3		3			
2	NLG	109	738	1	12	1	12	1	12			
3	MDK	81	690		2		2		2			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	15	79									
	Total	325	2784	1	17	1	17	1	17	0	0	
	Grand Total	560	4507	1	56	1	56	1	56	0	0	