

## TSSPDCL - LMRC / Corporate office

Date: 31.08.2016

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Parsapur	Mahabubnagar	11kv	Mahabubnagar	6:00	10:30	4:30		11KV Jumper cut at Parsapur (V)	-
2		Hasnabad	Mahabubnagar	11kv	Mahabubnagar	6:15	13:10	6:55		11KV Conductor cut at Hasnabad forest (V)	-
3		Perapalla	Mahabubnagar	11kv	Mahabubnagar	5:20	13:00	7:40		11KV Insuletar failure at Perapalla (vi)	
4		Laxmipur	Jadcherla	11kv	Jadcherla	4:00	9:00	5:00		11KV Conductor cut at Appireddypally (vi)	
5		Bandamidipally	Jadcherla	11kv	Jadcherla	8:00	12:30	4:30		Tree follon the line near Kaverammamet	
6		Industrial	Jadcherla	11kv	Jadcherla	7:45	12:25	4:45		Insulator fail near Polepally	
7		Chukkapur	Jadcherla	11kv	Jadcherla	9:00	10:30	1:30		11kv wire cut near Cheepnunthala	
8		Kishan Nagar	Jadcherla	11kv	Jadcherla	4:40	9:15	4:35		Insulator fail near Chilukamarry	
9		NADIGADDA	Nagarkurnool	11kv	Nagarkurnool	2:30	12:00	9:30		2POLES CONDUCTOR CUT NADIGADDA AGL LAND	-
10		CHOUTAPALLY	Nagarkurnool	11kv	Nagarkurnool	3.00	15.20	12:20		INSULATOR FAILED NEAR MADURANAGAR COLNEY	-
11		RANGAPUR	Nagarkurnool	11kv	Nagarkurnool	3.00	12.00	9:00		POLESHETYPALLY ROAD T/F PRABULAM	-
12		CHANDRAKAL	Nagarkurnool	11kv	Nagarkurnool	3.00	12.00	9:00		11KV WIRE CUT AT NAKALA PALLY GATE	-
13		SATHAPUR	Nagarkurnool	11kv	Nagarkurnool	6.00	11.40	5:40		INSULATOR FAILED AT JONALBIGUDA (V)	-
1		Marriguda	Thamadapally	11kv	Devarakonda	03.00	07.00	04.00	E/L	11Kv Insulator Failed	-
2		Kattangur	Powerloom	11kv	Suryapet	07.20	09.30	02.10	E/L	Tree branch fallen on the line	-
3		G.T Giri	Gunjaloor	11kv	Suryapet	08.50	12.20	03.30	E/L	11Kv Insulator Failed	-
4		Reddygudem	Maddirala	11kv	Suryapet	06.30	10.00	03.30	E/L	11Kv Jumper cut	-
5		Dirincherla	Somaram	11kv	Huzurnagar	12.00	16.00	04.00	E/L	33 kv poles damaged at Mutyalamma kunta village	-
6		Huzurnagar	Singaram	11kv	Huzurnagar	02.00	06.00	04.00	E/L	11 kv line snapped at Singaram village	-

7	NLG	Kodad	Tammara	11kv	Huzurnagar	07.00	09.30	02.30	E/L	11 kv Inslater failed at Shantinagar village	-
8		Ananthagiri	Ananthagiri	11kv	Huzurnagar	03.00	07.00	04.00	E/L	11 kv Inslater failed at Near palavaram village	-
9		Ananthagiri	V R Puram	11kv	Huzurnagar	03.00	05.10	02.10	E/L	11 kv Inslater failed at V R Puram village	-
10		Munagala	Tadvai	11kv	Huzurnagar	03.30	07.30	04.00	E/L	11 kv Inslater failed at Tadvai village	-
11		Keethavarigudem	Rainigudem	11kv	Huzurnagar	06.00	07.00	01.00	E/L	11 kv Inslatr failed at Ranigudem village	-
12		Keethavarigudem	Velidanda	11kv	Huzurnagar	03.30	06.00	02.30	E/L	11 jumper cut at Veldanda village	-
13		IDA	Bommaipally	11kv	Bhongir	09.00	13.00	04.00	E/L	Tree Branches Fallen On Line at Bommaipally	-
14		B.p.pally	Revanpally	11kv	Bhongir	10.20	14.20	04.00	E/L	11KV Line snapped at Revanpally	-
15		Ch.laxmapur	Madapur	11kv	Bhongir	08.00	12.00	04.00	O/L	11KV Line snapped at Madapur	-
16		M.R.Gudem	Baswapur	11kv	Bhongir	08.00	12.00	04.00	E/L	Post of Insulator failed baswapur	-
17		Solipet	Venkateshwara Indus	11kv	Bhongir	05.30	09.00	03.30	E/L	11KV Insulator failed	-
18		Bibinagar	Sakethindia	11kv	Bhongir	13.00	15.00	02.00	E/L	11KV Line snapped at Andra Ispath	-
19		Rayaniguda	G.Kondaram	11kv	Nalgonda	05.00	09.00	04.00	E/L	11KV Line Jumper Cut	-
20		Thimmanaguda	Ch.Chennaram	11kv	Nalgonda	04.00	08.00	04.00	E/L	11Kv Insulator Failed	-
21		Narketpally	Yellareddygudem	11kv	Nalgonda	06.00	10.00	04.00	E/L	11Kv Insulator Failed	-
22		Urumadla	Urumadla	11kv	Nalgonda	04.00	08.00	04.00	E/L	11KV Insulator Failure	-
23		Ramannapeta	K.M.Gudem	11kv	Nalgonda	11.00	12.30	01.30	E/L	11KV Insulator Failure	-
24		Ramannapeta	Bogaram	11kv	Nalgonda	08.00	12.00	04.00	E/L	11KV Line Jumper Cut	-
1		Pamulaparthu	Pathur	11kv		07.10	13.55	06.45		B/D due to Pin Insulator failed	-
2		Nacharam	Nacharam AGL	11kv		08.00	12.40	04.40		B/D due to Jumper Cut	-
3		Masaipet	Masaipet Indl	11kv		09.00	11.00	02.00		B/D due to Tree branch fallen on line	-

4	Kodakandla	Rayavaram	11kv
5	Bejgam	L.R.Pally	11kv
6	Gajwel Pregnapur	Town-I	11kv
7	Shivampet	Shivampet Indl	11kv
8	Kallakal	KP STEEL	11kv
9		Mycho	11kv
10	Konapur	Raylapur	11kv
11		Konapur	11kv
12	Chandaipet	Chandaipet	11kv
13	Govindapur	Govindapur	11kv
14	Naskal	Nandagokul	11kv
15	Wantimamidi	Cheelasagar	11kv
16	Markook	Sneha Indl	11kv
17	Kothapet	Kothapet	11kv
18	Danthanpally	Koppulapally	11kv
19	Toopran	Proagro	11kv
20	Manoharabad	ITL	11kv
21	Sangareddy Town-I	Nalsabgadda	11kv
22	Sangareddy Town-II	Kalabgoor	11kv
23		IK Pet	11kv
24	I K Pet	Goudicheria	11kv

Toopran

04.10	09.10	05.00		B/D due to Tree branch fallen on line	-
05.30	07.15	01.45		B/D due to Jumper Cut	-
08.50	10.25	01.35		B/D due to Insulator Failed	-
09.00	12.00	03.00		B/D due to Tree branch fallen on line	-
08.40	15.00	06.20		B/D due to Tree branch fallen on line	-
10.30	13.30	03.00		B/D due to 2Nos poles bend near Gloster cable company	-
07.00	11.50	04.50		B/D due to Tree branch fallen on line	-
09.00	11.20	02.20		B/D due to Insulator Failed	-
09.50	13.00	03.10		B/D due to Pole Damaged	-
08.00	14.15	06.15		B/D due to Pole Damaged	-
06.30	14.05	07.35		B/D due to heavy Tree fallen on line	-
08.30	17.55	09.25		B/D due to conductor cut	-
00.00	10.30	10.30		B/D due to CT PT failed & 2no's Disc Insulator failed	-
06.00	11.30	05.30		B/D due to Disk failed	-
10.00	19.00	09.00		B/D due to Pin Insulator Failed	-
08.00	10.00	02.00		B/D due to Conductor snapped at Venkatapur Vg	-
13.00	15.30	02.30		B/D due to Pole bend near Petrol pump	-
10.45	11.45	01.00		B/D due to bird fallen on line at Kalwakunta Water tank	-
07.05	16.45	09.40		B/D due to heavy Tree fallen on line	-
11.35	15.45	04.10		B/D due to heavy rain & Gale	-
06.20	11.00	04.40		B/D due to insulator burst at Hanuman Gadda	-

25	MDK		Arutla	11kv		06.22	13.45	07.23		B/D due to conductor snapped at Arutla road	-
26		Malkapur	Mallepally	11kv		06.30	14.35	08.05		B/D due to Insulator burst at Kistaigudem	-
27		Cheryal	Kandi	11kv		06.00	09.00	03.00		B/D due to HT/LT Touched at Kaulampet	-
28		Nandigama	AV Alloys	11kv		06.50	17.40	10.50		B/D due to heavy Tree fallen on line	-
29		Isnapur	Muthangi Agl	11kv		07.05	12.00	04.55		B/D due to Pin Insulator failed at Bachugudem	-
30			Kyasaram	11kv	Sangareddy	13.15	17.00	03.45		B/D due to Pole Damaged	-
31		Aroor	Maddikunta	11kv		07.30	16.00	08.30		B/D due to heavy rain & Gale	-
32		Kistareddypet	Indl.	11kv		04.30	13.00	08.30		B/D due to CT PT failed at AGK Company	-
33		Bollaram-I	Pavan	11kv		09.00	10.05	01.05		B/D due to heavy rain & Gale	-
34		PATI	Pati	11kv		14.03	17.00	02.57		B/D due to Pin Insulator failed	-
35		SOL	IDA-II	11kv		12.49	13.39	00.50		B/D due to Jumper cut at Suven Life Company	-
36			IDA-II	11kv		13.35	15.30	01.55		B/D due to Jumper cut at near SS	-
37		Patancheru	Shanthi Nagar	11kv		11.30	14.25	02.55		B/D due to tree fallen on line at Indian Home Pipe	-
38			Kanjarla	11kv		15.25	16.10	00.45		B/D due to Conductor cut	-
39		Pillikotyal	Nawabpet	11kv		09.00	17.00	08.00		B/D due to tree branches fallen on line	-
40		Thogita	H.Ganapur	11kv		11.00	12.50	01.50		B/D due to tree branches fallen on line	-
41		Sardhana	Sardhana	11kv		09.25	16.25	07.00		B/D due to 11KV disc failed Sardhana vg	-
42		NSF	Mjombopally	11kv		09.20	14.55	05.35		B/D due to tree branches fallen on line	-
43			Macharam	11kv		09.20	13.20	04.00		B/D due to tree branches fallen on line	-
44		Gavvalapally	Shanrampet R	11kv	Medak	09.30	17.40	08.10		B/D due to 11KV line cut Ch.Shankarampet vg	-
45		Hathnoora	Nawabpet	11kv		11.00	13.00	02.00		B/D due to 11KV Jumper cut Nawabpet vg	-

46	Jinnaram	Jinnaram	11kv		14.00	14.50	00.50		B/D due to Jumper cut	-	
47	Jinnaram	Ootla	11kv		07.45	14.00	06.15		B/D due to tree branches fallen on line	-	
48	Jinnaram	Kodakanchi	11kv		11.30	14.30	03.00		B/D due to pole broken Nalthoor vg	-	
49	Nallavally	Nallavally Indl	11kv		06.50	16.55	10.05		B/D due to heavy Tree fallen on line	-	
1	RR S	ALmasguda	Rajive gruha kalpa	11kv	CPT	08.55	12.15	03.20	EL/BD	11KV Insulators failed at Gandhi nagar	-
2		ALmasguda	Tirmala nagar	11kv	CPT	08.43	11.00	02.17	EL/OL BD	11KV Disk failed besides substation	-
3		Turkayamjal	Kammaguda	11kv	CPT	09.20	11.40	02.20	EL /OL BD	T/F Disk failed and bus bar failed at Muscut dairy form	-
4		Rapol	shadnagar	11kv	vkb	03.30	17.00	13.30	EL /OL BD	11kv line cut at padmaram (Vi)	-
5		Madanpally	Madanpally	11kv	vkb	05.30	11.30	06.00	EL /OL BD	Due to Heavy Rain	-
6		Peddemul	Janagam	11kv	vkb	06.00	13.30	07.30	EL /OL BD	11KV Insulators failed at peddemul	-
7		kawkutla	thagadipally	11kv	vkb	12.30	14.30	02.00	EL /OL BD	11kv disk failed at thagadipally (Vi)	-
8		Ibrahimbagh	Osmansagar	11kv	RJNR	08.26	11.00	02.34	B/D	Tree branches fallen on 11KV at Military gate-1	-
9		MD Pally	Pallecheruvu	11kv	RJNR	08.35	12.10	03.35	B/D	11KV disk failed at palechervu and insulator failed at krishnareddy nagar	-
10		Ganganpahad	Gaganpahad	11kv	RJNR	09.46	12.30	02.44	B/D	2Nos 11KV poles damaged Jalpally and Opp Gaganpahad SS	-
11		Ganganpahad	IDA Sathamrai	11kv	RJNR	10.12	13.02	02.50	B/D	11KV Line snapped at Sunder Synthetic	-
12		Gaganpahad	Jaibhavani	11kv	RJNR	11.40	14.07	02.27	B/D	11KV Jumpers cut at DR Metal	-
13		Puppalaguda	Puppalaguda	11kv	RJNR	09.35	10.20	00.45	B/D	T/F Bras patti cut touching to channel Near Tennis Court	-
1		Jeedimetla SS IV	Auto stand	11kv	Kukatpally	10.30	12.55	02.25	BD	11kv LT line cut at Subhashnagar	-
2		Mayurinagar	Ramnareshnagar	11kv	Kukatpally	09.40	11.50	02.10	BD	Tree branches & cloth fall on the 11kv line near girls Hostel at Mayurinagar	-
3		Aleap	RGK	11kv	Kukatpally	09.35	11.12	01.37	BD	11kv line cut & disk failure VNR Hostel back saide at Pragathinagar	-
4		Dp pally SS II	Cable MLR	11kv	Kukatpally	11.30	13.10	01.40	BD	Tree branches fall on the 11kv line at Madchel Mainroad	-

5		Jeedimetla SS I	Subhashnagar	11kv	Kukatpally	10.20	12.50	02.30	BD	Tree branches fall on the 11kv line near Auto stand at Subhashnagar	-
6		Jeedimetla SS I	NITCO	11kv	Kukatpally	10.30	12.10	01.40	BD	Tree branches fall on the 11kv line near Dada capacitor Industry at Phase I	-
7		Mathrusri Nagar	Vishwambere	11kv	Gachibowli	06.35	08.35	02.00	BD	11kv line pin-insulator failed at Gupta Residency	-
8		Nanakramguda	Manjeera Diamond	11kv	Gachibowli	06.45	08.45	02.00	BD	11kv line pin-insulator failed at Gopanpally Thanda	-
9		L & T infosity	PJR Nagar	11kv	Gachibowli	09.25	11.20	01.55	BD	11kv line pin-insulator failed at RTTC , Telecom Nagar	-
10		KPHB	JNTU	11kv	Gachibowli	09.55	11.28	01.33	BD	11kv line pin-insulator failed at Maharasta Bank, Bus stop	-
11	RR N	Gachibowli	Kothaguda	11kv	Gachibowli	07.44	09.40	01.56	BD	Trisula T/F HT service HG fuse cut at Maseed banda	-
12		Gachibowli	Kala Jyothi	11kv	Gachibowli	07.44	09.44	02.00	BD	11kv line twisting at Gachibowli S.S opposite	-
13		Gachibowli	Aparna	11kv	Gachibowli	10.30	12.25	01.55	BD	11kv line pin-insulator failed at Sahiti School, Nallagandla	-
14		ESCI	Prashanti Hills	11kv	Gachibowli	09.13	11.08	01.55	BD	100kva T/F pin-insulator failed at MGR Dhaba	-
15		Kodapur	Hafeezpet	11kv	Gachibowli	06.40	08.40	02.00	BD	11kv line pin-insulator failed at Vasantha Vally , Hafeezpet	-
16		Kodapur	Raghavendra colony	11kv	Gachibowli	07.40	09.25	01.45	BD	11kv line pin-insulator failed at Ananda Nagar, Kondapur	-
17		Medchal	Rural Kandlakoya	11kv	Medchal	09.01	11.05	02.04	BD	Tree fallen on the 11KV Line near Celkon Company	-
18		Subash Nagar	Jairam Nagar	11kv	Medchal	08.45	11.30	02.45	BD	11KV Disk failed at Indian Petrol Bunk, Main Road	-
19		Kandlakoya	Saigeetha Ashramam	11kv	Medchal	12.15	16.50	04.35	BD	2No 11KV Pin Insulator Failed at Highway Road,KV Reddy Nagar	-
20		Nuthankal	Oyster	11kv	Medchal	11.45	14.20	02.35	BD	11KV Line Cut & Replacement at Oyster Company	-
21		Hafeezpet	Janapriya Nagar	11kv	Gachibowli	08.45	10.40	01.55	BD	T/F HG fuse and brosspatti cut at Industrial Area	-
22		Suraram	Venkatram nagar	11kv	Kukatpally	09.32	10.42	01.10	BD	Tree branches fall on the 11kv line near Saibaba Temple at Suraram X Road	-
1		Cherelapally-II	Jannuram	11kv	Sainikpuri	08.44	10.08	01.24		Inter pole line touched to 11Kv line at jannuram (AE)	-
2		Cherelapally-II	Micro Media	11kv		09.11	11.04	01.53		11Kv pole Bended at College Hostel near Phase-II (AE)	-
3		Kushaiguda	Kushaiguda	11kv		08.45	11.05	02.20		11Kv Disk failed at Kushaiguda Industry (L.Insp Anil)	-

4	RR E	Kushaiguda	Kapara	11kv		09.30	11.00	01.30		11Kv line cut at ganesh temle (AE SKP)	-	
5		RGK	Nissa	11kv		09.40	11.05	01.25		Tree cutting on 11Kv line and Insulator changed at Campus (L.Insp Koteshwar Rao)	-	
6		Polytechnic SS	Madhura Nagar	11kv	Habsiguda	09.47	12.32	02.45		Line patrolling but no visible fault	-	
7		Mallapur	Sai Nagar	11kv		08.25	10.05	01.40		DP Pole touched LT line due to heavy rain at Sai Nagar Colony	-	
8		Nacharam	Guru Raghavendra	11kv		10.48	14.00	03.12		Tree fallen on 11KV Line near Indore Sub Station Backside	-	
9		NGRI	HMT Nagar	11kv		10.07	13.20	03.13		Pole broken & tree fallen at St.No.05 HMT Nagar	-	
10		Uppal	Gangappa	11kv		09.30	12.50	03.20		Tree fallen on 11kv line at IDA Uppal	-	
11		Uppal	Bank Colony	11kv		08.00	11.10	03.10		11KV Pin Insulator failed at Prasanth Nagar	-	
12		Uppal	Chilaka Nagar	11kv		08.10	10.45	02.35		11KV Pin Insulator failed at Adarsha Nagar	-	
13		Auto Nagar	Highcourt Colony	11kv		Saroornagar	10.15	12.45	02.30		11KV Disk failed at Hudasai Nagar Road no -8	-
14		Hayat Nagar	Hayat Nagar	11kv	09.40		11.45	02.05		Line patrolling but no visible fault	-	
1			Vittalwadi	I.C.I.C.I.	11kv	I	07.35	09.53	02.18	EL	No Visible Fault	due to rain
2			Indira Park	Domalguda	11kv	I	08.50	13.10	04.20	EL	Tree branches fallen on Lines & Jumper cut at Street No.4, Domalguda	-----
3			Indira Park	Gulshan Nagar	11kv	I	08.57	10.40	01.43	EL	Jumper cut at Sairam DTR & tree branches fallen on Lines at Gulshan Cly	-----
4	Exhibition		J.N.	11kv	I	08.58	12.57	03.59	OL-Rph	Insulator flash over at Nandana Appt	-----	
5	Lumbini Park		A.P.Tourism	11kv	I	09.39	09.49	00.10	EL,OL	No Visible Fault	due to rain	
6	Z.P Office		Padmavathi Nagar	11kv	I	10.10	17.03	06.53	EL	Cable fault at Anand Nagar & Disc flash over at Padmavathi Nagar	Arranged B/F on 11KV Z.P.Office fdr	
7	Hussain Sagar		Meera Theater	11kv	I	10.15	11.55	01.40	EL,OL-Rph	No Visible Fault	due to rain	
8	Vittalwadi		I.C.I.C.I.	11kv	I	10.20	12.27	02.07	EL	No Visible Fault	due to rain	
9	Indira Park		Kuchipudi	11kv	I	10.25	11.35	01.10	EL	HG fuse Insulator flash over at Santosh Tent House	-----	
10	Indira Park		Talla Basthi	11kv	I	10.30	12.50	02.20	EL,OL-Rph	Tree branches fallen on Lines at Talla Basthi	-----	

11	HYD C	Nizam College	Galaxy	11kv	I	11.52	14.22	02.30	EL,OL-Rph	Tree branches fallen on lines	----
12		Nizam College	Babu Khan Estate	11kv	I	12.48	14.20	01.32	EL	HT Jumper cut at L.B.Stadium	----
13		Z.P Office	Ramleela Maidan	11kv	I	16.38	17.38	01.00	EL	faulty loads of 11KV Anand Nagar fdr	----
14		Industrial Area	Adikmett	11kv	II	07.45	10.20	02.35	EL	No Visible Fault	due to rain
15		Fever Hospital	Fever Hospital	11kv	II	08.40	10.10	01.30	EL,OL	No Visible Fault	due to rain
16		Amberpet	Tilak Nagar	11kv	II	08.50	11.45	02.55	EL	Tree branches fallen on Lines at Tilak Nagar	----
17		Zamisthanpur	Balaji Nagar	11kv	II	10.55	12.05	01.10	OL-R&Bph	Tree branches fallen on Lines at P.R.K. Mension	----
18		Zamisthanpur	L.N.Nagar	11kv	II	19.38	20.55	01.17	EL,OL-Rph	Disc flash over at Hanuman Temple	----
19		Golconda	Golconda OH	11kv	VII	07.20	09.00	01.40	All Indication	Cable fault at Golconda	----
20		Nampally	Red Hills	11kv	VII	08.05	10.41	02.36	EL,OL-Bph	No Visible Fault	due to rain
21		Nampally	FAPCCI	11kv	VII	08.08	10.14	02.06	EL,OL-Bph	No Visible Fault	due to rain
1	HYD N	E.S.I	Municipal Park	11kv	IV	09.10	10.05	00.55	EL,OL	No Visible Fault	due to rain
2		I.D.P.L	Bharath Nagar	11kv	IV	09.50	14.00	04.10	EL,OL-Rph	Breaker fault	Loads transferred onto 33KV Janapriya SS
3		Begumpet	Shanthi Bagh	11kv	IV	10.15	13.00	02.45	EL,OL	Tree branches fallen on Lines at D.K.Road	----
4		Osm. University	Osm. University	11kv	V	07.35	09.35	02.00	EL	No Visible Fault	due to rain
5		Gymkhana	Balaji Enclave	11kv	V	09.10	10.30	01.20	OL-Bph	Bird fault on Lines at Gunrock Enclave	----
6		Lalaguda	Lalapet	11kv	V	09.40	11.50	02.10	EL	faulty DTR at Satya Nagar	----
7		Marredpally	Water Works	11kv	V	12.05	17.20	05.15	All Indication	Cable End Kit at Water Works	----
8		Bowenpally	Ferozguda	11kv	VI	08.35	09.45	01.10	EL	No Visible Fault	due to rain
9		Bowenpally	Akshaya Enclave	11kv	VI	08.55	10.10	01.15	EL	No Visible Fault	due to rain
10		I.D.P.L	SVCIE	11kv	VI	08.40	13.45	05.05	EL	Tree branches fallen on lines	Arranged B/F on 11KV Wonder Plast fdr



11		I.D.P.L	Oblum	11kv	VI	09.50	11.20	01.30	EL,OL-Bph	No Visible Fault	due to rain
12		I.D.P.L	SIFCO	11kv	VI	09.55	14.25	04.30	EL,OL-Bph	CT,PT fault at Kumar Rubber Factory	-----
13		Gunrock	Medchal	11kv	VI	10.15	11.25	01.10	EL	No Visible Fault	due to rain
14		N.I.M.S	City Central	11kv	X	08.27	15.00	06.33	EL,OL	Cable fault at SS	Arranged B/F on Banjara Hills fdr
15		Srinagar Colony	Kamalapuri Colony	11kv	X	08.35	12.30	03.55	EL	AB Cable fault at Kamalapuri Cly & Disc Insulator flash over at Indira Nagar	-----
16		Raviendra Society	C.O.D	11kv	X	10.05	11.40	01.35	OL-Rph	No Visible Fault	due to rain
17		Road No. 22	Jubilee Hills PS	11kv	X	12.12	15.30	03.18	EL	Cable fault	Arranged B/F on 11KV UCO Bank feeder
1	HYD S	Kanchan Bagh	Riyasath Nagar	11kv	III	08.50	12.30	03.40	EL	Cable fault Omar Hotel	Arranged B/F on 11KV fdr
2		Salarjung	Pathergatti	11kv	III	09.35	11.00	01.25	EL,OL	RMU fault at SYK Complex	-----
3		Gunj	Gunj	11kv	VIII	09.35	12.25	02.50	All Indication	faulty 11KV Super Bazar feeder loads	-----
4		Moosarambagh	Shalivahana Nagar	11kv	VIII	09.45	11.10	01.25	OL-Rph	Tree branches fallen on Lines at Navatha Apts	-----
5		Laxmi Nagar	Shankeswar Bazar	11kv	VIII	12.01	14.25	02.24	OL-Rph	Net Cable fallen on lines at Saraswathi Nagar	-----
6		Moosarambagh	Shalivahana Nagar	11kv	VIII	13.10	16.10	03.00	All Indication	Cable fault at Dilshuk Nagar	-----
7		Santosh Nagar	Jahangir Nagar	11kv	VIII	23.30	01.10	01.40	All Indication	No Visible Fault	4no DTR off
8		Seetharambagh	Dattatreya Nagar UG Cable	11kv	IX	02.10	03.15	01.05	All Indication	Cable fault	Arranged B/F on 11KV Seetharambagh feeder
9		E.N.T.	C.B.I.	11kv	IX	09.28	11.48	02.20	All Indication	No Visible Fault	due to rain
10		Kulsumpura	Mahalaxmi Nagar	11kv	IX	10.08	11.15	01.07	EL,OL	No Visible Fault	Arranged B/F on 11KV Dhoolpet UG Cable feeder
11		Gosha Mahal	Gyanbagh Colony	11kv	IX	11.00	12.20	01.20	EL,OL-Y&Bph	AB Cable End Kit failed at Godeki Khaber	-----

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Gajwel	Jagdevpur	33kv	Toopran	12.30	13.50	01.20		B/D due to Disc Failed	Jagdevpur	-
2		Narayanakhed	Poosalpad	33kv	Jogipet	10.00	15.45	05.45		B/D due to Insulator Failed	Poosalpad	-
3		Kowdipally	Venkatraopet	33kv	Medak	07.05	11.35	04.30		B/D due to Tree fallen on the line	Venkatraopet	-
4		Habsipur	Khajipur	33kv	Siddipet	07.25	11.35	04.10		B/D due to Jumper cut at Rudraram SS	Khajipur	-
5		Kandhi	BDL	33kv	Sangareddy	08.20	15.40	07.20		B/D due to Conductor snapped	BDL	-
1	RR S	Pargi	Rapol	33kv	vkb	06.15	14.15	08.00	BD	33KV POLE Broken at sulthanpur (Vi) heavy due to rain	Rapol	-
2		Tandur	Bommarajpet	33kv	vkb	05.45	12.35	06.50	BD	three fallen 33kv line at kokat villege and Bommarajpet Braker prablam at 132kv Tandur SS	Bommarajpet	-
1	HYD C	220KV Shivarampally	Karwan	33kv	Mehdipatnam	10.20	10.40	00.20	OL	33KV O/G flexible jumper cut and faulty End Kit on 33KV Karwan fdr at 220KV Shivarampally SS	Karwan	Loads transferred onto 132KV Asif Nagar SS

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	1	85									
2	NLG	3	110									
3	MDK	6	81									
4	RR(S)	10	106		9		9		9			
5	RR(N)	45	274		22		22		22			
6	RR(E)	34	223		14		14		14			
7	Hyd	136	844	1	49	1	49	1	49			
	<b>Total</b>	<b>235</b>	<b>1723</b>	<b>1</b>	<b>94</b>	<b>1</b>	<b>94</b>	<b>1</b>	<b>94</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	81	891		13		13		13			
2	NLG	109	738		24		24		24			
3	MDK	81	690	5	49	5	49	5	49			
4	RR(S)	31	338	2	4	2	4	2	4			
5	RR(N)	8	48									
6	RR(E)	15	79									
	<b>Total</b>	<b>325</b>	<b>2784</b>	<b>7</b>	<b>90</b>	<b>7</b>	<b>90</b>	<b>7</b>	<b>90</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>560</b>	<b>4507</b>	<b>8</b>	<b>184</b>	<b>8</b>	<b>184</b>	<b>8</b>	<b>184</b>	<b>0</b>	<b>0</b>	