

TSSPDCL - LMRC / Corporate office

Date: 05.08.2016

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Kankurthy	33KV	Mahabubnagar	13.15	16.05	02.50	E/L	Insulator Failed Near Mogalmdka SS	Kankurthy,Mogalmdka	No

TSSPDCL - LMRC / Corporate office

Date: 05.08.2016

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	ACHMPET	TOWN 2	11KV	Nagarkurnool	15.30	15.50	00.20		COLLAGE BOARD TOUCH TO 11 KV LINE	-
2		KOLLPUR	KUDIKILLA	11KV	Nagarkurnool	16.45	17.10	00.25		11 KV LINE WIRE CUT IN VILLAGE	-
3		MANTHATI	TADOR	11KV	Nagarkurnool	12.30	14.00	01.30		PULZALA VILLAGE 11 KV WIRE CUT	-
1	NLG	Jammigadda	B.B Gudem	11KV	Suryapet	07.40	08.50	01.10	EL	Bird fallen on the line at G.V.V function hall	-
2		Mukundapuram	Kalluru	11KV	Huzurnagar	12.10	16.10	04.00	EL	11 kv line snapped at Fattepuram village	-
3		Ananthagiri	Chanupally	11KV	Huzurnagar	13.10	14.50	01.40	EL	11 kv conductor snapped at chanupally vilage	-
4		Thogarrai	Kuchipudi	11KV	Huzurnagar	12.20	15.00	02.40	EL	Transfomer failed at Kuchipudi village	-
5		Nampally	Peddapuram	11KV	Devarakonda	09.30	12.30	03.00	E/L	Insulator Failure	-
6		Shivannagudam	R.R.Pally	11KV	Devarakonda	04.00	07.30	03.30	E/L	Tree Fallen the Line	-
7		Nandanam	Tukkapur	11KV	Bhongir	11.20	13.40	02.20	EL	Tree Branchess Fallen On Line	-
8		Chandupatla	Chanduptla Indus	11KV	Bhongir	10.30	14.30	04.00	EL	HT/LT	-
1	MDK	Isnapur	Kollur	11KV	Sangareddy	15.15	17.00	01.45		B/D Due to tree fallen on the line at Kollur	-
1	RR S	Jalpally	Jalpally	11KV	CPT	18.10	19.20	01.10	OL/EL	11KV Jumper cut at Grampanchayat DTR Jalpally	-
1	RR N	Nuthankal	Bharathi	11KV	Medchal	08.00	09.30	01.30		Bird fallen on the 11KV Line at Nuthankal Village	-
2		J D M SS-I	A P I I C	11KV	Kukatpally	01.15	02.15	01.00		11kv jumper Cut touched on channel at RS brother AplIc colony	-
3		KPHB	Bhagy nagar	11KV	Kukatpally	12.55	14.05	01.10		11kv Pin Insultor failure at Koteswar Enclave Usha mulapudi Road	-
4		Nanakramguda	TNGO'S	11KV	Gachibowli	15.08	16.39	01.31	EL & OL	11KV Pin Insulator Failure Near TNGO'S Colony Road Opposite SS	-
1	HYD N	Zamistanpur	S.P.College	11KV	Sec-Bad	09.46	10.48	01.02	EL,OL-Yph	Tree branches fallen on lines at P.R.Nagar	-
2		Thirumalgiri	Chinna Kamela	11KV	Bowenpally	09.48	10.50	01.02	EL,OL-Yph	No Visible Fault	Arranged B/F on 11KV Maruthi Nagar feeder
1	HYD S	Attapur	N.M.Guda OH	11KV	Charminar	09.20	11.05	01.45	EL,OL-Bph	R.M.U fault at Iqbal DTR	-
2		Kandikal Gate	Phool Bagh	11KV	Charminar	10.45	12.15	01.30	EL,OL-Rph	UG Cable fault at OYC School	-
3		Kandikal Gate	Indira Nagar	11KV	Charminar	11.40	13.00	01.20	EL,OL-Rph	Cut Jumper touching to Pole at Indira Nagar	-
1	HYD C	Public Garden	Nampally Railway Station	11KV	Saifabad	17.25	18.40	01.15	EL	Banner fallen on DTR at Public Garden Gate PT	-

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	1	85									
2	NLG	3	110									
3	MDK	6	81									
4	RR(S)	10	102		1		1		1			
5	RR(N)	45	271		4		4		4			
6	RR(E)	33	203									
7	Hyd	135	837		6		6		6			
	Total	233	1689	0	11	0	11	0	11	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	78	891	1	3	1	3	1	3			
2	NLG	109	738		8		8		8			
3	MDK	79	690		1		1		1			
4	RR(S)	31	341									
5	RR(N)	8	48									
6	RR(E)	15	78									
	Total	320	2786	1	12	1	12	1	12	0	0	
	Grand Total	553	4475	1	23	1	23	1	23	0	0	