

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	1	85									
2	NLG	3	110									
3	MDK	6	81									
4	RR(S)	10	102		1		1		1			
5	RR(N)	45	271		1		1		1			
6	RR(E)	33	203		1		1		1			
7	Hyd	135	837		1		1		1			
	Total	233	1689	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	78	891	1	2	1	2	1	2			
2	NLG	109	738		6		6		6			
3	MDK	79	690	1	3	1	3	1	3			
4	RR(S)	31	341									
5	RR(N)	8	48									
6	RR(E)	15	78									
	Total	320	2786	2	11	2	11	2	11	0	0	
	Grand Total	553	4475	2	15	2	15	2	15	0	0	

TSSPDCL - LMRC / Corporate office

Date: 09.08.2016

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	Chinchode	33KV	Jadcherla	07.50	09.30	01.40	E/L	Jumpers Opened near Chinchode(V)	Chinchode	-
1	MDK	Medak	Kowdipally	33KV	Amsanpally	10.15	13.40	03.25		B/D due to Jumper Phase to Phase	Kowdipally	-

TSSPDCL - LMRC / Corporate office

Date: 09.08.2016

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Annasagar	Tatikonda	11KV	Jadcherla	15.15	17.00	01.45		11 KV Jumper Cut Near Thatikonda(V)Out Side	-
2		Thimmajipet	Marikal	11KV	Jadcherla	04.50	09.20	04.30		11 KV Jumper Cut Near PutnalaThanda Side	-
1	NLG	B Chandupatla	Thimmapuram	11KV	Suryapet	09.00	10.00	01.00	EL	Jumper cut	-
2		Dirincherla	Chellepally	11KV	Huzurnagar	10.00	11.00	01.00	EL	11kv Transfomer failed at Chellepally village	-
3		Palakedu	Sajjapuram	11KV	Huzurnagar	11.00	12.00	01.00	EL	11 kv conductot snapped at Ngireddy gudem village	-
4		Keethavari gudem	Kothagudem	11KV	Huzurnagar	04.00	07.50	03.50	EL	11 kv line snapped at tallamalkapuram village	-
5		Mushampally	Erugantipally	11KV	Nalgonda	11.10	16.00	04.50	E/L	11KV Disc failed at Erugantipally(V)	-
6		Shivannagudam	S.R.Gudam	11KV	Devarakonda	07.00	10.00	03.00	E/L	Insuletor Failed	-
1	MDK	Chatlapally	Anthaiguda	11KV	Toopran	10.00	12.00	02.00		B/D due to Conductor snapped	-
2		Thogita	Thogita	11KV	Medak	13.30	14.00	00.30		B/D due to Conductor snapped	-
3		Gavvalapally	Madur	11KV	Medak	06.50	09.50	03.00		B/D due to Insulater failed	-
1	RR S	Kattedan-II	Ravi foods	11KV	RJNR	14.38	15.30	00.52		CTPT Fault at Durga Oil mill Rectified	-
1	RR N	Shameerpet	Thumkunta	11KV	Medchal	10.45	13.15	02.30	BD	11KV Pin Insulator Failed at Near Ring Road Shameerpet	-
1	RR E	IDA Uppal	L.N Nagar	11KV	Habsiguda	05.20	06.30	01.10		Line patrolling but no visible fault	-
1	HYD S	Asmangadh	Asmangadh	11KV	VIII	04.30	05.50	01.20	EL,OL-Bph	Tree branches fallen on Lines at S.K.Apts, Madhav Nagar	-