

TSSPDCL - LMRC / Corporate office

Date: 06.12.2016

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Singoor	Muddaipet	33KV	Jogipet	14.15	16.45	02.30		B/D due to Conductor Snapped near Kodur(V)	Singoor	-
1	RR N	Medchal	B.Madaram	33KV	Medchal	17.10	19.10	02.00	EL/OL	Tripped on EL & OL Indication , 33KV Cable failed andBD declare AE\OP\Rural Medchal Backfeeding arranged from 33KV GP Pally-I	Medchal	yes

TSSPDCL - LMRC / Corporate office

Date: 06.12.2016

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Eklaspur	Eklaspur	11KV	Mahabubnagar	16.20	17.20	01.00		11KV Conductor cut at Kanmanoor (V)	-
2		Hamsanpally	Hamsanpally	11KV	Mahabubnagar	09.00	11.40	02.40		11KV Conductor cut at Chowderpally (V)	-
1	NLG	Mushampally	Mushampally	11KV	Nalgonda	09.00	11.00	02.00	EL	11KV Line cut	-
2		Nemmani	Merlakunta	11KV	Nalgonda	08.30	11.00	02.30	EL	11Kv Line Jumper Cut	-
3		Kasarabad	Kesaram	11KV	Suryapet	05.30	09.00	03.30	EL	Line cut	-
4		Chinthapally	H.M.Pally	11KV	Devarakonda	11.00	14.00	03.00	EL	11kv jumper cutting	-
5		Chamapur	Singaram	11KV	Bhongir	13.00	16.30	03.30	EL	11KV Conductor Burnt near singaram	-
1	MDK	Kowdpally	Mohdnagar	11KV	Medak	08.00	12.00	04.00		B/D Due to Insulater failed	-
2		Bujrampet	Bujrampet	11KV	Medak	04.35	10.50	06.15		B/D Due to Insulater failed	-
1	RR N	IIIT	APHB Colony	11KV	Gachibowli	11.09	12.25	01.16	EL&OL	11KV Line Cut Near DLF 2nd Gate At APHB Colony.	-

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	52	153									
2	NLG	12	397									
3	MDK	83	350									
4	RR(S)	40	203									
5	RR(N)	75	396	1	1	1	1	1	1			
6	RR(E)	41	337									
7	Hyd	163	965									
	<b>Total</b>	<b>466</b>	<b>2801</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	81	891		2		2		2			
2	NLG	120	738		5		5		5			
3	MDK	81	695	1	2	1	2	1	2			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	15	79									
	<b>Total</b>	<b>336</b>	<b>2789</b>	<b>1</b>	<b>9</b>	<b>1</b>	<b>9</b>	<b>1</b>	<b>9</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>802</b>	<b>5590</b>	<b>2</b>	<b>10</b>	<b>2</b>	<b>10</b>	<b>2</b>	<b>10</b>	<b>0</b>	<b>0</b>	