

TSSPDCL - LMRC / Corporate office

Date: 21.12.16

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Ramannapeta	Veliminedu	33KV	Nalgonda	06.00	10.00	04.00		Jumper Cut	Veliminedu	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kothamolgara	Elikicherla	11KV	Jadcherla	07.00	10.10	03.10		11KV Insulator failed near Battupally (V)	No
1	NLG	Marrur	Mangalpally	11KV	Suryapet	8:30	11:00	2:30	EL	Jumper cut	No
2		Dirincherla	Dirincherla	11KV	Huzurnagar	07.00	11.00	04.00	EL	11 kv line snapped at Dirincherla village	No
3		Thogarrai	Gudibanda	11KV	Huzurnagar	08.40	13.00	04.20	EL	11 kv line snapped at Gudibanda village	No
4		Thogarrai	Kapugallu	11KV	Huzurnagar	09.10	10.10	01.00	EL	11 kv line snapped at Kapugallu village	No
5		Rayanagude	G.Kondaram	11KV	Nalgonda	03.00	06.00	03.00	EL	AB switch failed	No
6		Bhongir	Bhongir	11KV	Raigiri	9:45	12:30	2:45	EL	11KV Line snapped near Arorora college	No
1	RR S	IGS	Indra Shivashakthi	11KV	RJNR	14:11	15:38	1:27		No visible fault	No
1	RR N	Borabanda	Gayathri Nagar	11KV	Gachibowli	9:04	10:28	1:24	EL	11kv AB-Switch sparked and rectified at Vijaya Laxmi Super market, Gayathri Nagar	No
1	HYD N	Kalyan Nagar	Rehamath Nagar	11KV	Jublee Hills	14.30	15.43	01.13	EL,OL-Rph	Cable fault at Kallu Compound	No
1	HYD S	Malakpet	Komatiwadi	11KV	Asmangadh	19.40	20.50	01.10	OL-R&Bph	O/G AB Switch Jumper cut at SS	No
2		Santosh Nagar	SRT Colony	11KV	Asmangadh	13:12	15:00	1:48	EL,OL-R&Bph	Cable fault	No
1	HYD C	I.T.I Mallepally	Anjuman	11KV	Mehdipatnam	12.47	14.43	01.56	EL,OL	I/C Cable fault at Prabhaker Apts	No

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	52	153									
2	NLG	12	397									
3	MDK	83	350									
4	RR(S)	40	201		1		1		1			
5	RR(N)	75	398		1		1		1			
6	RR(E)	41	337									
7	Hyd	169	966		4		4		4			
	Total	472	2802	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	83	894		1		1		1			
2	NLG	142	738	1	6	1	6	1	6			
3	MDK	81	703									
4	RR(S)	31	338									
5	RR(N)	8	49									
6	RR(E)	15	79									
	Total	360	2801	1	7	1	7	1	7	0	0	
	Grand Total	832	5603	1	13	1	13	1	13	0	0	