

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	1	85									
2	NLG	3	110									
3	MDK	6	81									
4	RR(S)	10	102		1		1		1			
5	RR(N)	45	271	1	2	1	2	1	2			
6	RR(E)	33	203									
7	Hyd	135	837		5		5		5			
	Total	233	1689	1	8	1	8	1	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	78	891	1	4	1	4	1	4			
2	NLG	109	738		3		3		3			
3	MDK	79	690		2		2		2			
4	RR(S)	31	341									
5	RR(N)	8	48									
6	RR(E)	15	78									
	Total	320	2786	1	9	1	9	1	9	0	0	
	Grand Total	553	4475	2	17	2	17	2	17	0	0	

TSSPDCL - LMRC / Corporate office

Date: 21.07.2016

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthi	Narsaipally	33KV	Wanaparthi	03.10	08.05	04.55	E/L&O/L	Tree Branches fallen on the Line & 2No Insulator Failed & Replaced at Metpally	Narsaipally, Kethepally, Pangal,	-
1	RR N	Shapur Nagar	RCC Sales	33KV	Kukatpally	15.28	17.25	01.57	BD	Tree branches fall on the 33KV line near Suraram SS	RCC Sales	-

TSSPDCL - LMRC / Corporate office

Date: 21.07.2016

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	UPPUNUTHALA	DD KUNTA	11KV	Nagarkurnool	06.30	09.50	03.20		11kv DTR Problem at Doora Bavi	-
2		PKPALLY	CHANDRAKAL	11KV	Nagarkurnool	04.00	08.00	04.00		11KV Phase to Phase near Thirumalapur	-
3		AMRABAD	KUMARONIPALLY	11KV	Nagarkurnool	00.00	07.30	07.30		11KV Wire cut near Thirumalapur village	-
4		PEDAKARUPAMUL A	YAPTLA	11KV	Nagarkurnool	13.50	17.30	03.40		11KV Wire cut near village	-
1	NLG	Maryala	Chouderpally	11KV	Bhongir	10.30	14.00	03.30	EL	11KV Jumper snapped at Chouderpally	-
2		Kandagatla	Gattikal	11KV	Suryapet	12.50	14.10	01.20	E/L	Insulator failure	-
3		Mushampally	Mushapally	11KV	Nalgonda	05.00	08.00	03.00	E/L	11 KV Insulator Failed Under SS-8	-
1	MDK	Chitkul	Chitkul	11KV	Medak	11.00	12.00	01.00		B/D Due to Insulator failed	-
2		Dharpally	Achampet	11KV	Medak	06.00	10.00	04.00		B/D Due to Jumpercut near Achampet	-
1	RR S	Kismathpur	Difacecolony	11KV	RJNR	09.17	10.17	01.00		No Fault	-
1	RR N	Nanakramguda	Karvy	11KV	Gachibowli	05.57	07.10	01.13	BD	Karvy Feeder HT Service CT-BT Connecting UG Cable Damaged At Karvy	-
2		Mayurinagar	Cable	11KV	Kukatpally	05.00	05.40	00.40	BD	11kv line Insulator failure at Ramnareshnagar Cheruvukatta	-
1	HYD N	Begumpet	Shanthi Bagh	11KV	IV	03.00	06.40	03.40	EL	Pin Insulator flash over Akshaya Bank, D.K.Road	-----
2		Ayyappa Society	Image Garden	11KV	X	03.05	04.40	01.35	EL,OL-Bph	Tree branches fallen on lines at Narayana College	At 5.18 hs Arranged B/F on 11KV Hitech Theater feeder
1	HYD S	Asmangadh	Gowtham Nagar	11KV	VIII	12.20	14.49	02.29	OL-Rph	No Visible Fault	-----
1	HYD C	Jawahar Nagar	Post Office	11KV	I	22.10	23.30	01.20	EL,OL-Bph	No Visible Fault	-----
2		Jawahar Nagar	Ashok Nagar	11KV	I	22.30	00.10	01.40	EL	Pin Insulator fault at SBI, Ashok Nagar	Arranged B/F on 11KV R.K.Mutt fdr