

TSSPDCL - LMRC / Corporate office

Date: 14.06.16

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Narayankhed	Shankarampet	33	Jogipet	11:05	19:10	8:05		Conductor snppend near SS	Shankarampet	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Avancha	R.C.Thanda	11	Jadcherla	14.00	18.00	04.00		Phase to Phase near R.C.Thanda	No
2		Amangal	Vitaipally	11	Jadcherla	00.00	08.00	08.00		11kv wire cut near Konapur	No
3		Kodair	Janumpally	11	Nagarkurnool	21.00	Still			Not Rectified	No
1	NLG	Velmajala	Kommaipally	11	Bhongir	12:05	16:30	4:25	EL	AB Switch pin Insulator failed	No
2		Varkatpally	sangem	11	Bhongir	07.30	09.30	02.00	EL	DTR failed	No
3		Ananthagiri	VR Puram	11	Huzurnagar	02.05	06.45	04.40	EL	11 KV Jumper cut at Ameenabad (V)	No
4		Thogarrai	Thogarrai	11	Huzurnagar	11.00	15.00	04.00	EL	11 KV Jumper cut	No
5		Athmakur (S)	Athmakur (S)	11	Suryapet	13.30	17.20	03.50	EL/OL	Jumper cut	No
6		Narsingbatla	Koothurugudem	11	Nalgonda	13.00	15.20	02.20	E/L	11KV Jumper cut	No
7		Madgulapally	Kukkadam	11	Nalgonda	11.30	15.00	03.30	E/L	11KV Jumper cut	No
8		Rayanguda	G.Kondaram	11	Nalgonda	05.00	10.45	05.45	E/L & O/L	11KV line cut at Guttavarigudem	No
9		Thimmannagudem	Narsimhapuram	11	Nalgonda	11.00	13.20	02.20	E/L	Coper patty cut at SS-1 Narsimhapuram	No
10		D.Nagaram	Peepalpahad AGL	11	Nalgonda	03.00	07.00	04.00	E/L	11 KV line cut at Peepalpahad(V)	No
11		D.Nagaram	Indl. Feeder	11	Nalgonda	4:00	9:00	5:00	E/L & O/L	11KV line cut at Morsukunta	No
1	MDK	Jinnaram	Kodakanchi	11	Medak	8:45	13:00	4:15		11KV Line Cutting at Naltur vg.	No
2		Kulcharam	Appojipally	11	Medak	01.40	09.15	07.35		11KV Line Cutting at Appojipally Vg.	No
3		Pillikottal	Nawabpet	11	Medak	09.03	16.30	07.27		Tree branches fallen on the line	No
4		Rajpally	Venkatapur	11	Medak	16.20	18.20	02.00		11KV Jumper cut	No
1	RR S	Champapet	Padmanagar	11	CHPT	1:30	3:45	2:15	OL BD	11KV Line snapped at Anji reddy nagar	No
2		Vanasthalipuram	Prashanthi nagar	11	CHPT	19.15	20.15	01.00	EL BD	11KV Jumper cut at Durga matha Arch	No
3		Puppalguda	Narsing	11	RJNR	12.35	13.33	01.00	EL BD	Line touched at girls hostel	No
1	RR N	Aleap	Doctor's colony	11	KKP	8:10	9:40	1:30		11kv line A B Cable failure near plot no 1937 at Doctor's colony	No
1	HYD N	Prashasan Nagar	Ashwini Heights	11	Jublee Hills	12.10	13.15	01.05	EL,OL	Cable End Kit failed at Rd.No.72	No
1	HYD S	Yakuthpura	Murthuza Nagar	11	Asmangadh	12.30	17.50	05.20	EL,OL-Rph	Cable fault at Moula Ka Chilla	Arranged B/F on 11KV Sadath Nagar feeder

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	1	85									
2	NLG	3	110									
3	MDK	6	81									
4	RR(S)	10	95		3		3		3			
5	RR(N)	45	248		1		1		1			
6	RR(E)	33	193									
7	Hyd	134	832		2		2		2			
	<b>Total</b>	<b>232</b>	<b>1644</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	78	891		3		2		2		1	11KV 1 No. Still
2	NLG	109	738		11		11		11			
3	MDK	75	683	1	4	1	4	1	4			
4	RR(S)	30	335									
5	RR(N)	8	48									
6	RR(E)	15	78									
	<b>Total</b>	<b>315</b>	<b>2773</b>	<b>1</b>	<b>18</b>	<b>1</b>	<b>17</b>	<b>1</b>	<b>17</b>	<b>0</b>	<b>1</b>	
	<b>Grand Total</b>	<b>547</b>	<b>4417</b>	<b>1</b>	<b>24</b>	<b>1</b>	<b>23</b>	<b>1</b>	<b>23</b>	<b>0</b>	<b>1</b>	