

TSSPDCL - LMRC / Corporate office

Date: 05.06.2016

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Naraynkhed	Wasar	33KV	Jogipet	6:30	10:10	3:40		B/D Due to Disc & Insulator Fail near Wasar(V)	Naraynkhed	-
2		Naraynkhed	Kalher	33KV	Jogipet	7:30	9:10	2:20		B/D Due to Pole damaged & New Pole Erection near Kalher(V)	Naraynkhed	-
3		Naraynkhed	Sirgapur	33KV	Jogipet	9:20	13:30	4:10		B/D Due to Disc Fail near Sanjeevanraopet(V)	Naraynkhed	-
4		Zaheerabad	Zaheerabad	33KV	Zaheerabad	14:40	16:10	1:30		B/D Due to insulator binding failure	Zaheerabad	-

## TSSPDCL - LMRC / Corporate office

Date: 05.06.2016

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kadthal	Chellampally	11KV	Jadcherla	3:30	11:00	7:30		11kv wire cut near Peddavelmulabai thanda	-
2		Kondurgu	Chodarguda	11KV	Jadcherla	0:00	13:50	13:50		Tree follon the line near Gurrampally	-
3		Koduparthu	Pothireddypally	11KV	Jadcherla	11:30	15:10	3:40		Insulator fail near Pothireddypally	-
4		T.K.Pally	Chandradana	11KV	Jadcherla	13:30	15:00	1:30		Phase to Phase near Chandradana	-
5		Vankeshwaram	Ippalapally	11KV	Nagarkurnool	0:00	12:10	12:10		Due to 11KV Pole Damaged Chenchu Thanda	-
1	NLG	Raghunadapalem	Raghunadapalem	11KV	Huzurnagar	01.00	05.30	04.30	E/L	Due to 11 KV Disk failed At Raghunadapalem Village	-
2		Gondiryala	Gondiryala	11KV	Huzurnagar	05.10	06.55	01.45	E/L	Due to capur patti failed at Gondiryala village	-
3		Gondiryala	Chimiryala	11KV	Huzurnagar	00.00	05.15	05.15	E/L	11 kv jumper cut at chimiryala village	-
4		Repala	N S gudem	11KV	Huzurnagar	06.20	09.00	02.40	E/L	11 kv line snapped at N S gudem village	-
5		Ananthagiri	Ananthagiri	11KV	Huzurnagar	14.55	15.55	01.00	E/L	11 kv line snapped at mogalaikota village	-
6		Akupamula	Kodandarampuram	11KV	Huzurnagar	02.00	06.00	04.00	E/L	11 KV line snapped at kodandarampuram village	-
7		S.V.Collage	Loyala X press	11KV	Suryapet	04.10	05.30	01.20	E/L	Tree branch fallen	-
8		Marriguda	Konduru	11KV	Devarakonda	02.00	06.00	04.00	E/L	DTR Failed SS.No. Konduru	-
9		Marriguda	VATTIPALLY	11KV	Devarakonda	04.00	07.00	03.00	E/L	11Kv Jumper cut	-
10		Chamapur	Chamapur	11KV	Bhonagir	02.10	06.10	04.00	E/L	11KV Line Snapped Near Chamapur	-
11		Cheruvupally	Dhacharam	11KV	Nalgonda	07.00	10.30	03.30	E/L	Disk failed	-
12		SLBC	Kothapally	11KV	Nalgonda	09.00	11.30	02.30	E/L	Abswith fault	-
13		Mushampally	Mushampally	11KV	Nalgonda	05.00	07.00	02.00	E/L	Jumper cut	-
14		Narayanpur	Kothagudem	11KV	Nalgonda	07.00	10.30	03.30	E/L	SS24 DTR Failed	-
15		Thoragal	Madharam	11KV	Nalgonda	06.00	10.00	04.00	E/L	SS.5 Jumper cut	-
16		Thipparthu	G.G.Palem	11KV	Nalgonda	07.00	09.00	02.00	E/L	Jumper cut	-
17		Ramannapeta	Siripuram	11KV	Nalgonda	02.00	05.30	03.30	E/L	Insulator failed	-
18		Pagidimarri	Pagidimarri	11KV	Nalgonda	13.00	16.00	03.00	E/L	Heavy rain and wind	-
19		Pagidimarri	Dorepally	11KV	Nalgonda	13.00	16.00	03.00	E/L	Heavy rain and wind	-
1	MDK	Thogita	H. Ghanpur	11KV	Medak	1:40	8:00	6:20		B/D Due to 11kv insulator failure	-
2		Thogita	H. Ghanpur	11KV	Medak	12:00	14:45	2:45		B/D Due to tree branch fallen the line	-
3		Thogita	Aurangabad	11KV	Medak	2:00	8:15	6:15		B/D Due to 11kv insulator failure	-
4		Rajpally	Venkatapur	11KV	Medak	2:00	12:30	10:30		B/D Due to tree branch fallen the line	-
5		Venkatrapet	Venkatrapet	11KV	Medak	2:00	14:25	12:25		B/D Due to tree branch fallen the line	-
6		Hathnoora	Lingapur	11KV	Medak	7:00	12:30	5:30		B/D Due to 11KV Disc failure	-
7		Hathnoora	Nawabpet	11KV	Medak	8:00	10:00	2:00		B/D Due to Conductor snapped	-
8		Hathnoora	Hathnoora R	11KV	Medak	5:00	12:30	7:30		B/D Due to Jumper Cut	-
9		Kulcharam	Kulcharam	11KV	Medak	6:10	8:30	2:20		B/D Due to tree branch fallen the line	-
1	RR S	Gargstell	Khanapur	11KV	RJNR	6:10	7:57	1:47		Tree Branchces Fallen on 11 KV Line at Nagulapally	-
2		CBIT	Kokapet	11KV	RJNR	6:10	8:50	2:40		Tree Branchces Fallen on 11 KV Line at OOR	-
3		Mamidipally	Thukkuguda	11KV	CHPT	4:05	5:20	1:15		Line petroling no fault	-
4		Mamidipally	Pahadishareef	11KV	CHPT	10:20	11:10	0:50		Bird touched to 11KV AB Switch at Quba Colony dodi DTR	-
1		Nanakramguda	Church	11KV	GCB	03.15	05.10	01.55	BD	Post Office 11kv Pin Insulator Failed at Nanakramguda SS Back Side	-
2		Nanakramguda	Manjeera Diamond	11KV	GCB	03.53	05.53	02.00	BD	11kv Pin Insulator Failed at Gopanpally	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
3	RR N	IJM	New 9th Phase	11KV	GCB	03.30	05.05	01.35	BD	Flaxy Fallen on 11kv Line at 9th Phase	-
4		Mayuri nagar	Mayuri nagar	11KV	KKP	04.05	05.30	01.25	BD	11kv pin Insulator failure at ARK Apt Myurinagar	-
5		Suraram R G K	Suraram village	11KV	KKP	03.00	04.30	01.30	BD	Tree fallen On the 11kv Line at Suraram village	-
6		Athiwelly	SPIC	11KV	Medchal	03.50	06.30	02.40	BD	2 No Disc and 2 Nos Pin Insulator failed near SS	-
7		Aliabad	Jaganguda	11KV	Medchal	02.50	05.20	02.30	BD	Tree fallen on the 11KV Line at Usha Company, Jaganguda	-
1	RR E	IDA Uppal	Metro	11KV	HBG	03.30	05.20	01.50		11KV Pin Insulator failed at Metro Opposite	-
1	HYD N	Seethaphalmandi	Medibavi	NT	V	03.40	04.45	01.05	EL,OL	No Visible Fault	-----
2		Gymkhana	Sikh Village	NT	V	03.03	06.05	03.02	EL,OL-Rph	Pin Insulator flash over at Bantia Garden	-----
3		Patigadda	Rani Gunj	NT	V	03.02	04.10	01.08	EL	No Visible Fault	-----
4		Osm. University	Mettuguda	NT	V	03.00	04.45	01.45	EL,OL-Rph	No Visible Fault	-----
5		Osm. University	Keshava Nagar	NT	V	03.00	04.30	01.30	EL	No Visible Fault	-----
6		I.I.C.T	Deccan	NT	V	03.38	05.46	02.08	EL,OL	HT Jumper cut at Street No.1	-----
7		Bowenpally	Pension Line	NT	VI	03.00	05.40	02.40	All Indication	Disc Insulator flash over at Pension Line	-----
8		Bowenpally	Plassy Line	NT	VI	03.00	04.30	01.30	All Indication	No Visible Fault	Arranged B/F on 11KV Kalinga Enclave feeder
9		Yellareddyguda	Pragathi Nagar	NT	X	03.10	04.58	01.48	EL,OL	Tree branches fallen on lines at Shakthi Apts	-----
10		Jubilee Hills	Art Gallery	NT	X	04.20	06.05	01.45	All Indication	Disc Insulator flash over at Madhapur PS	-----
11		Road No.12	Kanaka Durga Temple	NT	X	06.56	08.00	01.04	EL	Disc Insulator flash over at Reliance Digital	-----
12		LV Prasad Marg	Road No.14	NT	X	03.10	05.30	02.20	EL,OL	Cable fault at Zahera Masjid	-----
1	HYD S	Kandikalgate	Phoolbagh	ST	III	04.00	05.30	01.30	EL	AB Cable fault at Lukey Star Hotel	-----
2		Aliyabad	Police Quarters	ST	III	11.30	13.39	02.09	EL	Cable fault at Police Quarters	Arranged B/F on 11KV Jangamett ABC fdr
3		Asmangadh	G.A Bank Colony	ST	VIII	03.20	05.18	01.58	EL,OL	No Visible Fault	Arranged B/F on 11KV P & T Colony feeder
4		Karwan	Tallagadda Cable	ST	IX	03.30	05.45	02.15	EL,OL	No Visible Fault	-----
5		Seetharambagh	Dhoolpet UG	ST	IX	03.00	05.00	02.00	EL,OL-Rph	Insulator flash over at Jali Hanuman	-----
1	HYD C	Z.P Office	Seven Temple	CEN	I	03.16	04.30	01.14	EL	Tree branches fallen on lines at Shadan College	-
2		Z.P Office	Ram Leela Maidan	CEN	I	03.13	04.50	01.37	EL,OL	No Visible Fault	-
3		Erramanzil	I.C Quarters	CEN	I	03.25	06.00	02.35	EL,OL	Tree branches fallen on lines at Intelligence Office	-
4		Lake View	N.K.M's Hotel	CEN	I	03.56	05.43	01.47	EL,OL-Yph	Tree branches fallen on lines at Ford Show Room	-
5		Hussain Sagar	Lakdikapool	CEN	I	03.30	05.20	01.50	EL	HT Jumper cut at Ladikapool	-
6		Langer House	Prashanth Nagar	CEN	VII	03.25	05.00	01.35	EL,OL	No Visible Fault	-
7		Langer House	Military Hospital	CEN	VII	03.30	05.00	01.30	EL,OL	No Visible Fault	-
8		Golconda	Darga OH	CEN	VII	03.05	05.10	02.05	EL,OL	Tree branches fallen on lines at Maruthi Nagar	-
9		S.D Hospital	Ahmed Nagar OH	CEN	VII	03.35	05.05	01.30	All Indication	No Visible Fault	-
10		Golconda	Narayanamma College	CEN	VII	03.35	10.40	07.05	EL,OL	315KVA DTR Cable fault at Vaternity Colony	-

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	1	85									
2	NLG	3	110									
3	MDK	6	81									
4	RR(S)	10	95		4		4		4			
5	RR(N)	45	248		7		7		7			
6	RR(E)	33	193		1		1		1			
7	Hyd	134	832		27		27		27			
	<b>Total</b>	<b>232</b>	<b>1644</b>	<b>0</b>	<b>39</b>	<b>0</b>	<b>39</b>	<b>0</b>	<b>39</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN		5		5		5		5			
2	NLG		19		19		19		19			
3	MDK	4	9	4	9	4	9	4	9			
4	RR(S)	30	335									
5	RR(N)	8	48									
6	RR(E)	15	78									
	<b>Total</b>	<b>57</b>	<b>494</b>	<b>4</b>	<b>33</b>	<b>4</b>	<b>33</b>	<b>4</b>	<b>33</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>289</b>	<b>2138</b>	<b>4</b>	<b>72</b>	<b>4</b>	<b>72</b>	<b>4</b>	<b>72</b>	<b>0</b>	<b>0</b>	