

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	52	153									
2	NLG	12	397									
3	MDK	82	350									
4	RR(S)	40	201		1		1		1			
5	RR(N)	74	389		1		1		1			
6	RR(E)	41	331									
7	Hyd	161	964		2		2		2			
	Total	462	2785	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	81	891	2		2		2				
2	NLG	109	738		8		8		8			
3	MDK	81	690		2		2		2			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	15	79									
	Total	325	2784	2	10	2	10	2	10	0	0	
	Grand Total	787	5569	2	14	2	14	2	14	0	0	

TSSPDCL - LMRC / Corporate office

Date: 04.09.2016

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Kondapur	33KV	Mahabubnagar	06.55	07.40	00.45	E/L	Tree fallen on the 33KV line		-
2		Mahabubnagar	Jadcherla	33KV	Jadcherla	03.12	07.20	04.08	E/L	33KV Y Phase Jumper Cut near Padmavathi Colony		-

TSSPDCL - LMRC / Corporate office

Date: 04.09.2016

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Pagidimarri	Dorepally	11KV	Nalgonda	09.00	10.00	01.00	E/L	11KV Line Jumper Cut	-
2		Palakedu	Nagireddygudem	11KV	Huzurnagar	02.00	06.00	04.00	E/L	11Kv Snapped at Nagireddygudem	-
3		Repala	Repala	11KV	Huzurnagar	10.00	11.00	01.00	E/L	11Kv Snapped at Repala	-
4		Ananthagiri	Ananthagiri	11KV	Huzurnagar	03.40	07.40	04.00	E/L	11Kv Snapped at Anthagiri	-
5		Thogarai	Kapugallu	11KV	Huzurnagar	10.00	11.30	01.30	E/L	11Kv Jumper cut at Kapugallu	-
6		Kudakuda	Kudakuda Agl	11KV	Suryapet	12.00	14.30	02.30	E/L	Tree branch fallen on the line	-
7		Nuthankal	Somlathanda	11KV	Suryapet	10.35	12.10	01.35	E/L	Insulator failed	-
8		Rajapet	Singaram	11KV	Bhongir	09.00	13.00	04.00	E/L	11KV Line snapped at rajapet	-
1	MDK	Rajpally	Komtoor	11KV	Medak	13.40	18.00	04.20		B/D Due to HG Fuse wire cut	-
2		Narspaur	Avancha	11KV	Medak	06.00	13.00	07.00		B/D Due to Insulator Failed at Avncha Village	-
1	RR S	Ibrahimbagh	Osman sagar	11KV	RJNR	7:37	10.10	02.33	B/D	11kv Cable Jumper cut Touching to Channel at Ramdev guda	-
1	RR N	Gachibowli	Nalagandla	11KV	Gachibowli	07.25	09.15	01.50	BD	11KV Disc Failed Near Barbar Shop T/F At Gopi Nagar	-
1	HYD C	Golnaka	Moulana Azad Nagar	11KV	II	01.52	04.20	02.28	OL	Cable fault	Arranged B/F on 11KV Tourist Hotel fdr
2		Vittalwadi	ICICI Bank	11KV	I	05.10	07.50	02.40	EL,OL	Internet wire fallen on lines & HG fuse blown off near Tourism Office	-----