

TSSPDCL - LMRC / Corporate office

Date: 29.09.16

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Amangal	Kadthal	33KV	Jadcherla	12.47	16.50	04.03	E/L	Kadthal Line Tag on to 33KV Amangal Feeder	Kadthal	No
1	HYD S	220KV Ch' Gutta	Asmangadh	33KV	Malakpet	03.40	04.10	00.30	EL,OL	Cable End Kit failed near Shiva Ganga Theater	Asmangadh	Loads transferred onto 220KV Ch' Gutta SS via 33KV Malakpet Gunj SS

TSSPDCL - LMRC / Corporate office

Date: 29.09.16

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kothapally	Kasarajpally	11KV	Devarakonda	1:00	3:00	2:00	E/L	11Kv Insulater Failed	No
2		Garidepally	Medaram	11KV	Huzurnagar	01.00	05.00	04.00	E/L	11Kv Insulator Failure at Medaram Village	No
3		N.G Bandala	VR.Pally	11KV	Bhongir	11.00	13.00	02.00	E/L	11KV Line snapped at V.R Pally	No
4		Yerkaram	Solipeta	11KV	Suryapet	08.00	10.45	02.45	E/L	11Kv Line cut	No
1	RR S	Mallapur	Al Jabri Colony	11KV	Champapet	9:45	11:33	1:48	EL	11KV Insulator failed on 11KV line at Thazari Colony	No
2		Puttapahad	Anyharam	11KV	Vikarabad	04.00	07.00	03.00	EL	Pole damaged at Ghanapur Gate	No
1	RR E	Hayatnagar	Kalvancha	11KV	Saroor Nagr	0:00	1:25	1:25		11KV Insulator failed at Saroor Nagar Kalvancha	No
1	HYD S	Karwan	Tallagadda OH	11KV	Begumbazar	06.00	07.00	01.00	EL,OL	No Visible Fault	No

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	52	153									
2	NLG	12	397									
3	MDK	83	350									
4	RR(S)	40	201		1		1		1			
5	RR(N)	74	393									
6	RR(E)	41	331		1		1		1			
7	Hyd	161	965	1	1	1	1	1	1			
	Total	463	2790	1	3	1	3	1	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	81	891	1		1		1				
2	NLG	109	738		4		4		4			
3	MDK	81	695									
4	RR(S)	31	338		1		1		1			
5	RR(N)	8	48									
6	RR(E)	15	79									
	Total	325	2789	1	5	1	5	1	5	0	0	
	Grand Total	788	5579	2	8	2	8	2	8	0	0	