

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	38	209									
5	RR(N)	77	399	1	2	1	2	1	2			
6	RR(E)	38	347		1		1		1			
7	Hyd	183	982		1		1		1			
	Total	494	2884	1	4	1	4	1	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	106	969	1		1		1				
2	NLG	150	948		3		3		3			
3	MDK	87	828									
4	RR(S)	27	316									
5	RR(N)	8	48									
6	RR(E)	18	80									
	Total	396	3189	1	3	1	3	1	3	0	0	
	Grand Total	890	6073	2	7	2	7	2	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 12.04.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthi	Kothakota	33KV	Wanaparthi	15.40	17.20	01.40	E/L	No Visible fault due to line petroling and jumper open and connected Supply stood ok	Buddaram, Mommaipally, Polkepad	Jumpers Opened at Buddaram Gandhi at 17:20 Hrs
1	RR N	IDPL	Balajinagar	33KV	BD	10.27	18.10	07.43	BD	33kv Endkit failure and replaced	Balajinagar	-

TSSPDCL - LMRC / Corporate office

Date: 12.04.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Thimannagude	Telakantigudem	11KV	Nalgonda	07.30	11.00	03.30	E/L	11 KV Line Jumper Cut at SS-1	-
2		IDA	Bommaipally	11KV	Bhongir	07.00	13.00	06.00	EL	11KV 2 Diskfailed near Bommaipally	-
3		Solipet	Peraram	11KV	Bhongir	13.00	15.00	02.00	EL	HT/LT	-
1	RR N	Chandanagar	Shankar nagar	11KV	Kukatpally	09.50	10.30	00.40	BD	A bird Fallon the 11kv line at Tele Phone Colony	-
2		Suraram	Rajiv Ghandhinagar	11KV	Kukatpally	17.55	19.00	01.05	BD	11kv line AB Cable Endkit failure at Rajiv gandhinagar	-
1	RR E	Tattiannaram	Tattiannaram	11KV	SRNR	17.45	19.00	01.15		11KV Lizard Fallone 11KV line at RK Nagar Near Tattiannaram	-
1	HYD N	Yellareddyguda	Pragathi Nagar	11KV	X	15.15	16.20	01.05	EL	Cable fault at Shalivahan Nagar Park	-