

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	77	404		1		1		1			
6	RR(E)	38	347									
7	Hyd	184	993		1		1		1			
	Total	497	2892	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	108	969	1	2	1	2	1	2			
2	NLG	150	948		4		4		4			
3	MDK	87	828		2		2		2			
4	RR(S)	29	322									
5	RR(N)	8	48									
6	RR(E)	18	80									
	Total	400	3195	1	8	1	8	1	8	0	0	
	Grand Total	897	6087	1	10	1	10	1	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 25.04.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Gadwal	Dharoor	33KV	Gadwal	05.42	09.05	03.23		Conductor Snapped near Gonupad Village	Dharoor	-

TSSPDCL - LMRC / Corporate office

Date: 25.04.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Vityal	Vityal	11KV	Jadcherla	14.15	16.10	01.55		11kv wire cut near Ediganipally	-
2		Vityal	Kishan Nagar	11KV	Jadcherla	12.15	16.00	03.45		11kv wire cut near degree collegr back side jadcherla	-
1	NLG	Kethapally	Korlaphad	11KV	Suryapet	12.00	14.15	02.15	EL	Jumpur cut	-
2		N.G Bandal	V.r.Pally	11KV	Bhongir	08.30	12.00	03.30	EL	11KV Jumper Snapped At Tirumalapur	-
3		Alingapuram	Raghavapuram	11KV	Huzurnagar	03.00	07.00	04.00	EL	Due to 11Kv Snapped Near Raghavapuram Village	-
4		Repala	Narsimhulagudem	11KV	Huzurnagar	07.30	11.00	03.30	EL	Due to 11Kv Snapped Near Narsimhulagudem Village	-
1	MDK	NSF	Chityala	11KV	Medak	14.30	17.30	03.00		B/D due to insulater failed	-
2		Rajpally	Rajpally	11KV	Medak	13.50	17.00	03.10		B/D due to jumper cut.	-
1	RR N	Suraram	Matrix	11KV	Kukatpally	08.45	10.01	01.16		11kv line Endkit failure opp:KLR Company at phase-IV	-
1	HYD N	I.I.C.T.	Dall Mill	11KV	V	01.10	02.45	01.35	EL,OL	Cable End Kit failed at Dall Mill	Arranged B/F on 11KV Deccan fdr