

TSSPDCL - LMRC / Corporate office

Date: 05.02.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	HYD S	132KV Asif Nagar	Kulsumpura	CEN	Asif Nagar	03.50	03.58	00.08	EL,OL-Rph	Under Breakdown	132KV Asif Nagar	Loads transferred onto 132KV Imlibun SS via 33KV Gosha Mahal fdr

TSSPDCL - LMRC / Corporate office

Date: 05.02.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Devarkadra	Gudibanda	11KV	Mahabubnagar	09.30	15.30	06.00		11KV Conductor cut near Deavarkadra (V)	-
1	NLG	Y.Singaram	Y.Singaram	11KV	Huzurnagar	05.00	08.20	03.20	EL	Due to AB Switch Fault near Y.Singaram village	-
2		Kanagal	Kanagal AGL	11KV	Nalgonda	13.30	15.00	01.30	E/L	11KV line cut at Kanagal wagu	-
3		Chanduptla	Veeravally	11KV	Bhongir	02.00	05.00	03.00	EL	11KV Insulator failed at veeravally	-
1	RR S	CBIT	11kv Gandipet	11KV	RJNR	16.13	17.19	01.06		Kites fallen on 11KV line at gandipet village	-
2		Chamapept	Sultanvala	11KV	CPT	14.00	15.30	01.30		11KV Line snapped at Gandhi Statue Champapet	-
3		Mamidipally	Videocon	11KV	CPT	13.30	15.05	01.35		Cable failed at Housing board colony	-
1	HYD N	Gymkhana	Tadbund Temple	11KV	Sec-Bad	05.02	06.40	01.38	EL,OL	Cable fault	Arranged B/F on 11KV Sikh Village feeder
2		Gunrock	Surya Enclave	11KV	Bowenpally	18.20	19.45	01.25	EL	Disc Insulator flash over Aruna Enclave	partial loads arranged B/F on 11KV Thirumalgiri fdr 10 DTR's kept off at S.P Colony
1	HYD S	Khilwath	Khazipura	11KV	Charminar	00.15	02.55	02.40	OL	UG Cable fault at Shakkergunj	-

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	153									
2	NLG	18	406									
3	MDK	85	383									
4	RR(S)	38	237		3		3		3			
5	RR(N)	77	398									
6	RR(E)	38	347									
7	Hyd	169	966	1	3	1	3	1	3			
	<b>Total</b>	<b>473</b>	<b>2890</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>6</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	104	894		1		1		1			
2	NLG	150	728		3		3		3			
3	MDK	94	826									
4	RR(S)	31	289									
5	RR(N)	8	49									
6	RR(E)	18	79									
	<b>Total</b>	<b>405</b>	<b>2865</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>878</b>	<b>5755</b>	<b>1</b>	<b>10</b>	<b>1</b>	<b>10</b>	<b>1</b>	<b>10</b>	<b>0</b>	<b>0</b>	