

TSSPDCL - LMRC / Corporate office

Date: 06.02.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Shadnagar	Stem Core	33KV	Jadcherla	16.05	18.50	02.45	E/L&O/L	Disc Replaced and loos line strining near Shadnagar SS back side	Stem Core	No

TSSPDCL - LMRC / Corporate office

Date: 06.02.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	B.Chandupatla	Pachya Thanda	11KV	Suryapet	03.30	07.15	03.45	E/L	Insulator failed	-
2		Dirincherla	Dirincherla	11KV	Huzurnagar	13.00	15.00	02.00	E/L	11 AB Switch problem at Enjavarigudem village	-
3		Kopple	Bollaram	11KV	Devarakonda	13.00	14.30	01.30	E/L	11kv Jumper Cutting	-
1	HYD S	Salarjung	Alija Kotla	11KV	Charminar	00.50	04.45	03.55	EL	Cable fault	Partial fdr charged & remaining loads arranged B/F on 11KV Gulzar House feeder

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	153									
2	NLG	18	406									
3	MDK	85	383									
4	RR(S)	38	237									
5	RR(N)	77	398									
6	RR(E)	38	347									
7	Hyd	169	966		1		1		1			
	Total	473	2890	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	104	894	1		1		1				
2	NLG	150	728		3		3		3			
3	MDK	94	826									
4	RR(S)	31	289									
5	RR(N)	8	49									
6	RR(E)	18	79									
	Total	405	2865	1	3	1	3	1	3	0	0	
	Grand Total	878	5755	1	4	1	4	1	4	0	0	