

TSSPDCL - LMRC / Corporate office

Date: 07.01.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	Gachibowli	Chandanagar	33KV	Gachibowli	05.40	09.47	04.07	BD	BD due to 33kv end kit failure at papireddy colony		-

TSSPDCL - LMRC / Corporate office

Date: 07.01.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Nakrekal	Nomula	11KV	Suryapet	06.00	08.40	02.40	E/L	Tree branch fallen on the line	-
2		Ramannapeta	Kommaigudem	11KV	Nalgonda	05.00	08.00	03.00	E/L	11KV Line Cut at 132KV Sub-Sation Back Side	-
3		Kopple	A.B.Colony	11KV	Devarakonda	08.00	11.00	03.00	E/L	11kv jumper cutting	-
1	MDK	Malkapur	Malkapur	11KV	Sangareddy	12.30	13.10	00.40		B/D Due to conductor snapped near Peddapur	-
2		Isnapur	Muthangi Agl	11KV	Sangareddy	13.04	15.30	02.26		B/D Due to tree branch fallen on line	-
1	RR N	Chandanagar	Mythri Nagar	11KV	Gachibowli	09.25	10.45	01.20	EL	Tree Branches Fallen on The 11kv Lline at Madinaguda B Block	-
1	RR E	Tattiannaram	Tattiannaram	11KV	SRNR	11.30	12.30	01.00		Line Petroling but no Visible falt	-
1	HYD S	Khilwath	Laldarwaza	11KV	Charminar	12.43	14.49	02.06	EL,OL-Rph	I/C Cable fault at Volga Hotel	Arranged B/f on 11KV kazipura fdr

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	52	153									
2	NLG	12	397									
3	MDK	83	350									
4	RR(S)	40	201									
5	RR(N)	75	398	1	1	1	1	1	1			
6	RR(E)	41	337		1		1		1			
7	Hyd	169	966		1		1		1			
	Total	472	2802	1	3	1	3	1	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	83	894									
2	NLG	142	738		3		3		3			
3	MDK	81	703		2		2		2			
4	RR(S)	31	338									
5	RR(N)	8	49									
6	RR(E)	15	79									
	Total	360	2801	0	5	0	5	0	5	0	0	
	Grand Total	832	5603	1	8	1	8	1	8	0	0	