

TSSPDCL - LMRC / Corporate office

Date: 23.01.17

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kattangur	Dugunevelly	11KV	Suryapet	5:30	9:00	3:30	E/L	11Kv Line cut	No
2		Narketpally	Mandra	11KV	Nalgonda	07.35	09.55	02.20	E/L	11KV Line Insulator Failed SS.56	No
3		Seethya Thanda	Vemulapally	11KV	Miryalguda	12.25	13.40	01.15	E/L	11KV Conductor snapped	No
1	MDK	Kowdipally	Mohd Nagar	11KV	Medak	9:05	10:40	1:35		B/D Due to Jumper cut	No
1	HYD N	Madhapur	Van-En-Burg	11KV	Jublee Hills	14.10	15.25	01.15	EL,OL-Rph	AB Switch fault at UBI Park	No
1	HYD S	Malakpet	Yashoda Hospital	11KV	Asmangadh	17.00	18.30	01.30	OL-Y&Bph	Bird fault on Lines & Yph Jumper cut at SS	No

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	153									
2	NLG	18	406									
3	MDK	85	383									
4	RR(S)	38	237									
5	RR(N)	77	398									
6	RR(E)	38	347									
7	Hyd	169	966		2		2		2			
	Total	473	2890	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	104	894									
2	NLG	150	728		3		3		3			
3	MDK	94	826		1		1		1			
4	RR(S)	31	289									
5	RR(N)	8	49									
6	RR(E)	18	79									
	Total	405	2865	0	4	0	4	0	4	0	0	
	Grand Total	878	5755	0	6	0	6	0	6	0	0	