

TSSPDCL - LMRC / Corporate office

Date: 11.07.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Jadcherla	33KV	Town	18.50	23.25	04.35		B Phase Bus Isolator to Breaker Jumper & B Phase Isolator to Line Jumper Snapped at 132KV SS. Connecting Snapped Jumpers at Badepally	Mahabubnagar	-
1	MDK	Habsipur	Raghothampally	33KV	Siddipet	15.53	16.53	01.00		B/D Due to Disk failed		-

TSSPDCL - LMRC / Corporate office

Date: 11.07.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Wangamarthy	Chittaloor	11KV	Suryapet	06.25	09.00	02.35	E/L	11KV Line cut near SS-15	-
2		Narketpally IE	Vattimarthy	11KV	Nalgonda	07.00	08.30	01.30	E/L	11 KV Line Insulator Failulre SS-6	-
3		Thimmannagudem	T.K.Gudem	11KV	Nalgonda	12.00	14.20	02.20	E/L	11KV Line Insulator Failure	-
4		Gaddipally	Medaram	11KV	Huzurnagar	14.30	16.30	02.00	EL	Due to 11Kv Snapped near Medaram village	-
5		Janpahad	Janpahad	11KV	Huzurnagar	03.00	06.15	03.15	EL	Due to AB swtich fault near Janpahad village	-
6		Repala	Repala	11KV	Huzurnagar	07.00	10.00	03.00	EL	Due to AB swtich fault near Repala village	-
7		Nadigudem	Ratnavaram	11KV	Huzurnagar	00.00	02.00	02.00	EL	Due to 11Kv Disk failure near Ratnavaram village	-
8		Ananthagiri	Mogalaikota	11KV	Huzurnagar	06.00	09.30	03.30	OL	Due to 11Kv Jumper cut near Mogalaikota village	-
1	MDK	Nagapur	ThimMaipally	11KV	Medak	08.00	10.00	02.00		B/D Due to Conductor Snapped	-
2		Narmetta	Thimmaipally	11KV	Siddipet	11.00	15.00	04.00		B/D Due to Insulater failed	-
3		Thornal	Appanapaly	11KV	Siddipet	07.16	08.10	00.54		B/D Due to Insulater failed	-
1	RR N	K P HB	Shathavana Nagar	11KV	KKP	21.56	23.00	01.04	BD	11kv Disk Failure At KalaMaindir Shop Mall BhagyNagar	-

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360									
7	Hyd	186	1014									
	Total	504	2929	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1		1		1				
2	NLG	150	948		8		8		8			
3	MDK	87	828	1	3	1	3	1	3			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	2	11	2	11	2	11	0	0	
	Grand Total	908	6149	2	12	2	12	2	12	0	0	