

TSSPDCL - LMRC / Corporate office

Date: 16.07.2017

| S.No | Circle | Name of 33/11KV SS    | Name of 11 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown  | Alternate Supply Arranged                           |
|------|--------|-----------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|---|
| 1    | MBNR   | Koukuntla             | Gopanpally           | 11kv | Mahabubnagar         | 04.00 | 06.30 | 02.30    |                  | 11KV Jumper cut near Dokur (Vi)   | -   |
| 1    | NLG    | Marriguda             | Kondur               | 11kv | Devarakonda          | 8:00  | 11:00 | 3:00     | EL               | Jumpet Cut  | -   |
| 2    |        | Nuthankal             | Chilpakuntla         | 11kv | Suryapet             | 13:00 | 15:30 | 2:30     | EL               | Insulator failure   | -   |
| 3    |        | Repala                | Repala               | 11kv | Huzurnagar           | 6:00  | 9:00  | 3:00     | EL               | Due to 11kv line cutted near Repala village                             | -   |
| 1    | RR S   | Indira Gandhi Society | Indirashivashakti    | 11kv | RJNR                 | 20.52 | 22.30 | 01.38    | B/D              | 11KV Insulator failed at Pooja Galli, AB Switch sparking at Lalji Galli | -   |
| 1    | RR N   | IIIT                  | Kendriya Vihar       | 11kv | GCB                  | 17.40 | 20.16 | 02.36    | BD               | Due to heavy rain (Line petroling, no visible fault found)              | -   |
| 2    |        | ESCI                  | Lubmini Park         | 11kv | GCB                  | 19.43 | 21.05 | 01.22    | BD               | Due to heavy rain (Line petroling, no visible fault found)              | -   |
| 3    |        | IIIT                  | Kendriya Vihar       | 11kv | GCB                  | 20.20 | 21.50 | 01.30    | BD               | 11KV pin insulator failed at Bata showrom, Vinyak nagar                 | -   |
| 4    |        | JNTU                  | S P Nagar            | 11kv | GCB                  | 20.50 | 22.10 | 01.20    | BD               | Lizard fallen on the T/F at Plot no-270,Vasanthnagar                    | -   |
| 5    |        | Bahadurpally          | I D A-2              | 11kv | KKP                  | 01.20 | 02.30 | 01.10    | BD               | Tree Branches Fallen on the 11kv Line at Jyothi milk                    | -   |
| 6    |        | Mayurinagar           | Ram Naresha Nagare   | 11kv | KKP                  | 20.00 | 21.30 | 01.30    | BD               | 11kv Pin Insultor Failure At maharashtra Bank Ram naresha Nagar         | -   |
| 7    |        | Thurkapally           | Thurkapally          | 11kv | MEDCL                | 12.40 | 15.30 | 02.50    | BD               | 11KV DISC failed at Thurkapally Village                                 | -   |
| 8    |        | Kolthur               | Anatharam            | 11kv | MEDCL                | 15.45 | 16.15 | 00.30    | BD               | 100KVA DTR Post of Insulator failed at Anatharam                        | -   |
| 9    |        | Kompally              | Kompally             | 11kv | MEDCL                | 20.05 | 20.43 | 00.38    | BD               | Tree Fallen on 11KV Line at Fish Godham Kompally                        | -   |
| 10   |        | Kompally              | Petbasirbag          | 11kv | MEDCL                | 20.05 | 21.05 | 01.00    | BD               | Tree Fallen on 11KV Line at Deccan cranial NCL                          | -   |
| 1    | RR E   | VK Nagar              | Neredmet Daiet       | 11kv | Sainikpuri           | 17.55 | 18.25 | 00.30    |                  | 11Kv Pin Insulator failed at Chaina Bazar (AE/VK Nagar)                 | -   |
| 2    |        | NAGOLE                | MAMATHA NAGAR        | 11kv | SAROOR NAGAR         | 06.08 | 07.08 | 01.00    | EL               | 11KV JUPER CUT AT VENKATARAMANA COLONY                                  | -   |
| 3    |        | NAGOLE                | MAMATHA NAGAR        | 11kv | SAROOR NAGAR         | 07.57 | 10.49 | 02.52    | EL               | 11KV JUPER CUT AND 11KV DISK FAIL AT NAGOLE                             | -   |
| 4    |        | Narapally             | P.Singaram           | 11kv | Habsiguda            | 21.50 | 22.55 | 01.05    |                  | 11kv jumper cut at subprabath town ship                                 | -   |
| 1    | HYD N  | Road No.13            | Star Hospital        | 11kv | X                    | 19.48 | 21.23 | 01.35    | EL,OL            | Jumper cut at Karve Office  | -----   |
| 1    | HYD S  | Chilalguda            | Musheerabad          | 11kv | I                    | 20.50 | 21.55 | 01.05    | EL,OL-Rph        | Pin Insulator flash over at 44 Bus Stop                                 | -----   |
| 1    | Hyd S  | Santosh Nagar         | Dry Land             | 11kv | VIII                 | 19.55 | 21.30 | 01.35    | EL               | Creepers fallen on lines at Harman Function Hall                        | -----   |
| 2    |        | Panjasha              | Methorwadi           | 11kv | III                  | 21.05 | 22.40 | 01.35    | OL               | Cable fault   | Arranged B/F on 11KV Sulthan Shahi & Chtrinaka fdrs |

3

|           |              |      |     |       |       |       |           |   |       |
|-----------|--------------|------|-----|-------|-------|-------|-----------|---|-------|
| Salarjung | Pather Gatti | 11kv | III | 22.55 | 00.40 | 01.45 | EL,OL-Yph | Big Tree fallen on lines at Pather Gatti Post Office & Post type Insulator flash over at Mamuki Talla | ----- |
|-----------|--------------|------|-----|-------|-------|-------|-----------|---|-------|

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown           | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|------------------------------|-----------------------|---------------------------|
| 1    | MBNR   | Nagarkurnool        | Telkapally           | 33kv | Nagarkurnool         | 19.20 | 21.20 | 02.00    | E/L              | Pole follen on the 33KV line | Telkapally, Talapally | -                         |
| 1    | MDK    | Gajwel              | Amdipur              | 33kv | Toopran              | 19.30 | 23.50 | 04.20    |                  | B/d due to Insulator fail    | Amdipur               | -                         |
| 2    |        | Ramayanpet          | Laxmapur             | 33kv | Toopran              | 23.50 | 00.00 | 00.10    |                  | B/d not rectified still      | Laxmapur              | No                        |

**Status Report on Breakdowns (Urban / Rural)****Urban**

| S.No | Circle       | No.of Feeders Existing Urban |             | Breakdowns occurred during the day |           | Attended during the day |           | Time taken for restoring the supply |           |                                |          | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
|      |              | 33KV                         | 11KV        | 33KV                               | 11KV      | 33KV                    | 11KV      | Rectified (Within 24 Hours)         |           | Not Rectified (Above 24 Hours) |          |                   |
|      |              |                              |             |                                    |           |                         |           | 33KV                                | 11KV      | 33KV                           | 11KV     |                   |
| 1    | MBN          | 48                           | 158         |                                    |           |                         |           |                                     |           |                                |          |                   |
| 2    | NLG          | 18                           | 406         |                                    |           |                         |           |                                     |           |                                |          |                   |
| 3    | MDK          | 92                           | 383         |                                    |           |                         |           |                                     |           |                                |          |                   |
| 4    | RR(S)        | 40                           | 201         |                                    | 1         |                         | 1         |                                     | 1         |                                |          |                   |
| 5    | RR(N)        | 82                           | 407         |                                    | 10        |                         | 10        |                                     | 10        |                                |          |                   |
| 6    | RR(E)        | 38                           | 360         |                                    | 4         |                         | 4         |                                     | 4         |                                |          |                   |
| 7    | Hyd          | 186                          | 1014        |                                    | 5         |                         | 5         |                                     | 5         |                                |          |                   |
|      | <b>Total</b> | <b>504</b>                   | <b>2929</b> | <b>0</b>                           | <b>20</b> | <b>0</b>                | <b>20</b> | <b>0</b>                            | <b>20</b> | <b>0</b>                       | <b>0</b> |                   |

**Rural**

| S.No | Circle             | No.of Feeders Existing Rurals |             | Breakdowns occurred during the day |           | Attended during the day |           | Time taken for restoring the supply |           |                                |          | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
|      |                    | 33KV                          | 11KV        | 33KV                               | 11KV      | 33KV                    | 11KV      | Rectified (Within 24 Hours)         |           | Not Rectified (Above 24 Hours) |          |                   |
|      |                    |                               |             |                                    |           |                         |           | 33KV                                | 11KV      | 33KV                           | 11KV     |                   |
| 1    | MBN                | 110                           | 969         | 1                                  | 1         | 1                       | 1         | 1                                   | 1         |                                |          |                   |
| 2    | NLG                | 150                           | 948         |                                    | 3         |                         | 3         |                                     | 3         |                                |          |                   |
| 3    | MDK                | 87                            | 828         | 2                                  |           | 2                       |           | 1                                   |           | 1                              |          | 1 no. 33kv still  |
| 4    | RR(S)              | 31                            | 338         |                                    |           |                         |           |                                     |           |                                |          |                   |
| 5    | RR(N)              | 8                             | 48          |                                    |           |                         |           |                                     |           |                                |          |                   |
| 6    | RR(E)              | 18                            | 89          |                                    |           |                         |           |                                     |           |                                |          |                   |
|      | <b>Total</b>       | <b>404</b>                    | <b>3220</b> | <b>3</b>                           | <b>4</b>  | <b>3</b>                | <b>4</b>  | <b>2</b>                            | <b>4</b>  | <b>1</b>                       | <b>0</b> |                   |
|      | <b>Grand Total</b> | <b>908</b>                    | <b>6149</b> | <b>3</b>                           | <b>24</b> | <b>3</b>                | <b>24</b> | <b>2</b>                            | <b>24</b> | <b>1</b>                       | <b>0</b> |                   |