

TSSPDCL - LMRC / Corporate office

Date: 11.06.17

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|-----------------------|--|
| 1 | MBNR | Maddur | Mogalmadka | 33KV | Mahabubnagar | 00.50 | 07.20 | 06.30 | E/L | Insulator failed near Bheempur to Khajipur | Mogalmadka | Alternate Supply Arranged from 33KV Kankurthy feeder at 20:15Hrs |
| 2 | | Alampur | Alampur Town | 33KV | Gadwal | 09.35 | 12.40 | 03.05 | E/L & O/L | Phase to Phase line twisting at Alampur X Road towards at Alampur Town | Alampur Town | No |
| 3 | | Alampur | Alampur Town | 33KV | Gadwal | 17.40 | 19.40 | 02.00 | E/L & O/L | Pin banding Failed near by Undavelly SS | Alampur Town | No |
| 1 | MDK | Sadashivapet | Koheer | 33KV | Sangareddy | 19:50 | 24.00 | 04.10 | | B/D Due to heavy gale and wind | Koheer | No |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|---------------------------|
| 1 | NLG | Edulur | Naregudem | 11KV | Suryapet | 03.50 | 07.00 | 03.10 | E/L | Line melt | No |
| 2 | | Mattampally | Allipuram | 11KV | Huzurnagar | 05.00 | 09.30 | 04.30 | EL | 11 KV Jumper cut at Allipuram village | No |
| 3 | | Arjalabavi | Arjalabavi | 11KV | Nalgonda | 02.15 | 06.00 | 03.45 | EL | 11KV Jumper cut | No |
| 4 | | Marriguda | Vattipally | 11KV | Devarakonda | 14.00 | 16.30 | 02.30 | EL | 11kv jumper cut | No |
| 1 | MDK | BB Pur | Muthaipally | 11KV | Medak | 05.00 | 08.00 | 03.00 | | 11KV Disc failed at Farreedpur village | No |
| 2 | | Sardhana | Jakkanpet | 11KV | Medak | 05.00 | 07.50 | 02.50 | | Jumper cut at Jakkanapet village | No |
| 3 | | Gummadidala | Gummadidala | 11KV | Medak | 17.00 | 19.00 | 02.00 | | Conductor snapped | No |
| 1 | RR S | Upparpally | Naidu Colony | 11KV | Rajendranagar | 13:05 | 14:45 | 1:40 | EL | 11KV Brass patti cut and touched to channel at Happy Homes colony | No |
| 2 | | Champapet | Padmanagar | 11KV | Champapet | 19.28 | 20.10 | 00.42 | EL | Line AB switch open at Kranthi nagar (Line petrolling no visible fault) | No |
| 1 | RR N | Nanakramguda | Gowlidoddi | 11KV | Gachibowli | 7:54 | 8:59 | 1:05 | | 25KV T/F HG Fuse Insulator failed & replacement at Government School Back Side, Gowlidoddi | No |
| 2 | | Kothaguda | Hafezpet | 11KV | Gachibowli | 19.23 | 20.35 | 01.12 | | 11KV Pin insulator failed & line snaped at Swarna Residency, Raghavendra Colony. | No |
| 3 | | Hafeezpet | Janapriya nagar | 11KV | Gachibowli | 20.15 | 22.00 | 01.45 | | 11KV Pin insulator failed at Hundai Shorom,Janapriya nagar. | No |
| 4 | | J D M SS-I | Apiic | 11KV | Kukatpally | 17.30 | 19.30 | 02.00 | | 11kv AB cable failed At Poornima company | No |
| 5 | | J D M SS-I | J E T EL | 11KV | Kukatpally | 20.15 | 21.00 | 00.45 | | 11kv Jumper Cut | No |
| 6 | | J D M SS-II | N R SA | 11KV | Kukatpally | 21.48 | 22.55 | 01.07 | | Tree fallen on the 11KV line | No |
| 7 | | K PHB | Gowthi Nagar | 11KV | Kukatpally | 21.22 | 22.22 | 01.00 | | 11kv Line AB switch opened At Srinivasa park | No |
| 8 | | Devarayamjal | Pothaipally | 11KV | Medchal | 22.30 | 23.55 | 01.25 | | CT failed in SS | No |
| 9 | | Shameerpet | Alankritha | 11KV | Medchal | 21.30 | 23.00 | 01.30 | | 11KV Pin Insulator failed at Gayatri Temple, Shameerpet | No |
| 10 | | UMCC | Crusher | 11KV | Medchal | 22:17 | 23:00 | 0:43 | | 11KV Pin insulator failed at Devender Nagar | No |
| 1 | RR E | Yapral | Tulasi Garden | 11KV | Sainikpuri | 20:08 | 21:08 | 1:00 | | Tree branches fallen on 11Kv line at Maitry Enclave | No |
| 2 | | Sainikpuri | Eshwaripuri | 11KV | Sainikpuri | 21.00 | 22.00 | 01.00 | | 11Kv Pin Inusuletor failed at Eshwaripuri Colony due to Heavy Rain | No |
| 3 | | Kushaiguda | Sriram Nagar | 11KV | Sainikpuri | 21.40 | 22.45 | 01.05 | | 11Kv line cut at Sriram Nagar Colony | No |
| 4 | | Moula-Ali | Kailasagiri | 11KV | Sainikpuri | 21.15 | 22.21 | 01.06 | | 11Kv Pin Inusuletor failur at near NCL Apt due to Heavy Rain | No |
| 5 | | Aushapur | Bokkenguda | 11KV | Habsiguda | 14.00 | 19.15 | 05.15 | | Lorry dased to 11kv pole at NFC Circle | No |
| 6 | | Cheeryal | RTC | 11KV | Habsiguda | 21.30 | 22.55 | 01.25 | | 11KV Insilatour failed at RTC colony | No |
| 7 | | Yadagarpally | Cheeryal | 11KV | Habsiguda | 20.15 | 22.30 | 02.15 | | 11KV Insilatour failed at Cheeryal Petrolpump | No |
| 1 | HYD N | Yellareddyguda | Engineer's Colony | 11KV | Jublee Hills | 12.15 | 13.30 | 01.15 | EL | Tree branches fallen on lines at Engineer's Colony Park | No |
| 2 | | Film Nagar | M.L.A Colony | 11KV | Jublee Hills | 15:50 | 16:55 | 1:05 | EL,OL-Rph | No Visible fault | No |
| 3 | | R.P Nilayam | Allwal | 11KV | Bowenpally | 19:40 | 20:46 | 1:06 | EL | No Visible fault | No |
| 4 | | Prashanth Nagar | Shakthipuram | 11KV | Bowenpally | 20:45 | 22:20 | 1:35 | EL | Disc Insulator flashed over at Rajiv Gandhi Nagar | No |

Status Report on Breakdowns (Urban / Rural)**Urban**

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 48 | 158 | | | | | | | | | |
| 2 | NLG | 18 | 406 | | | | | | | | | |
| 3 | MDK | 92 | 383 | | | | | | | | | |
| 4 | RR(S) | 40 | 201 | | 2 | | 2 | | 2 | | | |
| 5 | RR(N) | 77 | 404 | | 10 | | 10 | | 10 | | | |
| 6 | RR(E) | 38 | 347 | | 7 | | 7 | | 7 | | | |
| 7 | Hyd | 184 | 993 | | 4 | | 4 | | 4 | | | |
| | Total | 497 | 2892 | 0 | 23 | 0 | 23 | 0 | 23 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 108 | 969 | 3 | | 3 | | 3 | | | | |
| 2 | NLG | 150 | 948 | | 4 | | 4 | | 4 | | | |
| 3 | MDK | 87 | 828 | 1 | 3 | 1 | 3 | 1 | 3 | | | |
| 4 | RR(S) | 29 | 322 | | | | | | | | | |
| 5 | RR(N) | 8 | 48 | | | | | | | | | |
| 6 | RR(E) | 18 | 80 | | | | | | | | | |
| | Total | 400 | 3195 | 4 | 7 | 4 | 7 | 4 | 7 | 0 | 0 | |
| | Grand Total | 897 | 6087 | 4 | 30 | 4 | 30 | 4 | 30 | 0 | 0 | |