

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Kankurthy	33KV	Mahabubnagar	01.45	06.25	04.40	E/L	Pin Insulator Replacement near Kankurthy	Kankurthy	No
2		Thirumalaipally	Veltoor	33KV	Wanaparthy	15.24	19.30	04.06	E/L	Insulator failed and replaced near Sneha Pharm	Veltoor	No
3		Wanaparthy	Kodair	33KV	Wanaparthy	16.55	21.30	04.35	E/L	33KV Jumper connection at Rajapur (vi) , Due to Heavy Gale & Wind	Kodair	Alternate Supply arranged from 33KV Rajapur SS at 21:30
1	MDK	Narsapur	Kotha pet	33KV	Medak	18:20	22:20	4:00		B/D Due to heavy wind & gail	Kotha pet	No
2		Zaheerabad	Allana	33KV	Sangareddy	02.30	04.30	02.00		B/D Due to Jumper cut	Allana	No
1	HYD S	132KV Bandlaguda	Amberpet (Idle)	33KV	Chilkaiguda	13.20	18.18	04.58	EL	Tree branches fallen on Lines at EHT Pole No.130	Amberpet (Idle)	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Narva	Undecode	11KV	Mahabubnagar	04.15	09.30	05.15		11KV Tree fallen on the line at Undecode (V)	No
2		Makthal	Sangambanda	11KV	Mahabubnagar	05.20	09.00	03.40		11KV Conductor cut at Sangambanda (V)	No
3		Devarkadra	Lalkota	11KV	Mahabubnagar	06.00	08.30	02.30		11KV Tree fallen on the line at Lalkota (V)	No
4		Hazzipur	Chennaram	11KV	Nagarkurnool	03.00	10.00	07.00		11 KV Wire cut	No
5		Nagarkurnool	Naganool	11KV	Nagarkurnool	0:00	12:00	12:00		11 KV Wire cut	No
6		Peddapur	Molgara	11KV	Nagarkurnool	06.00	14.00	08.00		11 KV Wire cut	No
1	NLG	Dirincherla	Somaram	11KV	Huzurnagar	5:50	9:30	3:40	E/L	11 KV Jumper cut at Somaram village	No
2		Sharajpet	Tangutoor	11KV	Bhongir	03.00	05.00	02.00	E/L	11KV Insulator failed	No
3		B Chandupatla	Bheemla thanda	11KV	Suryapet	06.00	08.25	02.25	E/L	11KV Pin insulator failed	No
4		Chinthapally	Vinjumoor	11KV	Devarakonda	04.00	07.00	03.00	E/L	11KV Insulator failed	No
5		Marriguda	Thamadapally	11KV	Devarakonda	12.00	15.20	03.20	E/L	11KV Jumper Cut	No
6		Chandur	Tummalapally	11KV	Nalgonda	8:00	9:40	1:40	E/L	11 KV Disc failed	No
1	MDK	Ch. Shankampet	Kamaram	11KV	Medak	5:00	8:00	3:00		Insulator failed	No
2		Thogita	Aurangabad	11KV	Medak	08.30	11.30	03.00		Insulator failed	No
1	RR S	Vanasthalipuram	NGOS	11KV	Champapet	1:00	2:10	1:10	EL/OL BD	No visible fault	No
2		CBIT	Gandipet	11KV	Rajendranagar	07.13	08.13	01.00		Tree Branches fallen on the 11 KV Line	No
1	RR N	Bommarajpet	Ponnal	11KV	Medchal	16:05	17:30	1:25		11KV Pin Insulator Failed at Keshavaram cut Point	No
2		Chandanagar	Chandanagar	11KV	Gachibowli	17:25	18:25	1:00		11KV Line Snapped at Nagarjuna Grammer School	No
3		Guntur Vikas	KendriyaVihar	11KV	Kukatpally	17:37	19:00	1:23		11kv line AB Cable Endkit failure at Mayurinagar	No
4		Jeedimetla-II	SRC Naik Nagar	11KV	Kukatpally	14:14	15:20	1:06		Tree Branches fallen the 11kv line at SRC Naik Nagar	No
5		Jeedimetla-II	SRC Naik Nagar	11KV	Kukatpally	21.10	22.55	01.45		11kv line Pin Insulator failure at janpriya Apt , SRC Naik nagar	No
6		DPPally	Gagillapur	11KV	Kukatpally	00.00	01.10	01.10		11kv line Pin Insulator failure at Sundara Chaithanya Ashram at Gagillpur	No
7		Jeedimetla-I	C S Wires	11KV	Kukatpally	07.20	08.30	01.10		11kv line AB Cable failure at Azanda Company at phasa-I	No
8		KPHB	Bhygaynagar	11KV	Kukatpally	19:20	20:08	0:48		11kv line UG Cable failure at JEEDimetla Buse Depo, Bhagynagar	No
1	RR E	Cherlapally-II	Jannuram	11KV	Sainikpuri	3:39	4:09	0:30		11kv line AB Switch Spark at Ruchi Oil Company Phase-IV (Foc Veera Swamy)	No
2		Thatiannaram	Thatiannaram	11KV	Saroornagar	00.48	05.35	04.47	EL	DTR Open at Red Mate Company	No
3		Hayathnagar	Kalvanche	11KV	Saroornagar	01.10	02.10	01.00	EL/OL	3Nos 11KV Line cut at Shanthinagar	No
4		Maruthi nagar	Yadav nagar	11KV	Saroornagar	17.30	19.00	01.30	OL	11KV Insulator failed	No
5		Narapally	Narapally	11KV	Habsiguda	01.05	02.45	01.40		11KV Insulator failed	No
6		Keesara	Cheeryal	11KV	Habsiguda	03.45	09.40	05.55		11KV Jumper cut at Kundanpally	No
7		Keesara	Ankireddypally	11KV	Habsiguda	01.30	05.40	04.10		11KV Pin insulator Failed at Ankireddypally Chowrasta	No
8		Peerzathiguda	Peerzathiguda	11KV	Habsiguda	19.00	20.30	01.30		11KV Pin Insulator failed near Peerzathiguda Gutta	No
9		Taramathipet	Industrial	11KV	Saroornagar	21.35	23.40	02.05	EL	11KV Insulator failed	No
10		RFC	Umarkhanguda	11KV	Saroornagar	23:10	2:50	2:40	EL/OL	11KV Line AB switch opened	No
1	HYD N	Erramanzil	Durga Nagar	11KV	Erragadda	00.54	03.47	02.53	EL,OL	11KV UG Cable damaged at Somajiguda	No
1	HYD S	Gunj	Hanuman Temple	11KV	Asmangadh	18.46	20.02	01.16	All Indication	3Way RMU fault at Hanuman Temple	No
2		Yakuthpura	Bada Bazar	11KV	Asmangadh	23:46	1:18	1:32	All Indication	HT Jumper cut at Bada Bazar	No

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		2		2		2			
5	RR(N)	77	404		8		8		8			
6	RR(E)	38	347		10		10		10			
7	Hyd	184	993	1	3	1	3	1	3			
	<b>Total</b>	<b>497</b>	<b>2892</b>	<b>1</b>	<b>23</b>	<b>1</b>	<b>23</b>	<b>1</b>	<b>23</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	108	969	3	6	3	6	3	6			
2	NLG	150	948		6		6		6			
3	MDK	87	828	2	2	2	2	2	2			
4	RR(S)	29	322									
5	RR(N)	8	48									
6	RR(E)	18	80									
	<b>Total</b>	<b>400</b>	<b>3195</b>	<b>5</b>	<b>14</b>	<b>5</b>	<b>14</b>	<b>5</b>	<b>14</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>897</b>	<b>6087</b>	<b>6</b>	<b>37</b>	<b>6</b>	<b>37</b>	<b>6</b>	<b>37</b>	<b>0</b>	<b>0</b>	