

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		4		4		4			
5	RR(N)	77	404	2	5	2	5	2	5			
6	RR(E)	38	347		6		6		6			
7	Hyd	184	993	1	36	1	36	1	36			
	<b>Total</b>	<b>497</b>	<b>2892</b>	<b>3</b>	<b>51</b>	<b>3</b>	<b>51</b>	<b>3</b>	<b>51</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	108	969	3	5	3	5	3	5			
2	NLG	150	948	1	22	1	22	1	22			
3	MDK	87	828		6		6		6			
4	RR(S)	29	322									
5	RR(N)	8	48									
6	RR(E)	18	80									
	<b>Total</b>	<b>400</b>	<b>3195</b>	<b>4</b>	<b>33</b>	<b>4</b>	<b>33</b>	<b>4</b>	<b>33</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>897</b>	<b>6087</b>	<b>7</b>	<b>84</b>	<b>7</b>	<b>84</b>	<b>7</b>	<b>84</b>	<b>0</b>	<b>0</b>	

## TSSPDCL - LMRC / Corporate office

Date: 27.05.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Makthal	33KV	Krishna	01.55	09.55	08.00	E/L	33KV insulator damaged near Chandapur village	Makthal	-
2		Mahabubnagar	Kodangal	33KV	Kothur	18.45	19.45	01.00	E/L	No visibule fault , Alternate Supply Arranged at 132KV SS Tandoor at 19:45Hrs to Supply Stud ok	Kodangal	Alternate Supply Arranged at 132KV SS Tandoor at 19:45Hrs to Supply Stud ok
3		Jadcherla	Kalwakurthy	33KV	Sir Singandla	11.37	14.35	02.58	E/L	Pin Banding Replacement near Kamalpur Gate and Tree Cutting Work	Kalwakurthy	-
1	NLG	Ramapuram	Dondapadu	33KV	Huzurnagar	03.00	07.00	04.00	E/L	33Kv Insulator Failure near Dondapadu	Dondapadu	-
1	RR N	Shapurnagar	Shapurnagar	33KV	Kukatpally	12.15	15.10	02.55	BD	33kv Jumper cut at shapur	Shapurnagar	-
2		Madhapur	Gachibowli Interning Line	33KV	Gachibowli	10.25	11.52	01.27	BD	Flexi fallen on 33kv Line at Sothindia Shoppingmall Gachibowli	Gachibowli Interning Line	-
1	HYD N	132KV J' Hills	Road No. 13	33KV	Kalyan Ngr	01.05	02.40	01.35	OL	Cable Puncture	Road No. 13	Loads transferred onto 132KV J' Hills - Road No.13(A) Cable

## TSSPDCL - LMRC / Corporate office

Date: 27.05.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Nawabpet	Gurkunta	11KV	Mahabubnagar	05.20	10.00	04.40		11KV Conductor cut at Gurkunta (Vi)	-
2		Veldanda	Veldanda Rural	11KV	Jadcherla	10.00	12.00	02.00		11 kv wire cut near pothepally road	-
3		LATTUPALLY	MITTATHANDA	11KV	Nagarkurnool	00.00	15.00	15.00		POLES DAMAGED HVDS WORK	-
4		ITHOLE	ITHOLE	11KV	Nagarkurnool	06.30	12.00	05.30		2 POLES CONDUCTOR SNAPPED	-
5		HAZIPUR	CHENARAM	11KV	Nagarkurnool	12.00	15.00	03.00		11 KV WIRE CUT NEAR CHENARAM VLG	-
1	NLG	Kattangur	Kattangur Town	11KV	Suryapet	00.00	11.00	11.00	E/L	11Kv Pole Damage	-
2		Mukundapuram	Mamilla Madava	11KV	Suryapet	06.20	08.10	01.50	E/L	11Kv Disk Failed	-
3		Thatipamula	Thatipamula	11KV	Suryapet	11.30	13.00	01.30	E/L	11Kv Jumper cut	-
4		Penphad	Annaram	11KV	Suryapet	04.45	07.00	02.15	E/L	Tree branch fallen on the line	-
5		Thungathuthy	Ganugubanda	11KV	Suryapet	08.40	12.00	03.20	E/L	11Kv Jumper cut	-
6		Kodur	Kommala	11KV	Suryapet	09.10	13.50	04.40	E/L	Tree branch fallen on the line	-
7		Sirikonda	Sirikonda	11KV	Huzurnagar	11.00	14.30	03.30	E/L	11Kv Pole Damaged near Sirikonda (V)	-
8		Sirikonda	Ravipahad	11KV	Huzurnagar	10.30	13.30	03.00	E/L	11Kv Pole Damaged near Ravipahad (V)	-
9		Keetavarigudem	Kothagudem	11KV	Huzurnagar	02.30	05.30	03.00	O/L	11KV line Snapped near Kothagudem (V)	-
10		Keetavarigudem	Velidanda	11KV	Huzurnagar	05.20	08.40	03.20	E/L	11KV line Snapped near Velidanda (V)	-
11		Janpahad	Sunypahad	11KV	Huzurnagar	03.00	06.00	03.00	E/L	11Kv Pole Damaged near Sunypahad (V)	-
12		Chinthapally	Naraslapally	11KV	Devarakonda	00.00	00.00	00.00	E/L	11kv jumper cut	-
13		Gurrampode	Chamaild	11KV	Devarakonda	00.00	00.00	00.00	E/L	11kv insulator failure	-
14		Pallerla	Pallerla	11KV	Bhongir	05.00	11.00	06.00	E/L	11KV Poles Damaged	-
15		Pallerla	siddapur	11KV	Bhongir	13.00	17.00	04.00	E/L	11KV Poles Damaged	-
16		Peddathanda	PALLEPHAD	11KV	Bhongir	12.20	15.50	03.30	E/L	11Kv Jumper snapped at Pallephad	-
17		Chada	Kondapur	11KV	Bhongir	07.00	09.45	02.45	E/L	11KV Diskfailed & Insulator failed	-
18		Chamapur	Singaram	11KV	Bhongir	02.00	05.00	03.00	E/L	11KV Poles Damaged	-
19		Chamapur	Chamapur	11KV	Bhongir	23.00	02.00	03.00	E/L	11KV Diskfailed at Chamapur	-
20		M R Gudem	Gangasanipally	11KV	Bhongir	07.00	12.00	05.00	E/L	11KV Line snapped	-
21		Yadagirigutta	Wangapally	11KV	Bhongir	13.00	17.00	04.00	E/L	11KV Poles Damaged	-
22		Nandanam	Nagireddypally	11KV	Bhongir	23.00	02.00	03.00	E/L	Tree Branches Fallen On Line	-
1	MDK	Isnapur	IDA-I	11KV	Sangareddy	01.35	07.45	06.10		B/D Due to Jumper cut	-
2		Patancheru	MIA-I	11KV	Sangareddy	02.50	05.20	02.30		B/D Due to Conductor snapped	-
3		Patancheru	MIA-II	11KV	Sangareddy	03.00	03.40	00.40		B/D Due to Jumper cut	-
4		Isnapur	Muthangi-Agl	11KV	Sangareddy	09.04	12.30	03.26		B/D Due to Conductor snapped	-
5		Shalipet	Chennaipally	11KV	Medak	09.35	11.00	01.25		B/D Due to Conductor snapped	-
6		Gavvalapally	S. Kondapur	11KV	Medak	08.30	12.20	03.50		B/D Due to tree branch fallen on the line	-
1	RR S	Ibrahimbagh	Military-I	11KV	RJNR	03.00	04.17	01.17	B/D	T/F Failed at Ibrahimbagh	-
2		Kokapet	Kokapet	11KV	RJNR	03.30	05.05	01.35	B/D	No visible fault Due to rain	-
3		CBIT	Kokapet	11KV	RJNR	03.18	04.40	01.22	B/D	No visible fault Due to rain	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
4		Puppalaguda	Narsing	11KV	RJNR	03.40	06.00	02.20	B/D	Construction Sick fallen on 11KV Line near Darga	-
1	RR N	Gachibowli	Kothaguda	11KV	Gachibowli	03.40	06.20	02.40	BD	Tree Branches Fallen On The 11KV Line At Maseed banda And 11KV Insulator Failed Near Western Apartments.	-
2		L&T	PJR Nagar	11KV	Gachibowli	07.27	09.08	01.41	BD	AB Cable Failed Near L&T Park.	-
3		SEZ	Siddique Nagar	11KV	Gachibowli	02.58	04.05	01.07	BD	Flexi Fallen On The 11KV Line At Siddique Nagar.	-
4		Kothaguda	Hafeezpet	11KV	Gachibowli	03.35	04.55	01.20	BD	11KV Pin Insulator Failed At Raghavendra Colony.	-
5		Gachibowli	Mezzequity	11KV	Gachibowli	15.46	17.30	01.44	BD	Due To Rain And Heavy Wind. No Visible Fault.	-
1		RR E	RGK	RGK	11KV	SKP	19.05	19.50	00.45		Lizard fallen on 11Kv line at Yellammagudi Kowkooor (LM Rajender)
2	Anandbagh		Shivapuri	11KV	SKP	02.32	03.05	00.33		11Kv Disk failed at East Anandbagh (AE/OP)	-
3	Yapral		Kowkooor	11KV	SKP	03.10	04.00	00.50		11Kv Disk failed at Registration Colony (AE/OP/Yapral)	-
4	Cherlapally-I		EC Computer	11KV	SKP	00.15	04.00	03.45		11Kv Insulator failed at Kela Company (AECherlapally)	-
5	NGRI		Habssiguda	11KV	HBG	02.36	04.00	01.24		11KV Disc failed at Street No.4 and Pin Insulator failed at Street No.7 in Habsiguda	-
6	MANGALPALLY		KONGARAKALAN(AGL)	11KV	SAROORNAGAR	02.40	09.10	06.30	E/L	11KV LINE SNAPED AT SAHEBGUDA	-
1	HYD N	Road No.13	Sri Ram Nagar	11KV	X	01.40	03.15	01.35	EL,OL	Tree branches fallen on lines at Sri Ram Nagar	-----
2		Zamistanpur	MCH Park	11KV	V	02.30	04.30	02.00	EL,OL	AB Cable fault at Waker Town	-----
3		MLA Colony	Cancer Hospital	11KV	X	02.28	03.30	01.02	All Indication	Tree branches fallen on lines at Road No.10	-----
4		Maitrivanam	Anand Bagh	11KV	IV	02.25	03.56	01.31	EL,OL-Rph	Pin Insulator flash over at Satyam Theater	-----
5		Toli Chowki	Hanuman Temple	11KV	X	02.38	05.32	02.54	EL,OL-Y&Bph	Yphase Jumper cut at Water Works	-----
6		Yousufguda	Venkatagiri	11KV	X	03.20	06.10	02.50	EL	No Visible Fault	Arranged B/F on 11KV Venkatagiri fdr (70% feeder charged)
7		Yousufguda	Borabanda	11KV	IV	03.20	04.30	01.10	EL	No Visible Fault	-----
8		Prashanth Nagar	Colgate	11KV	VI	11.30	13.00	01.30	OL-R&Bph	Jumper cut at Prashanth Nagar Main Road	-----
9		Prasasan Nagar	Journalist Colony	11KV	X	17.38	19.28	01.50	EL,OL	Cable fault at Nandagiri Hills	-----

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
10		Prasasan Nagar	Nandagiri Hills	11KV	X	17.38	20.15	02.37	EL,OL	UG Cable fault	Arranged B/F on 11KV Journalist Clny fdr
11		Nehru Nagar	Rezimental Bazar	11KV	V	20.02	21.48	01.46	OL-Rph	Cable Jumper Cut at Rezimental Bazar	-----
12		Lalaguda	St.Anns	11KV	V	23.35	01.25	01.50	EL	No Visible Fault	-----
1		Aliyabad	Satherbagh	11KV	III	03.35	04.40	01.05	OL	No Visible Fault	-----
2		Attapur	N.M.Guda UG	11KV	III	11.05	12.30	01.25	EL,OL-Bph	Snapped HT Conductor at Golconda Functional Hall	-----
3	HYD S	Yakuthpura	Somanath Temple	11KV	VIII	14.42	17.08	02.26	EL,OL-Rph	Cable fault Opp. SS	At 16.15 hrs Added partial loads on 11KV Saleema Kathoon fdr At 17.08 hrs Arranged Partrial loads on B/f on 11KV Bhavani Nagar
4		Karwan	Jiyaguda OH	11KV	IX	23.10	00.15	01.05	EL,OL-Rph	DTR fault at Royal Function Hall	-----
5		Santosh Nagar	Bhavani Nagar	11KV	VIII	22.44	00.27	01.43	EL,OL-Rph	No Visible Fault	-----
6		Asmangadh	Gowtham Nagar	11KV	VIII	23.45	00.50	01.05	EL,OL-Rph	No Visible Fault	-----
7		Kanchan Bagh	Kanchan Bagh	11KV	VIII	23.44	01.00	01.16	EL,OL-Rph	Conductor snaped at Magnetion School	-----
8		Malakpet	Municipal Colony	11KV	VIII	23.35	01.05	01.30	EL,OL-Rph	Kite stick fault at Pochamma Temple	-----
9		Aliyabad	Police Quarters	11KV	III	22.45	01.38	02.53	All Indication	Tree branches fallen on lines at Guduma Satti	-----
10		Miralam	Mustafa Nagar	11KV	III	23.35	01.35	02.00	EL,OL-Bph	Insulator flash over at Lakdi Mission	-----
1		Nampally	Red Hills	11KV	VII	02.40	04.18	01.38	EL	Faulty loads of 11KV FAPCCI feeder	-----
2		Lumbini Park	A.I.R	11KV	I	02.43	05.12	02.29	All Indication	Tree branches fallen on lines at Commissioner Office	-----
3		Bathkammakunta	Ayyappa Temple	11KV	II	02.40	13.00	10.20	OL-Rph	Pin Insulator flash over at Sri Sai Encla Apts	-----
4		Asif Nagar	Padmanaba Nagar	11KV	VII	04.10	05.25	01.15	EL,OL-R&Bph	-----	Arranged B/F on 11KV Saber Nagar feeder
5		S.D Hospital	Ahmed Nagar OH	11KV	VII	02.40	04.26	01.46	EL	Pin Insulator flash over at Military Wall	-----
6		Asif Nagar	Toli Chowki	11KV	VII	04.20	05.30	01.10	EL,OL-Bph	Cable fault at Janaki Nagar	-----
7		Toli Chowki	Para Mount Colony	11KV	VII	04.50	06.15	01.25	EL,OL-Bph	DTR fault at Darul Colony	-----
8	HYD C	Z.P.Office	H.P.Sabha	11KV	I	22.21	00.22	02.01	EL,OL-Rph	Tree branches fallen on lines	-----
9		S.D Hospital	Ahmed Nagar Cbl	11KV	VII	22.47	23.50	01.03	EL	Pin Insulator flash over at Osman DTR	-----
10		Vittalwadi	Commissioner Office	11KV	I	23.05	00.58	01.53	All Indication	No Visible Fault	-----

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
11		Jawahar Nagar	Ashok Nagar	11KV	I	23.25	01.25	02.00	EL,OL-Bph	Tree branches fallen on lines at Ashok Nagar	-----
12		Vittalwadi	Taj Mahal	11KV	I	22.50	00.58	02.08	All Indication	Tree branches fallen on lines	Arranged B/F on 11KV Hyderguda fdr
13		Jawahar Nagar	Anjaiah Bhavan	11KV	I	23.45	02.20	02.35	EL	Tree branches fallen on lines at Labour Office	-----
14		Z.P.Office	Seven Temple	11KV	I	23.38	02.05	02.27	EL,OL-Rph	Tree branches fallen on lines	-----