

## TSSPDCL - LMRC / Corporate office

Date: 14.10.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Kowdipally	venkatraopet	33KV	Medak	14.10	15.40	01.30		B/D Due to Pin Insulator Failure and Jumper Cut	Kowdipally	-
2		Kowdipally	ch.Ghanpur	33KV	Medak	19.55	24.00	04.05		Under Breakdown	Kowdipally	-
3		Kowdipally	Amsanpally	33KV	Medak	10.00	14.20	04.20		B/D Due to Pin Insulator Failure	Kowdipally	-
4		Kowdipally	Bujarampet	33KV	Medak	20.20	24.00	03.40		Under Breakdown	Kowdipally	-
5		Narsapur	Reddypally	33KV	Medak	18.10	21.45	03.35		B/D Due to Insulator Faliure	Narsapur	-
6		Chegunta	DECCAN PAPER MILL	33KV	Toopran	17.40	19.40	02.00		B/D Due to tree branches fallen on the line	Chegunta	
7		Manoharabad	shivampet	33KV	Toopran	18.20	19.20	01.00		B/D Due to Jumper Cut	Manoharabad	
8		Gajwel	Shivam smelters	33KV	Toopran	19.30				B/D Due to Continuo	Gajwel	
9		Gajwel	B B Pur	33KV	Toopran	19.50	21.55	02.05		B/D Due to Insulator Faliure	Gajwel	-
10		Sadasivpet	Jogipet	33KV	Sangareddy	16.55	18.05	01.10		B/D Due to Conductor Snapped	Sadasivpet	-
11		Kandi	Sangareddy - II	33KV	Sangareddy	16.05	20.15	04.10		B/D Due to Jumper Cut Due to Heavy Rain	Kandi	-
12		Kandi	HFC-II	33KV	Sangareddy	16.05	20.10	04.05		B/D Due to Jumper Cut Due to Heavy Rain	Kandi	-

## TSSPDCL - LMRC / Corporate office

Date: 14.10.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Peddakadmoor	Peddakadmoor	11KV	Mahabubnagar	07.15	09.45	02.30		11KV Disk failure at Yellampally (vi)	-
2		Narva	Undecode	11KV	Mahabubnagar	04.30	11.00	06.30		11KV Conductor cut at Undecode (Vi)	-
3		Narva	Raicode	11KV	Mahabubnagar	08.00	14.15	06.15		11KV Conductor cut Near Raicode (Vi)	-
4		Gudeballore	Kothapally	11KV	Mahabubnagar	08.30	10.00	01.30		11KV Insulator Damage near Kothapally (V).	-
1	NLG	Biravunibanda	Biravunibanda	11KV	Nalgonda	06.00	08.00	02.00	EL	Insulator failed and jumper Cutting	-
2		SV College	Kasarabadha	11KV	Suryapet	13.50	17.00	03.10	EL	Jumper cut	-
3		Bibinagar	Sakethindia	11KV	Bhongir	10.30	12.45	02.15	EL	11Kv Linesnapped near Mukdumapally	-
4		Choutuppal	Tangedipally	11KV	Bhongir	16.45	18.00	01.15	EL	11KV Jumper snapped Golleden forest	-
5		Choutuppal	R.R.Metal	11KV	Bhongir	12.30	16.30	04.00	EL	Tree fallen On Line	-
1	MDK	Rajgopalpeta	Rajgopalpeta	11KV	Siddipet	08.20	13.15	04.55		B/D Due to Jumper Cut	-
2		Chellpaur	Chellpaur	11KV	Siddipet	06.00	10.30	04.30		B/D Due to location at near School	-
3		Isnapur	Kollur	11KV	Sangareddy	03.05	08.30	05.25		B/D due to overload on EL OL	-
4		Isnapur	Kyasaram	11KV	Sangareddy	09.20	10.20	01.00		B/D due to conductor snapped at Bread Company	-
5		Isnapur	Widia	11KV	Sangareddy	13.40	14.42	01.02		B/D due to No fault found jumper open at Pocharam side	-
6		EPIP-I	Chaitanya	11KV	Sangareddy	13.10	14.55	01.45		B/D due to conductor snapped at Satya Deva Company	-
1	RR S	Ibrahimbagh	Military-I	11KV	IBGH	17.49	19.11	01.22	B/D	No Visible Fault Due To heavy Rain	-
2		Puppalaguda	Manikonda	11KV	IBGH	03.05	04.30	01.25	B/D	11kv Disc Failed at Nageswara rao vencher	-
1	RR N	Shemshiguda	Thulashivanam	11KV	Kukatpally	05.30	07.30	02.00	OL	AB Cable Stethrough failure at PJR Colony	-
2		Madinaguda	JPN Nagar	11KV	Kukatpally	14.40	15.30	00.50	EL&OL	Due to Havy Rain	-
3		Jeedimetla-III	Fox Sagar	11KV	Jeedimetla	02.35	03.45	01.10	E&OL	AB Switch Opend Feedar OK, at Ram Reddy Nagar {Due To Havy Rain}	-
4		Jeedimetla-II	Phase-IV	11KV	Jeedimetla	15.08	16.45	01.37	E&OL	Line petroling No Visble Falt {Due to Havy Rain }	-
5		Jeedimetla-II	Phase-V	11KV	Jeedimetla	15.52	17.30	01.38	E&OL	Line petroling No Visble Falt {Due to Havy Rain }	-
6		DPPally	IDA-II	11KV	Jeedimetla	07.10	07.40	00.30	OI	Mass Company CTPT Failure at Pochampally	-
7		Jeedimetla-I	Phase-II	11KV	Jeedimetla	16.30	17.10	00.40	EI&OL	Due to Havy Rain	-
8		Jeedimetla-I	Balaji	11KV	Jeedimetla	15.10	16.50	01.40	EL	11kv line Jumpers Cut at Sub-station & {Due to Havy Rain}	-
9		Jeedimetla-I	Shapurnagar	11KV	Jeedimetla	15.10	16.40	01.30	EI&OL	Tree Branchesh fallon the 11kv line at Shapurnagar	-
10		HMT	Gandhi Nagar	11KV	Medchal	14.20	17.15	02.55	EL	Outgoing AB Switch Clamp binding in SS and 11KV Conductor Snapped at HMT company(Backfeeding arranged from 11KV Bhagathsingh Nagar)	-
11		Medchal	Navadurga	11KV	Medchal	17.15	18.17	01.02		Bird Fallen on 11KV Line at Dhruva college,Medchal	-
1	RR E	NGRI	Kalyanipuri	11KV	Habsiguda	13.28	14.09	00.41		Tree branches fallen on 11KV line at Jaheed Nagar	-
2		Moula-Ali	Jawahar Nagar	11KV	Sainikpuri	20.00	20.50	00.50		11Kv line Snapped at Jawahar Nagar (AE/OP)	-

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		2		2		2			
5	RR(N)	82	407		11		11		11			
6	RR(E)	38	360		2		2		2			
7	Hyd	186	1014									
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>15</b>	<b>0</b>	<b>15</b>	<b>0</b>	<b>15</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		4		4		4			
2	NLG	150	948		5		5		5			
3	MDK	87	828	12	6	12	6	12	6			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>12</b>	<b>15</b>	<b>12</b>	<b>15</b>	<b>12</b>	<b>15</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>12</b>	<b>30</b>	<b>12</b>	<b>30</b>	<b>12</b>	<b>30</b>	<b>0</b>	<b>0</b>	