

TSSPDCL - LMRC / Corporate office

Date: 12.09.17

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Suryapet	GT Giri	33KV	Suryapet	8:50	11:00	2:10	E/L	33Kv Line Conductor cut near 132/33KV SS Suryapet	GT Giri	No
1	MDK	Shenigaram	Chalimeda	33KV	Siddipet	10:55	13:30	2:35		B/D Due to tree branch fallen on the line	Chalimeda	No
2		Husnabad	Thotalpally	33KV	Siddipet	18.35	12.40	13.50		B/D Due to Pin Insulator failure	Thotalpally	No
3		Jogipet	G.Peddapur	33KV	Sangareddy	00.40	07.40	07.00		B/D Due to Conductor snapped	G.Peddapur	No

TSSPDCL - LMRC / Corporate office

Date: 12.09.17

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	SV College	G Hotel	11KV	Suryapet	5:10	7:55	2:45	E/L	11Kv Line Conductor cut	No
2		Keethavarigudem	Kothagudem	11KV	Huzurnagar	00.00	03.10	03.10	E/L	11Kv Jumper cut near Kothagudem (v)	No
3		Huzurnagar	Y.Singaram	11KV	Huzurnagar	14.20	16.10	01.50	E/L	11Kv Jumper cut near Y.Singaram (v)	No
4		Rajupeta	Rajupeta	11KV	Nalgonda	07.30	08.50	01.20	E/L	11 KV Jumper Cut	No
5		Narsingbatla	Industrial feeder	11KV	Nalgonda	09.30	12.20	02.50	E/L	11Kv Jumper cut and nsulator Fialure	No
6		Shivannaguda	Ramreddy pally	11KV	Devarakonda	8:00	11:00	3:00	E/L	11 KV Jumper Cut	No
1	MDK	Kadlur	Bardipur	11KV	Medak	7:00	10:30	3:30		B/D Due to Jumper Cut	No

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407									
6	RR(E)	38	360									
7	Hyd	186	1014									
	Total	504	2929	0	0	0	0	0	0	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948	1	6	1	6	1	6			
3	MDK	87	828	3	1	3	1	3	1			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	4	7	4	7	4	7	0	0	
	Grand Total	908	6149	4	7	4	7	4	7	0	0	