

TSSPDCL - LMRC / Corporate office

Date: 21.09.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Hanwada	33KV	Mahabubnagar	11.00	11.30	00.30		Due to Jumper Cut Y Phase Line Isolator to Line in Yard	Mahabubnagar	-
1	NLG	Kanagal	Pagidimarri	33KV	Nalgonda	05.00	08.30	03.30	E/L	Moment fault	Kanagal	-
2		Suryapet	Gumpula thirumala giri	33KV	Suryapet	08.30	11.20	02.50	E/L	Jumper cut	Suryapet	-

TSSPDCL - LMRC / Corporate office

Date: 21.09.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Indugula	Mallapurajugudem	11KV	Nalgonda	06.00	08.30	02.30	E/L	11KV insulator failed at SS-46	-
2		Pole centre	Budharam	11KV	Nalgonda	11.45	16.35	04.50	E/L	11KV insulator failed	-
3		Mattampally	Pedaveedu	11KV	Huzurnagar	07.00	09.00	02.00	E/L	11kv Disk failure near Pedaveedu village	-
1	MDK	Thornal	Appanapally	11KV	Siddipet	01.00	07.20	06.20		B/D Due to Conductor snapped	-
2		Dharamajipet	Pothareddypet	11KV	Siddipet	08.44	09.53	01.09		B/D Due to tree branch fallen on the line	-
1	RR N	K P HB	Jalavyu vihar	11KV	Kukatpally	04.28	06.10	01.42	BD	A cloth fallen on the 11kv Line at Shiva paravathi theara	-
2		Shemshiguda	N T R Nagar	11KV	Kukatpally	18.10	19.30	01.20	BD	A Kite Fallen on the 11kv Line At Nt r nagar	-
3		BahaduraPally	Indiramma Colony	11KV	Jeedimetla	07.18	08.20	01.02	BD	11kv Jumper Cut Touched On Channel At Indiramma colony	-
4		Bommarajpet	Ponnal	11KV	Medchal	09.40	11.00	01.20	BD	11KV Line Cut and replaced at Pochamma Temple, Ponnal	-
1	RR E	FRUITMARKET	SHIVALAYAM	11KV	SAROORNAGAR	02.54	04.50	01.56	OL	11KV LINE CUT AT CAITAYANAPURI	-
1	HYD N	Gymkhana	Pared Ground	11KV	Sec-Bad	07.58	09.15	01.17	EL,OL-Rph	Tree branches fallen on lines at Pared Ground	-
2		Patigadda	Budha Bhavan	11KV	Sec-Bad	11.35	13.09	01.34	EL,OL-Rph	HT Line snapped	Arranged B/F on 11KV H.S.P.H. fdr

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		4		4		4			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		2		2		2			
	Total	504	2929	0	7	0	7	0	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1		1		1				
2	NLG	150	948	2	3	2	3	2	3			
3	MDK	87	828		2		2		2			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	3	5	3	5	3	5	0	0	
	Grand Total	908	6149	3	12	3	12	3	12	0	0	