

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		8		8		8			
7	RR(E)	168	403		5		5		5			
8	Hyd	194	1044		11		11		11			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>25</b>	<b>0</b>	<b>25</b>	<b>0</b>	<b>25</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	2	1	2	1	2			
2	NLG	144	988		10		10		10			
3	MDK	107	933	1	2	1	2	1	2			
4	SDPT				21		21		21			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>35</b>	<b>2</b>	<b>35</b>	<b>2</b>	<b>35</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>60</b>	<b>2</b>	<b>60</b>	<b>2</b>	<b>60</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 04.08.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Sri Rangapur	Utharaspally	33KV	Shadnagar	10.00	10.20	00.20	E/L	Due to Disc failed and Chanel failed	Sri Rangapur	No
1	MDK	Sadasivpet	Manjeera	33KV	Sangareddy	19.20	20.15	00.55		BD Due to B PH JUMPER CUT	Sadasivpet	No

## TSSPDCL - LMRC / Corporate office

Date: 04.08.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Marikal	Kanmankalva	11KV	Jadcherla	04.40	07.35	02.55		B.D.11Kv jumper Cut Near Kanmankalva( Vi).	-
2		Tirumalapur	Dondlapally	11KV	Jadcherla	07.00	13.49	06.49		B.D.11Kv Jumper Cut Near Dondlapally Vi)	-
1	NLG	SV College	Loyala Agl	11KV	Suryapeta	16.00	18.15	02.15	E/L	Conductor snapped	-
2		Mukundapuram	Somaram	11KV	Huzurnagar	13.10	16.10	03.00	EL	Due to 11kv line cutted	-
3		Gaddipaly	Gaddipally	11KV	Huzurnagar	06.05	09.00	02.55	EL	Due to 11kv Insulator	-
4		Kandibanda	Gandi nagar thanda	11KV	Huzurnagar	11.02	12.25	01.23	EL	Due to 11kv line cutted	-
5		Bethavolu	Bethavolu	11KV	Huzurnagar	11.00	13.30	02.30	EL	Due to tree branch fall on 11Kv line	-
6		Ch.Annaram	Ch.Annaram	11KV	Nalgonda	10.30	13.50	03.20	EL	11KV Line cut	-
7		Arlagadda Gudem	N.R. Gudem	11KV	Nalgonda	12.00	14.20	02.20	EL	Tree Branch Fallen on the Line	-
8		Arlagadda Gudem	Mangalapally	11KV	Nalgonda	11.30	13.30	02.00	EL	11 KV Line Cut	-
9		Marrur	Gorinkalapally	11KV	Nalgonda	10.45	14.20	03.35	EL	Tree Branch Fallen on the Line and HT/LT Melting	-
10		Pamanagundla	Ismailpally	11KV	Nalgonda	11.40	14.52	03.12	EL	Tree Branch Fallen on the Line	-
1	MDK	Patancheru Town	Allwyn	11KV	Patancheru	11.10	13.35	02.25		BD Due to Insulator failure	-
2		Gummadidala	Agrobella	11KV	Patancheru	13.35	16.55	03.20		BD Due to Tree fallen on line	-
1	SDPT	Bejjanki	Kallepally	11KV	Husnabad	20.00	21.00	01.00		DTR problem	
2		Guggilla	Guggilla	11KV	Husnabad	15.30	17.55	02.25		BD	
3		Chityal	Thadoor	11KV	Husnabad	04.00	14.15	10.15		Conductor snapped	
4		Potharam	Mirzapoor	11KV	Husnabad	11.00	14.00	03.00		Conductor snapped	
5		Gandipally	Ramavaram	11KV	Husnabad	06.20	11.30	05.10		Insulator failure	
6		Gouravelly	Gudatipally	11KV	Husnabad	14.25	21.00	06.35		Insulator failure	
7		Husnabad	Pandilla	11KV	Husnabad	11.35	17.15	05.40		Insulator failure	
8		Ramchandrapur	Vinjalpally	11KV	Husnabad	06.20	08.20	02.00		DTR Work	
9		Dhoolmitta	Jalapally	11KV	Husnabad	10.20	13.40	03.20		DTR problem	
10		Rebarthy	Rebarthy	11KV	Husnabad	00.00	09.00	09.00		Tree fallen on line	
11		GAJWEL	11KV Jaligama AGL feeder	11KV	Gajwel	11.40	12.40	01.00		11KV Jumper out	
12		Thimmapur	11KV Baswapur Agl feeder	11KV	Gajwel	09.07	10.37	01.30		E/L	
13		Jagadevpur	11KV Industrial Feeder	11KV	Gajwel	10.20	12.12	01.52		11KV Pin Insulator fail	
14		SitaRampally	11KV Seetharampally Feeder	11KV	Gajwel	07.40	10.20	02.40		11KV Jumper out	
15		Thimmareddypally	11KV Lakudaram Agl Feeder	11KV	Gajwel	10.30	12.45	02.15		11KV Line cut	
16		Marpadaga	11KV Sirsanagandla Agl feeder	11KV	Gajwel	09.10	12.00	02.50		Tree branches fallen on the 11KV line	
17		Vantimamedi	11KV Chinna Thimmapur Agl feeder	11KV	Gajwel	08.26	11.06	02.40		11KV Pin Insulator fail	
18		KoKkonda	11KV Industrial Feeder	11KV	Gajwel	22.20	09.30	11.10		Tree branches fallen on the 11KV line	-
19		MULUGU	11kv Mulugu Town feeder	11KV	Gajwel	11.10	15.30	04.20		HT/LT SHORT CIRCUIT	-
20		MULUGU	11kv Mulugu Agln feeder	11KV	Gajwel	10.15	12.40	02.25		HT/LT SHORT CIRCUIT	-
21		MULUGU	11KV Nagireddypally Agl feeder	11KV	Gajwel	11.20	16.10	04.50		Stay Wire cut Due to EL	-
1	RR S	Nanakramguda	Manjeera	11KV	Gachibowli	01.38	03.30	01.52	BD	Lorry dashed, 1 T/F of 11kv line melted, near Thanda cicle	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	Nizampet	Nizampet	11KV	Kukatpally	03.40	06.00	02.20	BD	11kv line Jumper cut & PinInsulater failure at opp:Hanuman Temple	-
2		Mayurinagar	Ramnareshnagar Cable	11KV	Kukatpally	10.25	11.55	01.30	BD	T/F Brash patti Cut & Line AB Jumper cut at Ramalayam Temple	-
3		Jeedimetla-IV	Bhagyalaxmi	11KV	Jeedimetla	13.34	15.12	01.38	BD	Tree branchesh fallen the 11kv line at Biscuity Company,Subhashnagar	-
4		Subhash Nagar	Meenakshi	11KV	Medchal	02.50	03.20	00.30	BD	No Fault	-
5		HMT	Manikya Nagar	11KV	Medchal	08.30	09.10	00.40	BD	11KV Pin Insulator Failed at Chintal Market	-
6		GP Pally	Neighbourhood	11KV	Medchal	03.20	05.40	02.20	BD	11KV Pin Insulator Failed at Aparna opp	-
7		Kandlakoya	KV Reddy Nagar	11KV	Medchal	15.05	16.25	01.20	BD	11KV Pin Insulator failed at Kandlakoya	-
8		Thurkapally	Thurkapally	11KV	Medchal	19.30	20.45	01.15	BD	11KV Line cut and replaced at Cheruvukatta	-
1	RR E	Vasanthapuri	Ganesh Temple	11KV	Sainikpuri	14.55	16.10	01.15		11Kv jumper Cable failed at Prashanth Nagar (Artisan Beem Rao)	-
2		AS Rao Nagar	Gandhi nagar	11KV	Sainikpuri	19.26	20.06	00.40		11Kv Pin Insulator failed at MJ Colony Street No.5 (Artisan Ravinder)	-
3		Kushaiguda	Saibaba Temple	11KV	Sainikpuri	19.35	20.30	00.55		AB Switch Open at Dhanpal Reddy Venture (L.Insp Nageshwar Rao) due to 11Kv Pin Insulator failed & Immediately 80% feeder charged ok	-
4		Chakripuram	S V Nagar	11KV	Keesara	02.20	07.20	05.00		11KV Line cut at S V Nagar Road No.02	-
5		Chakripuram	Simhapuri Colony	11KV	Keesara	04.25	05.50	01.25		11KV Pin Insulator failed at Laxmi Nagar	-
1	HYD N	Bowenpally	Pipe Line Road	11KV	Bowenpally	01.15	02.35	01.20	EL	Disc Insulator flash over at Pipe Line Road	-
2		Addagutta	Shanthi Nikethan	11KV	Bowenpally	03.45	05.50	02.05	EL,OL-Rph	Pin Insulator flash over at Delhi Public School	-
3		Madhapur	Ven-En-Burg	11KV	Banjarahills	11.55	13.00	01.05	EL,OL-Bph	Cable fault at Madhapur PS	-
4		Addagutta	Shanthi Nikethan	11KV	Bowenpally	14.22	15.30	01.08	EL	Brass Patti cut & touching to Pole at Shanthi Niketan	-
1	HYD S	Gosha Mahal	Hindi Nagar	11KV	Begumbazar	04.20	05.30	01.10	EL	AB Cable End Kit failed at Sandhya Transport	-
2		Petlaburz	Shah Gunj	11KV	Charminar	07.40	09.00	01.20	EL,OL-Bph	Conductor snapped at Double feeding Point	-
3		Petlaburz	Chowk	11KV	Charminar	07.40	09.00	01.20	EL,OL-Bph	Conductor snapped at Double feeding Point	-
4		Panjasha	Panjasha	11KV	Charminar	07.54	09.39	01.45	All Indication	No Visible Fault	-
5		Vittalwadi	Gayatri Hotel	11KV	Begumbazar	11.00	12.30	01.30	EL	Cable fault	Arranged B/F on 11KV Ram Koti feeder
1	HYD C	A.S.R Raju Nagar	LIC Office	11KV	Mehdipatanam	11.10	12.20	01.10	OL	UG Cable fault at Habeeb Plaza	-
2		Toichowki	B.S.N.L	11KV	Mehdipatanam	19.40	20.45	01.05	EL,OL-Bph	AB Cable End Kit failed at I.A.S Colony	-