

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		3		3		3			
6	RR(N)	54	550	1	8	1	8	1	8			
7	RR(E)	168	403									
8	Hyd	194	1044	1	5	1	5	1	5			
	Total	606	3055	2	16	2	16	2	16	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	4	2	4	2	4			
2	NLG	144	988	1	15	1	15	1	15			
3	MDK	107	933	1	3	1	3	1	3			
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	24	4	24	4	24	0	0	
	Grand Total	1082	6468	6	40	6	40	6	40	0	0	

TSSPDCL - LMRC / Corporate office

Date: 05.08.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Gudeballore	33KV	Narayanapet	14.10	15.45	01.35	E/L&O/L	Tree Fallen on the Line Near at Chandapur Village	Makthal	No
2		Amangal	Polepally	33KV	Shadnagar	20.55	22.08	01.13	E/L	for Insulator Replacement at Jangareddypally	Amangal	No
1	NLG	Marriguda	Shivannagudam	33KV	Devarakonda	03.30	07.00	03.30		Tree Fallen the Line		-
1	MDK	R.C.Puram	NSL	33KV	Patancheru	16.55	18.45	01.50		BD due to Tree fallen on line		-
1	RR N	132KV Medchal	33KV Athiwelly	33KV	Medchal	17.01	17.55	00.54	BD	No Fault		-
1	HYD N	132KV Gunrock	Macha Bollaram	33KV	Nehru Ngr	23.45	01.00	01.15	EL	Smokes observed in 33KV R.M.U		Loads transferred onto 132KV Gunrock SS via 33KV Hakimpet SS

TSSPDCL - LMRC / Corporate office

Date: 05.08.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Donur	vaspula	11KV	Jadcherla	09.14	11.24	02.10		BD due to 11KV wire cut near Vallabrao pally.	-
2		Donur	Donur	11KV	Jadcherla	07.25	09.20	01.55		BD due to 11 KV insulater fail near at donur.	-
3		Rajapur	Chennavelly	11KV	Jadcherla	10.55	14.00	03.05		BD due to jumper cut near chennavelly.	-
4		Nawabpet	Gurukunta	11KV	Jadcherla	02.25	10.50	08.25		BD due to Phase to phase near gurukunta.	-
1	NLG	P.D.Pally	P.D.Pally	11KV	Nalgonda	13.40	16.30	02.50	E/L	11 KV Jumper cut	-
2		Thipparthi	Marrigudem	11KV	Nalgonda	14.25	16.35	02.10	E/L	Tree Branch Fallen on the Line	-
3		Narketpally	M.Yedavelly	11KV	Nalgonda	07.50	09.50	02.00	E/L	11 KV Insulator failed	-
4		Gattupal	Lachammagudem	11KV	Nalgonda	08.45	11.30	02.45	E/L	Tree Branch Fallen on the Line	-
5		Aitipamula	Gangadevigudem	11KV	Nalgonda	11.29	14.00	02.31	E/L	Tree Branch Fallen on the Line	-
6		CH.Annaram	Garlabavigudem	11KV	Nalgonda	13.00	16.00	03.00	E/L	11 KV line cut	-
7		Katangur	Kalimera	11KV	Nalgonda	02.10	03.10	01.00	E/L	11 KV Jumper cut	-
8		Pamanagundla	Yerrasanigudem	11KV	Nalgonda	06.00	08.25	02.25	E/L	Tree Branch Fallen on the Line	-
9		Damarcherla	Damarcherla	11KV	Miryalguda	09.00	09.47	00.47	E/L	11KV pin insulator failed	-
10		T Singaram	Mood thanda	11KV	Suryapet	05.00	07.15	02.15	E/L	Insulator failed	-
11		Tekumatla	Pillalamarri	11KV	Suryapet	06.52	08.50	01.58	E/L	Jumper cut	-
12		Kandibanda	N B Gudem	11KV	Huzurnagar	22.10	23.30	02.20	EL	11 KV JUMPER CUT	-
13		Akupamula	Akupamula	11KV	Huzurnagar	22.10	23.55	01.45	EL	11 KV Disk failed	-
14		Garidepally	Kalmalcheruvu	11KV	Huzurnagar	11.15	13.10	02.05	EL	11 KV JUMPER CUT	-
15		Kalmalcheruvu	Ganganagar	11KV	Huzurnagar	07.40	10.00	02.20	EL	11 KV LINE SNAPPED	-
1	MDK	Patancheru Town	MIA-I	11KV	Patancheru	16.15	18.50	02.35		BD due to Conductor snapped	-
2		Gaddapotharam -II	Khajipally Indl.	11KV	Patancheru	16.30	18.50	02.20		BD due to Insulator failed	-
3		Hathnoora	Town Ind	11KV	Jogipet	18.45	20.00	01.15		BD due to tree fallen on line	-
1	SDPT	Benjankki	Kallepally	11KV	Husnabad	17.30	23.30	06.00	B/D	Due Jumper cut	-
2		Gagillapur	Gagillapur agri	11KV	Husnabad	17.40	23.15	05.35	B/D	Insulator failed	-
1	RR S	JNTU	BS Nagar	11KV	Gachibowli	09.25	10.55	01.30	BD	11KV pin Insulator Failed and Cable End Kit Failed near plot no -697 at BS Nagar.	-
2		IJM	New 6th Phase	11KV	Gachibowli	17.14	18.35	01.21	BD	11KV Pin insulator failed near water tank at HIG - 194 & 195.	-
3		IIIT	IVRCL	11KV	Gachibowli	09.25	10.45	01.20	BD	11KV Line AB switch Jumper's cut at Villa's.	-
1	RR N	Subhash Nagar	Padma Nagar	11KV	Medchal	04.55	07.15	02.20	BD	25KVA T/F Brass Patti cut and replaced at Sai Residency	-
2		Subhash Nagar	Meenakshi	11KV	Medchal	16.20	17.15	00.55	BD	Line AB Switch opened at Meenakshi(11KV Line cut)	-
3		Subhash Nagar	Ramaraj Nagar	11KV	Medchal	13.55	14.28	00.33	BD	11KV Pin Insulator failed at Ramraj Nagar	-
4		K P H B	HyderNagar	11KV	Kukatpally	17.18	18.28	01.10	BD	Tree fallen On the 11kv line At vijathasupermarket	-
5		Madinaguda	Miyapur	11KV	Kukatpally	17.25	18.39	01.14	BD	11kv AB Cable Failure At miyapur	-
6		Mayurinagar	Ram nareshanagar	11KV	Kukatpally	17.00	18.00	01.00	BD	11kv Pin insulotor Failure At Mithra Hills	-
7		Kistapur	Kistapur	11KV	Medchal	00.40	02.10	01.30	BD	11KV Line & LT Line cut and repaled near SS	-
8		Kistapur	Ravalkole Out	11KV	Medchal	10.16	12.44	02.28	BD	33KV Disc failed at Pudur Road	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	Chinna Thokatta	Old Bowenpally	11KV	Bowenpally	16.22	17.26	01.04	EL	Disc Insulator flash over at Lucky Homes	-
2		Tirumalagiri	Mangapuram Colony	11KV	Bowenpally	16.50	19.10	02.20	EL,OL	Cable fault	Arranged B/F on 11KV Ayyappa Ngr fdr
1	HYD S	C.R.P.F.	Barkas	11KV	Charminar	18.05	19.29	01.24	All Indication	HT Jumper cut at C.R.P.F.	-
2		Laxmi Nagar	Laxmi Nagar	11KV	Asmangadh	18.06	19.38	01.32	All Indication	HT Jumper cut at B.S.N.L. Office	-
1	HYD C	S.D Hospital	Cha Cha Nehru Park	11KV	Mehdipatanam	21.40	23.15	01.35	EL,OL-Rph	Breaker Limb failed at SS	Arranged B/F on 11KV Khadi Bhandar fdr