

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		6		6		6			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		4		4		4			
	Total	606	3055	0	11	0	11	0	11	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988	1	12	1	12	1	12			
3	MDK	107	933	1	3	1	3	1	3			
4	SDPT				10		10		10			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	25	3	25	3	25	0	0	
	Grand Total	1082	6468	3	36	3	36	3	36	0	0	

TSSPDCL - LMRC / Corporate office

Date: 07.08.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Koukuntla	33kv	Narayanapet	15.30	16.00	00.30	E/L	Load Diverted From Koukuntla to Devarkadra	Koukuntla	-
1	NLG	Miryalguda	Avanthipuram	33kv	Miryalguda	09.30	11.30	02.00	E/L	33KV line melt and Jumper cut near sub-jail road	Avanthipuram	-
1	MDK	Pashamailaram	Manjeera	33kv	Sangareddy	06.48	08.30	01.42		BD Due Jumper Cut	Manjeera	-

TSSPDCL - LMRC / Corporate office

Date: 07.08.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Marrur	marrur	11kv	Nalgonda	12.00	16.00	04.00	E/L	11KV Line Cut	-
2		Nemmani	Merlakunta	11kv	Nalgonda	00.15	09.30	02.10	E/L	11KV Line Disc Failur	-
3		Mamidala	Aregudem	11kv	Nalgonda	06.15	10.25	04.10	E/L	11KV Line Jumper Cut	-
4		Thungathurthy	Banda Ramaram	11kv	Suryapet	11.50	13.50	02.00	E/L	11Kv Conductor snapped	-
5		G.T Giri	Thirumalagiri Agl	11kv	Suryapet	03.30	06.20	02.50	E/L	11Kv Conductor snapped	-
6		Akupamula	Akupamula	11kv	Huzurnagar	07.00	09.20	02.20	E/L	11Kv Conductor snapped	-
7		Kalmalcheruvu	Ganganagar	11kv	Huzurnagar	06.30	09.10	02.40	E/L	11Kv Conductor snapped	-
8		Gaddipally	Medaram	11kv	Huzurnagar	18.30	23.30	02.30	E/L	11KV Line Jumper Cut	-
9		Mukundapuram	Dacharam	11kv	Huzurnagar	05.00	08.30	03.30	E/L	11Kv Conductor snapped	-
10		Mukundapuram	Shunyapahad	11kv	Huzurnagar	12.30	15.15	02.45	E/L	11KV Line Jumper Cut	-
11		Mothkur	Anajipur	11kv	Bhongir	02.20	07.20	05.00	E/L	11kv Line Snapped Near Dacharam (V)	-
12		Choutuppal	Thangedipally	11kv	Choutuppal	04.00	11.00	07.00	EL/OL	11kv Pole Damaged & 11kv Line snapped near Thangedipally (V)	-
1	MDK	Bollaram - II	Town-I	11kv	Patancheru	13.55	17.30	03.35		BD taken for Tree fallen on line	-
2		Bollaram - I	Kythan	11kv	Patancheru	11.24	12.33	00.13		BD taken for Jumper cut	-
3		Patancheru Town	Shanthinagar	11kv	Patancheru	15.55	16.40	00.45		BD due to tree branche fallen line	-
1	SDPT	Thotapally	Gandinagar	11KV	Husnabad	08.15	11.35	03.20		Line cut	-
2		Akkannapet	Fakkirnayak thanda	11KV	Husnabad	00.00	17.40	17.40		Disk Failure	-
3		Gandipally	Ramavaram	11KV	Husnabad	12.15	16.20	04.05		Heavy gale and wind	-
4		Gandipally	Ramavaram	11KV	Husnabad	20.10	20.30	00.20		Disk Failure	-
5		Pandilla	Kuchanpally	11KV	Husnabad	07.10	07.50	00.40		Heavy gale and wind	-
6		Rebarthy	Gagillapur	11KV	Husnabad	00.00	07.30	07.30		Insulator failure	-
7		Komuravelli	Kistampet	11KV	Husnabad	00.00	07.30	07.30		Insulator failure	-
8		Inapur Agl	Inapur Agl	11KV	Husnabad	20.35	21.15	00.40		Heavy gale and wind	-
9		Guruvannapet	Pochanpally	11KV	Husnabad	00.00	07.40	07.40		Heavy gale and wind (3Ph)	-
10		Mustyala	Cherial town	11KV	Husnabad	00.00	10.20	10.20		Line cut	-
1	RR N	UMCC	Mahadevpuram	11kv	Medchal	02.00	02.35	00.35		11KV Jumper cut and replaced at Mahadevpuram	-
2		IDA Hanuman	Medchal	11kv	Medchal	16.10	17.40	01.30		2Nos 11KV Pin Insulator Failed at Ravalkole X Roads	-
3		Checkpost	Medchal	11kv	Medchal	18.12	19.25	01.13		11KV Pin Insulator failed at Bahubali Company	-
4		Mayurinagar	K T R colony	11kv	Kukatpally	18.00	19.05	01.05		Due To rain	-
5		Jeedimetla-I	Maheshawari	11kv	Jeedimetla	16.05	17.30	01.25		11kv Jkumper Cut near Jain polymer	-
6		Jeedimetla-I	J E T E L:	11kv	Jeedimetla	18.20	19.30	01.10		11kv Jumper Cut In Sub Station	-
1	RR E	Vayupuri	JK Colony	11kv	Sainikpuri	20.50	21.30	00.40		11Kv Pin Insulator failed & replacement at Sai Kuteer Apport. Kakathiya Nagar (LM Narsimha)	-
1	HYD C	Bathkammakunta	Saibaba Temple	11kv	Azamabad	00.26	03.18	02.52	EL,OL-Bph	Pin Insulator flash over at Royal Apartment	Partial charged at 00:50Hrs & remaining loads added on 11KV C.E.Colony fdr
1	HYD N	Pragatools	Eshwar Vimal	11kv	Bowenpally	05.50	07.28	01.38	EL,OL-R&Bph	Tree branches fallen on lines at Gandhi Nagar	-----
2		Patigadda	Ranigunj	11kv	Clock Tower	15.57	17.27	01.30	EL,OL	No Visible Fault	-----
3		Hakimpet	Bollaram P.S	11kv	Bowenpally	16.20	19.10	02.50	EL	Cable fault Bajarang Nagar Colony	-----