

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		6		6		6			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044	1	3	1	3	1	3			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>1</b>	<b>11</b>	<b>1</b>	<b>11</b>	<b>1</b>	<b>11</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1								
2	NLG	144	988		6	1	8	1	8			
3	MDK	107	933									
4	SDPT			1	5	1	6	1	6			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>11</b>	<b>2</b>	<b>14</b>	<b>2</b>	<b>14</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>3</b>	<b>22</b>	<b>3</b>	<b>25</b>	<b>3</b>	<b>25</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 12.08.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Nagarkurnool	lthole	33KV	Nagarkurnool	18.20	19.50	01.30	E/L	AB Switch Open & Close No Visible fault Supply Stude OK	Nagarkurnool	No
1	SDPT	Palamakula	Gonepally	33KV	Siddipet	01.34	07.10	05.36		Insulator fail	Palamakula	No
1	HYD N	132KV Balkampet	Allwyn (Lodha)	33KV	Allwyn	00.55	01.06	00.11	EL,OL	I/C Cable End Kit failed at 33KV Allwyn SS	132KV Balkampet	Loads transferred onto 132KV Erragadda SS

TSSPDCL - LMRC / Corporate office

Date: 12.08.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Athmakur	T Penpahad	11KV	Suryapeta	11.50	13.10	01.20	E/L	Insulator failed	-
2		Ponugodu	Kothagudem	11KV	Huzurnagar	09.20	11.11	01.51	EL	Due to jumper cutted	-
3		Palakaveedu	Sajjapuram	11KV	Huzurnagar	03.45	06.45	03.00	EL	Due to 11kv line Snapped	-
4		Kodad Town	Thammara	11KV	Huzurnagar	03.15	06.00	02.45	EL	Due to 11kv line cutted	-
5		Gundrampally	Aepoor	11KV	Nalgonda	15.20	16.20	01.00	EL	11KV Line Jumper Cut	-
6		Golankonda	Golankonda	11KV	Bhongiri	10.50	12.45	01.55	EL	11 KV Pin Insulator Failed Near Golankonda Village	-
1	SDPT	Guruvannapet	Guruvannapet	11KV	Husnabad	00.00	07.50	07.50		BD,Heavy gale&wind	-
2		Guruvannapet	Posanpally	11KV	Husnabad	00.00	07.05	07.05		BD,Heavy gale&wind	-
3		Guruvannapet	Tapaspally	11KV	Husnabad	00.00	06.10	06.10		BD,Heavy gale&wind	-
4		Rebarthy	Gagillapur Agl	11KV	Husnabad	01.10	06.55	05.45		BD,Conductor snapped	-
5		Thotapally	Devakkapally	11KV	Husnabad	08.50	10.20	01.30		BD,DTR failure	-
1	RR N	Mayurinagar	G R R R	11KV	Kukatpally	14.58	16.13	01.15	BD	T/F HG Fuse Cut & Touched the Erth Chanal at Ganesh Tower Venktrao Colony	-
2		Vikas	Apparna	11KV	Kukatpally	15.30	16.30	01.00	BD	Tree Branchesh Fallen the 11kv line at TSL Bachupally Road	-
3		Jeedimetla-II	Excil	11KV	Jeedimetla	15.13	17.53	02.40	BD	11kv line AB Cable Failure at Shakthi Cylender at Phase-III	-
4		Jeedimetla-II	Uthambiscuity	11KV	Jeedimetla	15.13	17.53	02.40	BD	11kv line AB Cable Failure at Shakthi Cylender at Phase-III { Dobule Feeder Single Pole }	-
5		Jeedimetla-I	Subhashnagar	11KV	Jeedimetla	14.55	15.55	01.00	BD	11kv line Jumper cut at SS Out side	-
6		Bowrampet	Junnrum	11KV	Jeedimetla	14.50	16.55	02.05	BD	11kv line Pin Insulater failure & Replecment at opp:Srichaithanya Collage	-
1	RR E	Yapral	Yapral	11KV	Sainikpuri	18.30	19.30	01.00		11Kv line cut at Mani Enclave (L.Insp Narshima)	-
2		Chengicherla	chengicherla	11KV	Keesara	15.30	16.30	01.00		Tree fallen on 11kv line near bus stop	-
1	HYD C	S.D Hospital	Ahmed Nagar OH	11KV	Mehdipatanam	19.05	22.15	03.10	All Indication	Cat fallen on DTR near S.D Hospital Quarters	Arranged B/F on 11KV Police Mess & 11KV Military feeders
2		Golconda	Shaikpet Water Works	11KV	Mehdipatanam	19.35	21.30	01.55	EL,OL-Rph	Cable fault at Jai Hind Nagar	-
3		Golconda	O.U Colony	11KV	Mehdipatanam	19.37	22.00	02.23	EL,OL-Rph	Cable fault at Cable Raising Point	Arranged B/F on 11KV Darga Cable feeder