

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	4	1	4	1	4			
7	RR(E)	168	403		5		5		5			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	1	10	1	10	1	10	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		19		19		19			
3	MDK	107	933		2		2		2			
4	SDPT				4		4		4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	25	0	25	0	25	0	0	
	Grand Total	1082	6468	1	35	1	35	1	35	0	0	

TSSPDCL - LMRC / Corporate office

Date: 13.08.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV LGM Pet	33KV LGM Pet	33kv	Medchal	05.52	07.46	01.54	BD	Tripped on EL Indication(No Fault)	33KV LGM Pet	-

TSSPDCL - LMRC / Corporate office

Date: 13.08.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Rajupeta	Kankanalapally	11kv	Nalgonda	05.10	12.30	07.20	E/L	Insulator failed	-
2		Rajupeta	Jangareddygudem	11kv	Nalgonda	05.10	12.00	06.50	E/L	Tree branches fallen on line	
3		NakkALAPALLY	Shapally	11kv	Nalgonda	07.45	11.15	03.30	E/L	11 Kv line cut	
4		Aitipamula	Gangadevigudem	11kv	Nalgonda	10.42	14.40	03.58	E/L	Jumper cut	
5		Gundrampally	Apoor	11kv	Nalgonda	08.20	09.30	01.10	E/L	Insulator failed	
6		Nakrekal	Maroor	11kv	Nalgonda	05.55	09.15	03.20	E/L	Heavy rain	
7		Nakrekal	Chandampally	11kv	Nalgonda	06.00	09.15	03.15	E/L	Tree branches fallen on line	
8		Nakrekal	Kadaparthi	11kv	Nalgonda	05.55	08.20	02.25	E/L	Insulator failed	
9		Eduloor	Eduloor	11kv	Nalgonda	09.00	11.30	02.30	E/L	Insulator failed	
10		Eduloor	Kurumarthy	11kv	Nalgonda	08.00	10.00	02.00	E/L	Jumper cut	
11		P.D.Pally	P.D.Pally	11kv	Nalgonda	06.00	09.10	03.10	E/L	Tree branches fallen on line	
12		P.D.Pally	Kanchanapally	11kv	Nalgonda	05.00	08.50	03.50	E/L	Jumper cut	
13		Koppole	Bheemaram	11kv	Nalgonda	08.30	11.30	03.00	E/L	Jumper cut	
14		Koppole	Koppole	11kv	Nalgonda	04.50	08.00	03.10	E/L	Heavy rain	
15		T Giri	Thatipamula	11kv	Suryapet	08.30	09.40	01.10	E/L	Insulator failed	
16		Gudimalkapuram	Thammaram	11kv	Huzurnagar	03.50	05.00	01.10	EL	Due to 11Kv jumper cutted	
17		Garidepally	Ponugodu	11kv	Huzurnagar	07.00	09.55	02.55	EL	Due to 11Kv Disk Failure	
18		Ambala	Parupally	11kv	Bhongir	10.30	13.15	02.45	EL	11 kv Insulator Failed	
19		Jublakpally	Kanumukula	11kv	Choutuppal	07.00	10.15	03.15	EL	11 kv Disc Failed	
1	MDK	Waddepally	Industrial	11kv	Jogipet	07.10	08.05	00.55		BD due to Tree fallen on line	-
2		Hathnoora	Town Ind	11kv	Jogipet	11.30	12.30	01.00		BD due to Jumper cut	-
1	SDPT	Komuravelly	Komuravelly Agl	11kv	Husnabad	14.10	17.00	02.50		Due to Insulator failed, the was same rectified	-
2		MULUGU SS	BAILAMPOOR	11kv	Gajwel	00.00	17.30	17.30		Due to DISC FAILURE	-
3		GURRALASOPA SS	WADDEPALLY	11kv	Gajwel	13.00	17.05	04.05		Due to DISC FAILURE	-
4		RAYAPOLE SS	THIMAKKAPALLY	11kv	Gajwel	20.40	22.00	01.20		Due to INSULATOR PROBLEM	-
1	RR N	Mayurinagar	G R R R	11kv	Kukatpally	15.16	16.40	01.24	BD	T/F Fuse of Insulater failure at Venkatraya Colony	-
2		132KV LGM Pet	33KV LGM Pet	11kv	Medchal	02.07	03.12	01.05	BD	Tripped on EL Indication(No Fault)	-
3		Ravalkole	IDA Ganapathi	11kv	Medchal	02.35	05.10	02.35	BD	Tree Branch fallen on the 11KV Line at Rajabollaram Thanda	-
4		Laxmapur	IDA Laxmapur	11kv	Medchal	08.00	08.20	00.20	BD	11KV Jumper Opened at Rice Mill, Anantharam	-
1	RR E	Moula-Ali	Moula-Ali	11kv	Sainikpuri	09.45	10.15	00.30		11Kv jumper cut at Moula-Ali Common (L.Insp Venkatershwarulu)	-
2		Anand Bagh	Bal ram Nagar	11kv	Sainikpuri	05.28	06.32	01.04		Cloth fallen on 11Kv line at East Anand Bagh near Majid (LM Murali)	-
3		Cherelapally-I	Phase-I	11kv	Sainikpuri	04.35	06.10	01.35		Ground Patrolling Done But No Fault Found (LM Kashi Ram)	-
4		Aushapur	Aushapur	11kv	Keesara	03.10	06.20	03.10		2Nos insulator fail at Rabbit form	-
5		Aushapur	Madharam	11kv	Keesara	04.20	06.00	01.40		11KV line twisted at Narayana reddy poltery form	-
1	HYD S	Devi Bagh	Shivalayam		Charminar	05.04	07.28	02.24	EL	Cable fault at Naya Goodwill Hotel	