

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		4		4		4			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	7	0	7	0	7	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	1	2	1	2	1			
2	NLG	144	988		7		7		7			
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	9	2	9	2	9	0	0	
	Grand Total	1082	6468	2	16	2	16	2	16	0	0	

TSSPDCL - LMRC / Corporate office

Date: 14.08.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Chinnamarror	Weepangandla	33KV	Wanaparthu	02.45	03.40	00.55	E/L	Conductor Snapped	Weepangandla	-
2		Kothur	PNG	33KV	Shadnagar	03.30	09.30	06.00	E/L	Cable lugs reconnecting at Kothur Railway Station	PNG	-

TSSPDCL - LMRC / Corporate office

Date: 14.08.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Udithyal	Macharam	11kv	Jadcherla	12.25	15.25	03.00		11KV Phase To Phase Near Macharam(Vi).	-
1	NLG	Eduloor	Kurumarthy	11kv	Nalgonda	06.20	10.30	04.10	E/L	11KV jumper cut	-
2		Baironibanda	T.K.Pahad	11kv	Nalgonda	01.15	07.35	06.20	E/L	11KV jumper cut	-
3		Nagaram	Machireddy pally	11kv	Suryapet	07.00	09.20	02.20	E/L	11Kv Insulator failed	-
4		Kistapuram	Thammaram	11kv	Huzurnagar	03.45	06.40	02.55	E/L	11kv jumper cut	-
5		Munagaia	Turkagudem-2	11kv	Huzurnagar	15.00	17.00	02.00	E/L	11Kv line snapped	-
6		Thogarrai	GudiBanda	11kv	Huzurnagar	11.00	14.00	03.00	E/L	11kv jumper cut	-
7		Pamukunta	Pamukunta	11kv	Bhongir	03.30	07.30	04.00	E/L	11kv Insulator Failed Near Pamukunta Village	-
1	SDPT	Chityal	Dommata	11kv	Husnabad	08.10	12.20	04.10		BD,Disc failure	-
1	RR N	Madinaguda	Miyapur	11kv	Kukatpally	04.10	06.10	02.00	BD	11kv line cut near R V Brudhavan aptt at Miyapur	-
2		Aliabad	Jaganguda	11kv	Medchal	06.00	06.40	00.40	BD	11KV Jumper Opened at Gayatri Company(11KV Pole damaged by Lorry)	-
1	RR E	Vinayak Nagar	Sharadha Nagar	11kv	Sainikpuri	11.07	11.38	00.31		Lezard fallen on 11Kv line at Chandragiri Colony (AE/OP)	-
2		CRPF	Chennapur	11kv	Keesara	16.50	17.50	01.00		Bird fallen on 11KV AB Switch near Dumping Yard T/F	-
3		Aushapur	Madharam	11kv	Keesara	12.30	13.40	01.10		Bird fallen on 11KV line near Somi Reddy Agricultural land at Madharam	-
4		Narapally	Prathap Singaram	11kv	Keesara	05.40	06.30	00.50		11KV Pin Insulator failed at Swarnagiri Colony	-
1	HYD N	K.I.M.S	My Fair Complex	11kv	Secunderabad	11.44	12.58	01.14	OL-Rph	Cable Jumper cut at Traffic P.S & removed loads of 11KV Police Lines feeder	