

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	1	1	1	1	1			
7	RR(E)	168	403									
8	Hyd	194	1044	1	2	1	2	1	2			
	Total	606	3055	2	3	2	3	2	3	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	4	0	4	0	4	0	0	
	Grand Total	1082	6468	2	7	2	7	2	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 17.08.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV Malkaram	Ratnalayam	33KV	Medchal	15:48	18:36	2:48		33KV Jumper cut and replaced at Ringroad	Ratnalayam	No
1	HYD N	Madhapur	KRIT (Raheja PTR-2)	33KV	Kalyan Ngr	19.50	20.05	00.15	OL-Bph	Cable damaged by Indira Garden Hotel construction workers	KRIT (Raheja PTR-2)	Loads transferred onto 33KV Madhapur-Train properties

TSSPDCL - LMRC / Corporate office

Date: 17.08.19

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Eduloor	Kurumarthi	11KV	Nalgonda	6:00	9:00	7:00	E/L	11KV Jumper cut	No
2		Ramadugu	Ramagudu	11KV	Miryalaguda	06.20	07.36	01.16	E/L	11KV Disk failure	No
3		Garidepally	Ponugodu	11KV	Huzurnagar	18.40	19.40	01.00	E/L	11KV Jumper cut	No
4		Garidepally	Kalmalcheruvu	11KV	Huzurnagar	09.20	11.20	02.00	E/L	11KV Jumper cut	No
1	RR N	GP Pally	GP Pally	11KV	Medchal	18:35	19:30	0:55		Tree fallen on the 11KV Line at Beerappa Gadda, GP Pally	No
1	HYD S	C.R.P.F	Barkas	11KV	Charminar	08.25	11.25	03.00	OL	HT Jumper cut near SS, Bird fault on lines at CRPF Campus & Breaker fault at SS	Arranged B/F on 11KV Balapur fdr
1	HYD C	Golconda	Darga Cable	11KV	Mehdipatnam	14.01	15.54	01.53	EL,OL-Rph	O/G Cable fault near SS	(15:24 Hrs) partial arraged B/F on 11KV O.U Colony fdr & remaining partial loads added on 11KV Aditya Nagar Cable fdr