

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403									
8	Hyd	194	1044	1	1	1	1	1	1			
	Total	606	3055	1	4	1	4	1	4	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		22		22		22			
3	MDK	107	933	1		1		1				
4	SDPT			1	4	1	4	1	4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	27	2	27	2	27	0	0	
	Grand Total	1082	6468	3	31	3	31	3	31	0	0	

TSSPDCL - LMRC / Corporate office

Date: 18.08.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Bollaram	ITC & Anrich	33KV	Patancheru	01.30	05.15	03.45		BD due to 2 No.s Pin Insulators failed	Bollaram	No
1	SDPT	Palamakula	Gonepally	33KV	Siddipet	12.12	16.30	04.18		Pole to Pole Survey no fault	Palamakula	No
1	HYD C	132KV Asif Nagar	Kulsumpura	33KV	Asif Ngr	09.12	09.25	00.13	EL,OL-Yph	Cable fault	132KV Asif Nagar	Loads transferred onto 132KV Imlibun SS via 33KV Gosha Mahal fdr

TSSPDCL - LMRC / Corporate office

Date: 18.08.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Udithyal	Udithyal	11KV	Jadcherla	06.50	09.50	03.00		Phase to Phase Near Veerannapally	-
1	NLG	P.D.Pally	P.D.Pally	11KV	Nalgonda	04.00	07.00	03.00	E/L	11KV jumper cut	-
2		P.D.Pally	K.Kondaram	11KV	Nalgonda	04.00	08.10	04.10	E/L	Insulator failed	-
3		P.D.Pally	Gundlapally	11KV	Nalgonda	04.00	06.10	02.10	E/L	11KV jumper cut	-
4		Pullemla	Pullemla	11KV	Nalgonda	07.00	09.06	02.06	E/L	tree branches on the line	-
5		Gattupal	Gattupal	11KV	Nalgonda	05.30	09.30	04.00	E/L	Disk failure	-
6		Thummadam	Narammagudem	11KV	Miryalaguda	05.36	06.18	00.42	E/L	Insulator Failed	-
7		Thummadam	Nethapuram	11KV	Miryalaguda	05.15	06.40	01.25	E/L	Conductor Snapped	-
8		Haliya	Anumula	11KV	Miryalaguda	04.56	05.57	01.01	E/L	Insulator Failed	-
9		Pottichelma	Ramannagudem	11KV	Miryalaguda	06.20	07.45	01.25	E/L	Insulator Failed	-
10		Nellikai	Chinthalapalem	11KV	Miryalaguda	06.52	07.48	00.56	E/L	Insulator Failed	-
11		K.M.Pally	Palvai	11KV	Devarakonda	06.00	11.20	05.20	E/L	Jumper Cutt	-
12		Nampally	Mandapuram	11KV	Devarakonda	07.00	08.30	01.30	E/L	11Kv Disc Failed	-
13		Palvai	Kalavapally	11KV	Devarakonda	05.00	11.30	06.30	E/L	11 Kv 2 Nos Insulator Failed	-
14		Palvai	M.K.gudam	11KV	Devarakonda	04.00	10.00	06.00	E/L	11Kv Insulator Failed	-
15		Thirumalagiri	Thatipamula	11KV	Suryapet	12.00	14.10	02.10	E/L	Insulator failed	-
16		Gaddipally	Kutubshapuram	11KV	Huzurnagar	09.15	11.30	02.15	EL	11 KV LINE SNAPPED	-
17		Garidepally	Appannapet	11KV	Huzurnagar	08.10	11.15	03.05	EL	11 KV JUMPER CUT	-
18	Anantharam	Hanmapuram	11KV	Bhongir	10.10	13.40	03.30	EL	11 kv Insulator Failed Near Hanmapuram Village	-	
19	NG.Bandal	Gandamalla	11KV	Bhongir	13.20	17.25	04.05	EL/OL	11 KV Disc Failed & 11 KV Insulator Failed Near Gandamalla Village	-	
20	Pamukunta	Jala	11KV	Bhongir	11.30	14.30	03.00	EL	11 kv Insulator Failed Near Jala Village	-	
21	Datherpally	Jangampally	11KV	Bhongir	08.20	10.40	02.20	EL	11 kv Insulator Failed Near Jangampally Village	-	
22	Choputuppal	Thangedipally	11KV	Choputuppal	06.30	10.00	03.30	EL	11 kv Disc Failed Near Thangedipally Village	-	
1	SDPT	Husnabad	Pandilla	11KV	Husnabad	13.10	15.30	02.20		Tree branch fallen on line same rectified	-
2		Potharam	Potharam Rural	11KV	Husnabad	08.10	08.40	00.30		HT/LT same rectified	-
3		Akunoor	Aknor Agl	11KV	Husnabad	15.05	17.20	02.15		Lines touched same rectified	-
4		Mustyal	Chuchanakota	11KV	Husnabad	10.05	13.45	03.40		Tree branch fallen on line same rectified	-
1	RR N	Madinaguda	B K enclave	11KV	Kukatpally	03.46	04.53	01.07	BD	11kv line PinInsulater failure at Sai Garden, BK Enclave	-
2		Bommarajpet	Karkamma	11KV	Medchal	13.05	14.25	01.20	BD	Bird fallen on the 11KV Pin Insulator at Gollolla Bhavi	-
3		Shameerpet	Shameerpet	11KV	Medchal	11.20	16.30	05.10	BD	11KV Disc failed at Modi Opposite, Shameerpet	-
1	HYD N	H.A.L.	Sri Rama	11KV	Bowenpally	14.55	16.40	01.45	EL	Tree branches fallen on lines at Sri Rama Company	-