

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	2	3	2	3	2			
2	NLG	144	988		6		6		6			
3	MDK	107	933	1		1		1				
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	8	4	8	4	8	0	0	
	Grand Total	1082	6468	4	12	4	12	4	12	0	0	

TSSPDCL - LMRC / Corporate office

Date: 20.08.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Achampet	Uppunuthala	33kv	Nagarkurnool	15.45	18.30	02.45	EL	AB Swtich open at Uppunuthala SS Due to Tree Branch follen on the line.		-
2		Balanagar	Induspin	33kv	Jadcherla	11.00	17.50	06.50	EL	Old C& R Panel replaced with new one		-
3		Wanaparthy	Rajapur	33kv	Wanaparthy	19.10	21.46	02.36	EL	33KV Breaker Problem at 132KV Wanaparthy SS		-
1	MDK	Gummadidala	GPSS-2	33kv	Patancheru	13.50	17.35	03.45		BD due to Conductor snapped at Gummadidala SS		-

TSSPDCL - LMRC / Corporate office

Date: 20.08.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Marikal	Chakalapally	11kv	Jadcherla	05.16	09.30	04.14		BD due to 11 KV wire cut near at chakalapally thanda	-
2		Kothamolgara	Elkicherla	11kv	Jadcherla	05.50	07.00	01.10		BD due to 11 kv jumper cut near Battupally thanda.	-
1	NLG	B.Chandupatla	Pachya thanda	11kv	Suryapeta	13.50	15.40	01.50	E/L	Insulator failed	-
2		Munagala	Turkagudem	11kv	Huzurnagar	10.15	13.15	03.00	EL	AB SWITCH PROBLEM	-
3		Raghunadapalem	Nakkagudem	11kv	Huzurnagar	12.30	15.30	03.00	EL	11 KV INSLATER FAILED	-
4		Pedaveedu	Lothuvagu	11kv	Huzurnagar	13.00	14.20	01.20	EL	AB SWITCH PROBLEM	-
5		Arlagaddagudem	Suraram	11kv	Nalgonda	12.30	13.40	01.10	EL	11KV line cut at Pavuralagudem	-
6		Akaram	Vallala	11kv	Nalgonda	06.00	09.00	03.00	EL	Tree branch fallen on 11KV line at SS-10	-
1	RR N	Jagathgiringutta	Jagathgiringutta	11kv	Medchal	10.00	10.35	00.35	BD	11KV Brass Patti cut & replacement at Kallu Compound, Ajaiah Nagar	-
2		Subhash Nagar	Jairam Nagar	11kv	Medchal	11.10	12.14	01.04	BD	11KV Line Cut & Replaced at Jyothi Nagar	-
3		KPHB	H M T	11kv	Kukatpally	15.05	16.14	01.09	BD	11kv Cable Diamage At rythubazar	-
1	RR E	IDA Uppal	Ram Reddy Nagar	11kv	Habsiguda	01.54	02.44	00.50		Tree fallen on 11kv line near Road No.03 at Ram Reddy Nagar	-