

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044	1	23	1	23	1	23			
	Total	606	3055	1	27	1	27	1	27	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	1	2	1	2	1			
2	NLG	144	988		9		9		9			
3	MDK	107	933	1		1		1				
4	SDPT			1	8	1	8	1	8			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	18	4	18	4	18	0	0	
	Grand Total	1082	6468	5	45	5	45	5	45	0	0	

TSSPDCL - LMRC / Corporate office

Date: 23.08.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Palkonda	33KV	Janampet	19.50	21.30	01.40	E/L	Cable Problem at MBNR Cotton Mill	Palkonda	No
2		Wanaparthy	Revally	33KV	Wanaparthy	06.15	11.08	04.53	E/L&O/L	No visible Fault	Revally	Alternate Supply Arranged From Pedda Kothapally at 7:45Hrs
1	MDK	Narayankhed	Poosalpad	33KV	Jogipet	02.01	06.45	04.44		BD due to Tree branches fallen on line	Poosalpad	-
1	SDP	Duddeda	Kondapak	33KV	Gajwel	06.40	07.55	01.15		Bird fallen on line	Kondapak	-
1	HYD C	132KV H' Sagar - Hyderguda	Hussain Sagar (PTR-6) (Alternate feeder)	33KV	H' Sagar	01.20	01.40	00.20	OL	33KV Cable End Kit failed at 33KV Nizam College SS	Hussain Sagar (PTR-6) (Alternate feeder)	-

TSSPDCL - LMRC / Corporate office

Date: 23.08.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Udityal	Udityal	11KV	Jadcherla	01.45	07.15	05.30		11 KV wire cut near Adavi baavulu.	-
1	NLG	Velminedu	Velminedu	11KV	Nalgonda	08.45	10.24	01.39	EL	11 KV Line Jumper Cut	-
2		Madgulapally	Kukkadam	11KV	Nalgonda	00.00	13.00	13.00	EL	HT/LT Lines Melt	-
3		Eduloor	G.B.Gudem	11KV	Nalgonda	13.13	16.40	03.27	EL	Jumper Cut Under SS-4	-
4		Dirsincherla	Narsaigudem	11KV	Huzurnagar	06.20	09.00	02.40	EL	11 KV JUMPER CUT	-
5		Mellacheruvu	Y .Madaram	11KV	Huzurnagar	06.00	08.15	02.15	EL	11 KV LINE SNAPPED	-
6		Mukundapuram	Somaram	11KV	Huzurnagar	04.00	06.30	02.30	EL	11 KV LINE SNAPPED	-
7		Ng.Bandal	Gandamalla	11KV	Bhongir	07.15	10.30	03.15	EL	11kv Disc Failed	-
8		Maryala	Chowderpally	11KV	Bhongir	05.30	09.00	03.30	EL	11 kv Insulator Failed	-
9		Golankonda	Mator	11KV	Bhongir	06.05	08.45	02.40	EL	11 kv Insulator Failed	-
1	SDP	Ahmadipur	Kolgur feeder	11KV	Gajwel	04.10	05.10	01.00		11Kv conductor snap	-
2		Bejjanki	Regulapally	11KV	Husnabad	13.30	17.10	03.40		Disc failure	-
3		Cherial Town	Cherial-Town	11KV	Husnabad	00.00	02.04	02.04		Insulator failure	-
4		Gandipally	Gandipally	11KV	Husnabad	00.10	15.30	15.20		Insulator failure	-
5		Gouravelly	Gouravelly Rural	11KV	Husnabad	00.00	09.40	09.40		Insulator failure	-
6		Husnabad	Husnabad Town-2	11KV	Husnabad	09.40	10.50	01.10		Conductor snapped	-
7		Bekkal	Bairanpally	11KV	Husnabad	12.30	14.00	01.30		Disc failure	-
8		Dhoolmitta	Arjunpatla	11KV	Husnabad	05.00	09.00	04.00		Tree fallen	-
1	RR N	KPHB	hydernagar	11KV	Kukatpally	15.24	16.40	01.16	EL	11kv Pin Insultor failure near PT No 36 Jayabharthinagar	-
2		Suraram	Sai Baba nagar	11KV	Jeedimetla	15.35	17.00	01.25	OL	11kv PIN Insultor FailureAt Hanuman Temple Pandu Basti	-
3		Kompally	Dholari Dhani	11KV	Medchal	23.42	01.20	01.38		Tripping Coil Burned in SS(Backfeeding to 11KV GBR Club feeder from Petbasheerabad SS)	-
1	RR E	St.No.08	Greenhills	11KV	Habsiguda	00.32	03.40	03.08		11KV Pin Insulator failed near Heritage shop beside line	-
1	HYD N	Tirumalgiri	Khanajiguda	11KV	VI	00.15	01.25	01.10	EL	Pin Insulator flash over at Indra Nagar	-
2		Srinagar Colony	Nagarjuna Nagar	11KV	X	00.25	01.35	01.10	EL	Post type Insulator flash over at Pallavi Estate	-
3		H.P.S	Post Office	11KV	IV	02.35	04.35	02.00	EL,OL-Bph	AB Cable fault at Lane No.4, Brahmanwadi	3:25Hrs partial fdr charged
4		Madhapur	APIIC-II	11KV	X	04.40	06.00	01.20	EL,OL	Cable fault	Arranged B/F on 11KV Patrika Nagar feeder

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD S	Malakpet B-Block	Samatha Degree College	11KV	VIII	00.05	01.58	01.53	OL-R&Yph	No Visible Fault (Due to Rain)	-
2		Ch' Baradari	Ch' Baradari	11KV	III	00.40	02.50	02.10	EL	No Visible Fault (Due to Rain)	-
3		Kulsumpura	Ambedkar Nagar	11KV	IX	00.41	03.28	02.47	EL	Cable fault at Ambedkar Nagar	-
4		Chanchalguda	Chanchalguda	11KV	VIII	00.45	02.44	01.59	OL	Cable End Kit failed at Jail Petrol Pump	-
5		Miralam	Jahanuma	11KV	III	00.50	02.25	01.35	EL	Coconut tree branches fallen on lines at Jahanuma	-
6		Miralam	Tadbun	11KV	III	00.52	02.35	01.43	EL	HG fuse burnt out at Koti Chaman	-
7		Gunj	Palton	11KV	VIII	00.54	02.17	01.23	All Indication	Tree branches fallen on lines at BKB School	-
8		Moosarambagh	Moosarambagh	11KV	VIII	00.55	02.15	01.20	EL	No Visible Fault (Due to Rain)	-
9		Seetharambagh	Asif Nagar	11KV	IX	01.15	04.27	03.12	EL,OL-Y&Bph	Cable fault at Friends Colony	-
10		Kandikal Gate	Rakshapuram	11KV	III	01.51	03.13	01.22	EL,OL	Tree branches fallen on lines at Shivalayam Temple	-
11		Salarjung	Pathergatti	11KV	III	01.55	03.10	01.15	EL,OL	Line touch to Wi-Fi Pole near Jain Mandir	-
12		Khilwath	Lal Darwaja	11KV	III	05.08	06.55	01.47	All Indication	Faulty 2No. DTR's at Lal Darwaja	-
13		Malakpet	M.M.H	11KV	VIII	08.25	09.55	01.30	EL,OL-R&Bph	2No. Disc Insulators flash over at M.M.H	-
14		Panjesha	Bibi Bazar	11KV	III	08.40	10.25	01.45	All Indication	AB Cable fault at Darjiling School	-
15		Attapur	Kishanbagh OH	11KV	III	11.56	13.25	01.29	EL,OL	AB Cable fault at Naganna Kunta	-
1	HYD C	Public Garden	Nampally Railway Station	11KV	I	15.42	16.44	01.02	EL,OL-R&Yph	Pin Insulator flash over at Nampally Rly Stn.	-
2		Golnaka	Moulana Azad Nagar	11KV	II	15.44	18.13	02.29		DTR fault at Laxmi Nagarayana Nagar (DTR comes under CBD-9)	-
3		Amberpet	Golnaka	11KV	II	15.45	17.05	01.20	EL	Tree branches fallen on lines at Tirumala Nagar	-
4		Golnaka	Nehru Nagar	11KV	II	16.14	18.34	02.20	OL-Bph	HT Line snapped at Bone Factory	-