

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		7		7		7			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>9</b>	<b>0</b>	<b>9</b>	<b>0</b>	<b>9</b>	<b>0</b>	<b>0</b>	



## TSSPDCL - LMRC / Corporate office

Date: 24.08.19

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Janpahad	Janpahad	11KV	Huzurnagar	19:00	21:35	2:35	EL	Insulator failed	No
2		Dirsincherla	Narasayagudem	11KV	Huzurnagar	06.50	09.45	02.55	EL	11KV Line cut	No
3		Kethapally	Kethapally	11KV	Nalgonda	16.00	17.10	01.10	EL	11KV Jumper Cut	No
4		Edloor	G.B.Gudem	11KV	Nalgonda	08.00	12.00	04.00	EL	11KV Jumper Cut	No
5		Edloor	Parada	11KV	Nalgonda	09.30	11.00	01.30	EL	11KV Jumper Cut	No
6		Pamanagundla	Yarrasani Gudem	11KV	Nalgonda	02.00	08.20	06.20	EL	11KV Jumper Cut	No
7		Anneparthi	Cherlapally	11KV	Nalgonda	3:00	6:45	3:45	EL	Insulator failed	No
1	HYD N	Zamistanpur	Sanjeevapuram	11KV	V	04.08	05.48	01.40	EL,OL	Tree branches fallen on lines at S.R Hospital & Twisted lines at Sunnam Batti	No
1	HYD C	Jawahar Nagar	Post Office	11KV	I	02.20	03.30	01.10	EL,OL-Rph	Cable fault at Post Office	No