

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		7		7		7			
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	8	0	8	0	8	0	0	
	Grand Total	1082	6468	0	10	0	10	0	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 26.08.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Annaram	Sangem	11KV	Suryapet	10.00	12.25	02.25	E/L	11Kv Insulator failed	-
2		Akupamula	Singaram	11KV	Huzurnagar	05.00	08.00	03.00	E/L	11Kv line snapped	-
3		Huzurnagar	Burugadda	11KV	Huzurnagar	07.00	10.00	03.00	E/L	11Kv jumpr cut	-
4		Paladugu	Duppally	11KV	Bhongir	03.00	05.00	02.00	E/L	11kv Line snapped near Narsapuram Village	-
5		Mamidala	Aregudem	11KV	Nalgonda	12.00	14.40	02.40	E/L	11KV jumper cut	-
6		Palem	Ogodu	11KV	Nalgonda	08.00	11.36	03.36	E/L	11KV jumper cut	-
7		Nakkalapally	Shapally	11KV	Nalgonda	01.00	08.40	07.40	E/L	11KV Insulator failed	-
1	SDPT	Chityala	Laddunoor	11KV	Husnabad	05.40	08.40	03.00		Line cut	-
1	HYD N	S.P.R.Hills	Karmika Nagar	11KV	Erragadda	06.06	08.30	02.24	EL,OL-Rph	AB Cable fault at Fathima Mutton Shop	-
1	HYD S	Aliyabad	Satherbagh	11KV	Charminar	20.50	22.40	01.50	EL	Twisted HT Lines at Danika Bagh	Arranged B/F on 11KV Gazi Banda feeder