

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988		3		3		3			
3	MDK	107	933		1		1		1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>5</b>	<b>1</b>	<b>5</b>	<b>1</b>	<b>5</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>9</b>	<b>1</b>	<b>9</b>	<b>1</b>	<b>9</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 27.08.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Hanwada	33kv	Mahabubnagar	12.55	13.55	01.00	E/L&O/L	Isolator Opened at Abhangapatnam Supply Stood OK	Hanwada	-

## TSSPDCL - LMRC / Corporate office

Date: 27.08.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Pedda Revally	Tirumalagiri	11kv	Jadcherla	08.00	10.00	02.00		Jumper Cut Near Modampally (V)	-
1	NLG	Duggala	Duggala	11kv	Devarakonda	07.45	08.45	01.00	EL	Earth Fault	-
2		Athmakur(S)	Gottimukkula gudem	11kv	Suryapet	08.55	10.00	01.05	EL	Conductor snapped	-
3		Munagala	Nelamarry	11kv	Huzurnagar	15.40	17.10	01.30	EL	11 KV LINE SNAPPED	-
1	MDK	Anrich Bollaram	Sulaxshana-II	11kv	Patancheru	02.30	03.30	01.00		BD Due to Jumper Cut	-
1	RR N	HMT	Manikya Nagar	11kv	Medchal	14.20	15.00	00.40		11KV Jumper Cut & Replaced at Chintal	-
2		Jeedimetla-II	Uttham Biskatay	11kv	Jeedimetla	07.58	09.20	01.22	OL	11AB Cable Failure ta RS Insuctrial ,phase-III	-
1	HYD S	Kandikal Gate	Phool Bagh	11kv	Charminar	13.37	14.45	01.08	All Indication	UG Cable fault at Madina Hotel	-----
2	HYD N	Addagutta	Addagutta	11kv	Secunderabad	13.55	15.30	01.35	EL,OL-Rph	Cable Fault	Arranged B/F on 11KV Ayan Nagar fdr