

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		3		3		3			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT				4		4		4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>11</b>	<b>0</b>	<b>11</b>	<b>0</b>	<b>11</b>	<b>0</b>	<b>0</b>	



TSSPDCL - LMRC / Corporate office

Date: 29.08.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Mamidala	Godavarigudem	11KV	Nalgonda	07.30	08.30	01.00	EL	Tree branches fallen on the Line	-
2		Tripuraram	Bejjikal	11KV	Miryalguda	09.25	11.15	01.50	EL	Jumper cut	-
3		Addagudur	Kotamarthy	11KV	Bhongir	03.00	07.00	04.00	EL	11kv Line Snpped	-
1	SDP	Wardarajpur	11KV Wardarajpur Agl feeder	11KV	Gajwel	18.20	18.55	00.35		Bird fallen on the line	-
2		Gouravelly	Gudatipally	11KV	Husnabad	02.20	05.20	03.00		3 Ph BD 1 Ph ok	-
3		Guggilla	Gagillapur	11KV	Husnabad	22.05	00.00	01.55		3 Ph BD 1 Ph ok	-
4		Guruvannapet	Posanpally	11KV	Husnabad	00.00	05.55	05.55		Insulator failure	-
1	RR N	Athiwelly	Ravalkole Thanda	11KV	Medchal	14.45	16.10	01.25	BD	Bird fallen on the 11KV Line at Kaveri Company	-
1	HYD N	Marredpally	Railway Colony	11KV	C-VI	08.15	09.30	01.15	Auto Reclosure tripped	No Visible Fault	-
2		Marredpally	Railway Colony	11KV	C-VI	09.50	11.05	01.15	EL,OL-Bph	Cable fault at Sanjay Nagar (1No. DTR Kept Off)	-
1	HYD C	Zamistanpur	L.N Nagar	11KV	II	01.23	09.12	07.49	EL,OL-Y&Bph	Tree branches fallen on lines at Bangaru Maisamma Temple	-