

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		13		13		13			
6	RR(N)	54	550		10		10		10			
7	RR(E)	168	403		7		7		7			
8	Hyd	194	1044		15		15		15			
	Total	606	3055	0	45	0	45	0	45	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988	1	12	1	12	1	12			
3	MDK	107	933	5	6	5	6	5	6			
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	7	19	7	19	7	19	0	0	
	Grand Total	1082	6468	7	64	7	64	7	64	0	0	

TSSPDCL - LMRC / Corporate office

Date: 30.08.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Nagarkurnool	lthole	33KV	Nagarkurnool	21.52	06.15	08.23		No visible fault	lthole	-
1	NLG	Nalgonda	Indoor	33KV	Nalgonda	04.50	06.10	01.20	E/L	Tree branch fallen on 33Kv line at Prakasham Bazar		-
1	MDK	Kandi	HFC I	33KV	Sangareddy	16.50	18.30	01.40		BD due to Insulator failed	HFC I	-
2		Zaheerabad	Chota Hyderabad	33KV	Zaheerabad	18.35	21.50	03.15		BD Due to Jumper cut	Chota Hyderabad	-
3		Jogipet	Laxmi sagar	33KV	Jogipet	15.50	18.30	02.40		BD due to Insulator failed	Laxmi sagar	-
4		Gummadidala	Gummadidala	33KV	Patancheru	16.20	19.45	03.25		BD due to Jumper cut	Gummadidala	-
5		Borapatla	Waddepally	33KV	Jogipet	01.12	06.30	05.18		BD due to Disk failed	Waddepally	-

TSSPDCL - LMRC / Corporate office

Date: 30.08.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Peddathanda	Peddathanda	11KV	Bhongir	08.15	09.10	00.55	E/L	11kv Line snapped near Peddathanda (V)	-
2		Nemaragomula	Jamilapet	11KV	Bhongir	03.00	07.50	04.50	E/L	11kv Disc Failed near Jamilapet (V)	-
3		Annaram	Annaram	11KV	Suryapet	06.00	08.40	02.40	E/L	11Kv Insulator failed	-
4		Bibigudem	Chivvemla AGL	11KV	Suryapet	09.30	10.30	01.00	E/L	11Kv Jumper cut	-
5		Thogarrai	Ganapavaram	11KV	Huzurnagar	06.50	07.50	01.00	E/L	11Kv jumper Ccut	-
6		Ravipahad	Appanngudem	11KV	Huzurnagar	07.00	10.00	03.00	E/L	Bird fall on 11kv line	-
7		Sirikonda	Sirikonda	11KV	Huzurnagar	09.00	12.00	03.00	E/L	Squirrel fall on 11kv line	-
8		Palem	Ogodu	11KV	Nalgonda	01.00	09.55	08.55	E/L	11KV Insulator failed	-
9		Arjalabavi	Arjalabavi	11KV	Nalgonda	11.50	11.50	00.00	E/L	11KV Insulator failed	-
10		Narkatpally	M.Yadavally	11KV	Nalgonda	06.15	08.15	02.00	E/L	11KV jumper cut	-
11		Eduloor	Parada	11KV	Nalgonda	05.20	09.30	04.10	E/L	HT/LT melting at SS-12	-
12		Nakrekal	Kadaparthi	11KV	Nalgonda	04.35	08.00	03.25	E/L	11KV jumper cut	-
1	MDK	Patancheru Town	Shanthinagar	11KV	Patancheru	18.00	19.00	01.00		BD due to Insulator failed	-
2		Patancheru Town	Town Ind	11KV	Patancheru	17.40	20.20	02.40		BD due to Insulator failed	-
3		Gummadidala	Bell Remedies	11KV	Patancheru	00.10	06.10	06.00		BD due to Tree branches fallen on line	-
4		EPIP-II	Srinivasa Costing	11KV	Sangareddy	02.54	06.20	03.26		BD due to Tree branches fallen on line	-
5		Munipally	Budhera	11KV	Sangareddy	13.00	13.35	00.35		BD due to Insulator failed at Budhera VG	-
6		Sadasivpet	TSM	11KV	Sangareddy	16.42	18.47	02.05		BD due to Insulator failed	-
1	SDP	Dharmaram	Nandaram	11KV	Husnabad	14.30	14.55	00.25		Bird died on conductor	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR S	Lanco Hills	Khajaguda	11KV	Gachibowli	01.09	03.11	02.02	BD	11kv Pin-insulator failed near Niharika apartment at Khajaguda	-
2		Madinaguda	Hafeezpet	11KV	Gachibowli	01.35	04.00	02.25	BD	Tree fallen on the 11kv line near Sai krupa apartment at Madinaguda	-
3		Chanda Nagar	Engineers Enclave	11KV	Gachibowli	01.30	04.00	02.30	BD	11kv Pin-insulator failed near Nirmal ratna apartment at Engineers Enclave	-
4		Nanakramguda	Church	11KV	Gachibowli	02.12	03.32	01.20	BD	Phoneix HT service 11kv Pin-insulator failed at Nanakramguda	-
5		IJM	New 6th Phase	11KV	Gachibowli	04.05	05.15	01.10	BD	11kv Pin-insulator failed near Plot no-151-152 at New 6th Phase	-
6		Gachibowli	Aparna	11KV	Gachibowli	08.40	11.00	02.20	BD	11kv Pole damaged by Lorry at Aparna	-
7		IIIT	APHB Colony	11KV	Gachibowli	18.35	19.35	01.00	BD	Due to heavy rain and wind (B/F From Jayabheri feeder)	-
8		Chanda Nagar	Engineers Enclave	11KV	Gachibowli	19.25	20.35	01.10	BD	Tree branches fallen on the 11kv line at Engineers Enclave	-
9		IJM	9th Phase	11KV	Kondapur	01.20	02.35	01.15	BD	Public T/F Plinth bend 11kv jumper cut at Vijetha super market, Auto stand	-
10		Kaithalapur	Kaithalapur	11KV	Kondapur	01.45	03.15	01.30	BD	11kv Pin-insulator failed near Grave yard at Kaithalapur	-
11		Borabanda	Padmavathi Nagar	11KV	Kondapur	01.30	02.55	01.25	BD	11kv Line snapped nera TDP office at Allapur	-
12		Lodha	RTO Office	11KV	Kondapur	12.30	13.58	01.28	BD	Cable failed at RTO Office	-
13		IJM	9th Phase	11KV	Kondapur	15.58	18.30	02.32	BD	11kv Pin-insulator failed at Forum mall	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	Nizampet	Bhavyas	11KV	Kukatpally	17.52	19.00	01.08	BD	11kv Pin Insultor Failure Near Raghvendra Tiffins Centre Nizampet	-
2		Jeedimetla-IV	Aai Matha	11KV	Jeedimetla	03.12	05.30	02.18	BD	11kv Breaker Cable Failure In Sub station	-
3		Petbasheerabad	Balaji Hospital	11KV	Medchal	01.35	03.35	02.00	BD	No Fault(Heavy Rain)	-
4		Petbasheerabad	Balaji Hospital	11KV	Medchal	17.20	17.50	00.30	BD	11KV AB Cable failed at Narayan School, Angadipet	-
5		Dulapally	Dulapally Village	11KV	Medchal	18.22	18.50	00.28	BD	11KV Line touched to Internet cable at Dulapally Village	-
6		Shameerpet	33KV Leo Meridian	11KV	Medchal	02.10	05.00	02.50	BD	No Fault	-
7		Kandlakoya	Kandlakoya	11KV	Medchal	01.50	02.40	00.50	BD	Tree Branch fallen on the 11KV Line at Nirmala Garden, Kandlakoya	-
8		Nuthankal	Nuthankal	11KV	Medchal	15.55	16.35	00.40	BD	Bird fallen on the 11KV Line at Nuthankal Village	-
9		Gowdavelly	IDA Gowdawelly	11KV	Medchal	16.40	17.50	01.10	BD	11KV Pin Insulator Failed at HP Petrol bunk,Basaragadi	-
10		GP Pally	GP Pally	11KV	Medchal	16.45	18.10	01.25	BD	11KV Pin Insulator failed at Beerappagadda, GP Pally	-
1	RR E	Moula-Ali	Spectra	11KV	Sainikpuri	06.00	06.50	00.50		11Kv Disk fail at Barath Steel IDA Moula-Ali (Artisan/Janaiah)	-
2		Sainikpuri	Eshwaripuri	11KV	Sainikpuri	23.48	00.47	00.59		11K Disk fail on line AB Switch Open at Madhavapuri Colony (Artisan/Yakaiah)	-
3		Kushaiguda	Kushaiguda	11KV	Sainikpuri	00.15	01.50	01.30		Lorry Dashed on 100Kv DTR at Vimal Showroom on Load Add on Saibaba Temple feeder	-
4		Nagaram	Bandlaguda	11KV	Keesara	17.15	18.33	01.18		Tree branches fallen on 11kv line at Petro bunk	-
5		GKSR	Yamunnapet	11KV	Keesara	02.16	04.00	01.44		Disk fail at sai teja venchare	-
6		Keesara	Bogaram	11KV	Keesara	18.25	19.11	00.46		Pin insulotr fail at Petrol bunk Keesara	-
7		Keesara	Vardhana	11KV	Keesara	16.35	18.55	02.20		Tree branches fallen on 11kv line at Kundanpally	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	Gunrock	Surya Enclave	11KV	C-VI	01.40	02.50	01.10	EL,OL-Rph	No Visible Fault	-----
2		Road No.22	Obul Reddy	11KV	X	02.10	03.10	01.00	EL,OL-Yph	RMU fault at Tennis Court	Arranged B/F on 11KV Hylam Colony feeder
3		Bowenpally	Jaya Nagar	11KV	VI	02.15	03.30	01.15	EL	Tree branches fallen on lines at Jaya Nagar	-----
4		New Bowenpally	Ali Complex	11KV	VI	02.35	04.00	01.25	EL,OL	Insulator flash over at Ali Complex & Ford Show Room HT Service fault	-----
5		Sanjeevaiah Park	N.B.T Nagar	11KV	IV	03.01	04.30	01.29	OL-R&Bph	No Visible Fault	-----
1	HYD S	Miralam	Jahanuma	11KV	III	01.30	02.40	01.10	EL,OL	No Visible Fault	-----
2		Aliyabad	Shamsheer Gunj	11KV	III	01.34	02.44	01.10	EL	Tree branches fallen on lines at Komatiwadi	-----
3		Moosarambagh	Dilsukh Nagar	11KV	VIII	02.10	05.06	02.56	EL,OL	No Visible Fault	Arranged B/F on 11KV Shalivahan Nagar fdr
4		Khilwath	Charminar	11KV	III	16.35	18.14	01.39	EL	DTR fault at Setwin	-----
5		Petlaburz	Murali Nagar	11KV	III	17.30	18.35	01.05	EL,OL	Tree branches fallen on lines at Labour Adda	-----
6		Falaknuma	Aliyabad	11KV	III	18.58	21.18	02.20	EL,OL-Rph	Cable fault at Aliyabad	Arranged B/F on 11KV Rooplal Bazar feeder
1	HYD C	Gudimalkapur	Amba Garden	11KV	VII	00.45	02.15	01.30	EL,OL	Pin Insulator flash over at Vijaya Vihar Apts	-----
2		Amberpet	C.P.L	11KV	II	03.20	07.45	04.25	OL-Y&Bph	Tree branches fallen on lines at Patel Nagar	-----
3		Zamistanpur	Jamai Osmania	11KV	II	05.18	07.38	02.20	EL,OL-Yph	Disc Insulator flash over at Ambedkar Ngr	-----
4		Golconda	Aditya Nagar UG	11KV	VII	16.04	17.25	01.21	EL	Big tree fallen on lines & 2No. Pin Insulators flash over	-----