

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		7		7		7			
7	RR(E)	168	403		4		4		4			
8	Hyd	194	1044		23		23		23			
	Total	606	3055	0	34	0	34	0	34	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3		3		3				
2	NLG	144	988		8		8		8			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	8	3	8	3	8	0	0	
	Grand Total	1082	6468	3	42	3	42	3	42	0	0	

TSSPDCL - LMRC / Corporate office

Date: 02.12.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	Kollur	33KV	Jadcherla	20.45	22.45	02.00	E/L	for LA fail at Udithyal SS	Kollur	-
2		Maddur	Kothapally	33KV	Narayanapet	13.05	15.30	02.25	E/L	Line Patrolling No visible fault	Kothapally	-
3		Alampur	Shanthinagar-I	33KV	Gadwal	13.05	16.50	03.45	O/L	Tree Fallen on the 33KV Line Near Mesamma Gattu Village	Shanthinagar-I	-

TSSPDCL - LMRC / Corporate office

Date: 02.12.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Chedella	Chedella	11KV	Suryapet	05.30	07.35	02.05	EL	Conductor snapped	-
2		Jammigadda	Estate	11KV	Suryapet	15.25	17.50	02.25	EL	Insulator failed	-
3		G T Giri	G T Giri	11KV	Suryapet	15.34	17.45	02.11	EL	Jumpur cut	-
4		Dirisncherla	Yellapuram	11KV	Huzurnagar	05.00	07.00	02.00	OL	Due to 11Kv line cutted	-
5		Chamapur	Chandepally	11KV	Bhongir	07.00	09.30	02.30	EL	11kv Insulator Failed near Chandepally Village	-
6		Mothkur	Areygudem	11KV	Bhongir	08.10	09.30	01.20	EL	11 kv Line Snapped Near Areygudem Village	-
7		Vemulakonda	Vemulakonda	11KV	Choutuppal	12.15	17.30	05.15	EL	11kv Line Sanpped near Vemulkonda Village	-
8		MT.Pally	Mogalipaka	11KV	Choutuppal	13.35	16.10	02.35	EL	11kv Pin Insulator Failed near Mogalipaka Village	-
1	RR N	Kompally	Kompally	11KV	Medchal	01.30	02.20	00.50	BD	100KVA DTR AB Cable Failed at Dulapally X road	-
2		Jeedimetla-I	Thirumala	11KV	Jeedimetal	20.45	22.15	01.30	EL	Due to Heavy rain	-
3		Jeedimetla-I	JETL	11KV	Jeedimetal	20.40	22.20	01.40	EL	Due to Heavy rain	-
4		Jeedimetla-I	Phase-II	11KV	Jeedimetal	21.00	23.30	02.30	EL	Due to Heavy rain	-
5		Jeedimetla-I	Sudarshan Drugs	11KV	Jeedimetal	21.00	22.10	01.10	EL	Due to Heavy rain	-
6		Jeedimetla-I	Balaji	11KV	Jeedimetal	21.30	22.30	01.00	EL/OL	Due to Heavy rain	-
7		KPHB	Bagynagar	11KV	Kukatpally	22.00	00.00	02.00	EL	11KV Pin insulator failed at saibaba Temple	-
1	RR E	Sainikpuri	Saipuri	11KV	Sainikpuri	20.20	21.05	00.45		11Kv line Patrolling done but no fault found (FOC Bhaskar)	-
2		Vayupuri	Ambedkar Nagar	11KV	Sainikpuri	21.22	22.15	00.53		End Kit failure at Shiva Nagar near Sai Baba Temple (AE)	-
3		NN Colony	Yallareddy	11KV	Sainikpuri	22.15	23.20	01.05		11KV Disk Failed At Yallareddy	-
4		Sainikpuri	Ramalayam	11KV	Sainikpuri	21.31	22.25	00.54		11KV Insulator failed at Defence Colony (AE)	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	Bansilalpet	Nagannakunta	11KV	V	20.47	23.21	02.34	EL	Pin Insulator flash over at Grave Yard	-----
2		Ayyappa Society	Kummari Basti	11KV	X	21.15	22.20	01.05	EL,OL-R&Bph	No Visible Fault	-----
3		Gymkhana	Balamrai	11KV	C-VI	21.25	22.40	01.15	EL	Kite Sticks fallen on lines at Balamrai	-----
4		Road No.22	UCO Bank	11KV	X	22.05	23.10	01.05	EL,OL-Bph	Cable fault at H & D Mall	-----
5		Chilkaiguda	Pragatools	11KV	V	22.55	00.20	01.25	All Indication	Suspected Cable fault at Musheerabad X-Roads	Arranged B/F on 11KV R.L.H.C fdr
6		Durga Nagar	Durga Nagar	11KV	IV	23.43	01.05	01.22	EL	-----	Arranged B/F on 11KV Hyd.Central fdr
1	HYD S	Yakuthpura	Khan Nagar	11KV	VIII	19.10	21.50	02.40	EL,OL-Bph	AB Cable fault at Khan Nagar	-----
2		Yakuthpura	Dharmavanth	11KV	VIII	19.42	21.40	01.58	EL,OL-Rph	-----	Arranged B/F on 11KV Bada Bazar feeder
3		Ch' Baradari	Ramnaspura	11KV	III	21.15	22.30	01.15		2No. DTR's Jumpers at I.T.I Ground	-----
4		Devibagh	Bondalguda	11KV	III	21.41	23.35	01.54	EL	Pin Insulator flash over at Bahadurpura P.S	-----
5		Falaknuma	Chatrinaka	11KV	III	22.10	23.25	01.15	EL,OL	Pin Insulator flash over at Musq Mahal	-----
6		Salarjung	Q.Q Stadium	11KV	III	23.02	01.09	02.07	All Indication	No Visible Fault	-----
7		Miralam	Madina Masjid	11KV	III	23.15	00.00	00.45	EL,OL-Bph	No Visible Fault	-----
1	HYD C	S.D.Hospital	Humayun Nagar	11KV	VII	01.35	02.50	01.15	EL,OL-Rph	AB Cable Jumper cut at KFC DTR	-----
2		Zamistanpur	L.N Nagar	11KV	II	20.08	22.10	02.02	EL,OL	Breaker problem at SS	Arranged B/F on 11KV Mother Dairy feeder
3		Bathkammakunta	Ramalayam	11KV	II	20.13	21.43	01.30	EL	Cable burntout at Mother Dairy DTR	-----
4		Industrial Area	Shankermutt	11KV	II	20.15	21.20	01.05	EL	No Visible Fault	-----
5		A.C Guards	Shanthi Nagar	11KV	VII	20.42	22.56	02.14	EL	HT Jumper cut at Amul Ice Cream & Tree branches fallen on lines at Shanthi Ngr	-----
6		Chilkaiguda	Golconda X-Roads	11KV	II	20.50	22.04	01.14	EL	No Visible Fault	-----
7		Mothi Mahal	M.D Lines	11KV	VII	20.50	22.32	01.42	EL,OL	Pin Insulator flash over at Shatam Kalab	-----
8		Asif Nagar	N.S.F Colony	11KV	VII	20.55	22.48	01.53	EL	Pin Insulator flash over at Al Karim Colony	-----
9		Golnaka	Tulasi Nagar	11KV	II	20.56	22.07	01.11	EL	Coconut branches fallen on lines at Sri Balaji Apts	-----
10		Vittalwadi	APCO	11KV	II	21.50	23.40	01.50	EL	Pin Insulator flash over at Telugu Academy	-----