

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933	1	2	1	2	1	2			
4	SDPT			1	1	1	1	1	1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	6	2	6	2	6	0	0	
	Grand Total	1082	6468	2	8	2	8	2	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 04.12.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Kandi	Sangareddy Town-I	33KV	Sangareddy	12.00	14.40	02.40	B/D Due to Conductor snapped	Sangareddy Town-I		-
1	SDP	Gajwel	B v Pur	33KV	Gajwel	07.30	11.05	03.35		Bird fallen on line	B v Pur	-

TSSPDCL - LMRC / Corporate office

Date: 04.12.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Cherkupally	Cherkupally	11KV	Nalgonda	14.10	16.00	01.50	EL	Snake burnt on 11KV line at village end	-
2		Nagaram	D.Kothapally	11KV	Suryapet	12.40	15.15	02.35	E/L	Conductor Snapped	-
3		Mattampally	Mattampally Town	11KV	Huzurnagar	09.06	10.35	01.29	EL	11 KV LINE SNAPPED	-
1	MDK	Patancheru	MIA-II	11KV	Patancheru	11.45	14.38	02.53		B/D due to Tree branches fallen on the line	-
2		Kisateddtpet	Patelguda	11KV	Patancheru	14.50	17.25	02.35		B/D due to Insulator failed	-
1	SDP	Guruvannapet	Guruvannapet	11KV	Husnabad	03.45	10.50	07.05		BD, Conductor snapped	-
1	RR S	Chandanagar	Rail Vihar	11KV	Gachibowli	12.05	13.25	01.20	BD	Tree fallen on the 11kv line near Amaron Apts at Huda trade centre.	-
1	RR N	Gowdavelly	Ayodhya	11KV	Medchal	10.05	11.45	01.40	BD	11KV Jumper Cut & replacement at Gowdavelly X Road	-