

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988	1	3	1	3	1	3			
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	5	1	5	1	5	0	0	
	Grand Total	1082	6468	1	7	1	7	1	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 09.11.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Mattampally	BNL Thanda	33kv	Huzurnagar	02.40	07.30	04.50	EL/OL	33Kv Line Snapped	BNL Thanda	-

TSSPDCL - LMRC / Corporate office

Date: 09.11.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Karvena	Kothur	11kv	Jadcherla	05.02	08.05	03.03		11KV Wire cut near Kothur Thanda	-
1	NLG	Dirincherla	Narsaigudem	11kv	Huzurnagar	05.00	06.45	01.45	E/L	11Kv Line Snapped	-
2		Mattapally	Sulthapuram thanda	11kv	Huzurnagar	11.50	13.20	01.30	E/L	11Kv Line Snapped	-
3		Mothkur	Kondagadapa	11kv	Bhongir	15.00	15.50	00.50	EL/OL	11kv Pole Damedged In lowry & Fallen at 11kv Line near Thatimatta (V)	-
1	SDPT	Dharmaram	Dharmaram(R.)	33kv	Husnabad	08.05	10.25	02.20		B/D due to tree branches fallen on the line	
1	RR N	DP Pally	Gagillapur	11kv	Jeedimetla	10.00	12.20	02.20	BD	11kv Disk Failure At Nagloor & 11Kv Out going Jumper cut In sub station	-
1	RR E	Kushaiguda	Sriram Nagar	11kv	Sainikpuri	05.10	05.55	00.45		11Kv line Jumper cut on sidaram at Gandhi Nagar (AE/OP)	-