

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044	1	2	1	2	1	2			
	Total	606	3055	1	2	1	2	1	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	3	1	3	1	3	0	0	
	Grand Total	1082	6468	2	5	2	5	2	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 11.12.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Amangal	Kadthal	33KV	Shadnagar	10.50	11.00	00.10	E/L&O/L	Due to Moneky fallen on the Line	Kadthal	Alternate Supply Given From 33KV Mudwin at 11:00Hrs.
1	HYD N	132KV Gunrock	Nehru Nagar (Idle)	33KV	Nehru Ngr	00.15	18.30	00.00	OL-Bph	Cable puncture at JBS Check Post	Nehru Nagar (Idle)	-

TSSPDCL - LMRC / Corporate office

Date: 11.12.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Pamangundla	Express	11KV	Nalgonda	10.00	11.20	01.20	EL	Jumper cut	-
2		Bibigudem	Bibigudem Agl	11KV	Suryapet	03.40	07.30	03.50	EL	Insulator flashover	-
3		Raghunadapalem	Gundlapally	11KV	Huzurnagar	07.00	08.30	01.30	EL	11 KV LINE SNAPPED	-
1	HYD N	Bowenpally	Plassy Line	11KV	VI	19.00	20.05	01.05	EL,OL-Rph	Breaker fault at SS & Pin Insulator flash over at Plassy Line	Arranged B/F on 11KV Ali Complex fdr
1	HYD C	Bathkammakunta	Shivam	11KV	II	16.30	18.24	01.54	OL-Rph	Bird fault on DTR at Vidya Nagar Railway Station	Partial 50% feeder charged (16:50 Hrs)