

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550									
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>0</b>	



## TSSPDCL - LMRC / Corporate office

Date: 13.12.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	G.T Giri	Thirumalagiri	11KV	Suryapet	10.20	12.00	01.40	E/L	11Kv Conductor snapped	-
2		Bethavolu	Bethavolu	11KV	Huzurnagar	21.10	22.20	01.10	E/L	11Kv Conductor snapped	-
3		Dirincherla	Yallapuram	11KV	Huzurnagar	13.15	14.45	01.30	E/L	11Kv Insulator Failed	-
1	RR S	IIIT	IVRCL	11KV	Gachibowli	16.41	18.24	01.43		11kv Cable End Kit failure at Sub-station Opposite.	-
1	RR E	IDA Uppal	Ram Reddy Nagar	11KV	Habsiguda	09.25	10.15	00.50		11KV Cable failed near Dumping Yard & B/F supply taken from 11KV Sri Nagar Colony feeder	-
2		Cherlapally-I	Surana	11KV	Sainikpuri	13.20	14.00	00.40		11Kv line cut at SGT Forgin Compony (L Insp Satyanarayana)	-
1	HYD C	Durga Nagar	Krishna Nagar	CEN	II	04.20	05.46	01.26	EL,OL-Bph	Cable fault	-