

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	2	1	2	1	2			
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	4	1	4	1	4	0	0	
	Grand Total	1082	6468	1	8	1	8	1	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 14.12.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Nagarkurnool	lthole	33KV	Nagarkurnool	09.08	11.38	02.30	O/L	33KV Jumper Cut at 132KV Nagarkurnool SS	lthole	-

TSSPDCL - LMRC / Corporate office

Date: 14.12.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Marikal	Malkapur	11KV	Jadcherla	12.10	13.10	01.00		Due to 11 KV jumper cut near Bangarampally (V)	-
2		Janampet	Polkampally	11KV	Jadcherla	11.01	12.30	01.29		Due to 11 kv line cut near polkampally.	-
1	NLG	Dirincherla	Yallapuram	11KV	Huzurnagar	14.10	15.30	01.20	EL	11 KV LINE SNAPPED	-
2		Mothkur	Mothkur rural	11KV	Bhongiri	14.00	16.15	02.15	OL	11 kv Line snapped Near Rajannagudem	-
1	RR S	Nanakramguda	Church	11KV	Gachibowli	03.12	04.14	01.02	BD	11kv AB Cable End Kit failure near SC Basti community hall at Nanakramguda	-
1	RR N	Athiwelly	PHI	11KV	Medchal	06.40	10.05	03.25	BD	11KV Line cut and replaced at PHI	-
1	RR E	IDA uppal	Devendar nagar	11KV	Habsiguda	16.00	16.50	00.50		11KV Line cut at Nobal hospital	-
1	HYD C	Toli Chowki	Hakeemsha	11KV	VII	00.22	01.27	01.05	EL,OL-Rph	Cable fault	Arranged B/F on 11KV Brindavan Colony feeder