

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1		1		1				
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044									
	Total	606	3055	1	2	1	2	1	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	6	0	6	0	6	0	0	
	Grand Total	1082	6468	1	8	1	8	1	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 15.12.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV LGM Pet	33KV LGM Pet	33KV	Medchal	05.30	08.02	02.32	BD	No visible Fault	33KV LGM Pet	-

TSSPDCL - LMRC / Corporate office

Date: 15.12.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Marrikal	Marrikal	11kv	Jadcherla	03.20	09.15	05.55		11KV Wire Phase to Phase near Marrikal	-
1	NLG	Kethapally	Inupamula	11kv	Nalgonda	15.00	16.10	01.10	EL	Jumper cut	-
2		Akaram	Akaram	11kv	Nalgonda	06.10	07.30	01.20	EL	Insuleter failed	-
3		Gaddipally	Gaddipally	11kv	Huzurnagar	10.25	11.35	01.10	EL	11 KV LINE SNAPPED	-
4		Nandanam	Anajipur	11kv	Bhongir	06.30	09.00	02.30	EL	25 KVA DTR Failed	-
1	SDPT	Husnabad-2	Husnabad Town-4	11kv	Husnabad	12.15	13.10	00.55		Line fault	
1	RR E	Malkajgiri	Dayanand Nagar	11kv	Sainikpuri	09.00	11.04	02.04		11Kv cable failed at Uttam Nagar Common (AE/Mirjalguda) due to safety purpose	-
2		Narapally	Prathap Singaram	11kv	Keesara	00.05	00.50	00.45		11KV Pin Insulator failed at Korremula	-