

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1		1		1				
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	1	1	1	1	1	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT			1		1		1				
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	3	2	3	2	3	0	0	
	Grand Total	1082	6468	3	4	3	4	3	4	0	0	

## TSSPDCL - LMRC / Corporate office

Date: 16.12.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Thirumalaipally	Veltoor	33KV	Wanaparthi	07.10	11.15	04.05	E/L	Jumper Cut at Palem SS & Pin Insulator Damaged near Palem (V)	Veltoor	-
1	SDPT	Husnabad	Koheda	33KV	Husnabad	09.55	13.35	03.40		Pin binding problem	Koheda	-
1	RR N	132KV LGM Pet	33KV LGM Pet	33KV	Medchal	05.22	10.00	04.38		Tree fallen on the 33KV line near Aliabad SC Colony	33KV LGM Pet	-

## TSSPDCL - LMRC / Corporate office

Date: 16.12.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Karkonda	Rudraram	11KV	Jadcherla	09.46	14.10	04.24		11KV Jumper Cut Near Rudraram(V)	-
1	NLG	Kasarabadha	T.K.Pahad	11KV	Suryapet	12.40	14.00	01.20	E/L	Insulator Flashover	-
2		Gondriyala	Chimiryala	11KV	Huzurnagar	04.00	07.00	03.00	OL	Due to 11Kv Line Snapped	-
1	HYD S	Falaknuma	Falaknuma OH	11KV	III	16.15	17.30	01.15	EL,OL	Cable fault	Arranged B/F on 11KV Falaknuma UG Cable fdr