

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	1	2	1	2	1	2			
3	MDK	107	933		2		2		2			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	4	1	4	1	4	0	0	
	Grand Total	1082	6468	1	6	1	6	1	6	0	0	

TSSPDCL - LMRC / Corporate office

Date: 19.12.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Suryapet	Chandupatla	33KV	Huzurnagar	00.50	07.30	06.40	EL/OL	33 KV Jumpet Cut	-

TSSPDCL - LMRC / Corporate office

Date: 19.12.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Mukundapuram	Kalluru	11KV	Huzurnagar	12.30	13.30	01.00	EL	11 KV Pole Damaged	-
2		Paladugu	Duppelly	11KV	Bhongiri	04.15	10.00	05.45	EL	11 kv Line Snapped Near Duppelly Village 3 Phase B/d Single phase ok	-
1	MDK	Anrich Bollaram	Mallampet	11KV	Patancheru	15.30	16.20	00.50		B/D due to Jumper cut	-
2		Bonthapally	Ayyappa	11KV	Patancheru	13.05	13.35	00.30		B/D due to Jumper cut	-
1	RR N	Jeedimetla SS III	vinayaka nagar	11KV	Jeedimetla	11.40	12.55	01.15		11kv AB Cable failure near Mylon Company 50% load added to Pipeline feeder	-
2		Medicity	Rajabollaram	11KV	Medchal	06.30	08.00	01.30		Bird fallen on the 11Kv Line at SV Rao Thota, Rajabollaram	-